

PRESSURE SWITCH DATA

Form 21605

TEST NO. 178-03-24

DEVICE 77PS	DATE REQUESTED 10/30/91	REQUESTED BY Steve Offley	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. DonPrisco	DATE STARTED 11/19/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford MY '91 Electronic Speed Control Deactivate PS			

CUSTOMER:

PURPOSE OF TEST: Attempt to control the clamping and wetting of the Repton.

PROCEDURE: Over

- all use 8 cent washers for quick results
- all crimped on AMI
- sensor @

Table								
Device #	Repton	Repton	Act/Rel					Failure
178-03-01	Standard	Spacer	116/60					
-02			145/61					
-03			128/62	176.6	54.2			
-04			122/59	93	17			
-05			126/60					
-06			127/57					
178-03-07	Standard	Repad	159/88					
-08			159/87					
-09			161/89	156.0	85.3			
-10			168/95	9.1	1.8			
-11			151/89					
-12			155/94					
178-03-13	102" chip	Repad	147/87					
-14			159/83					
-15			159/86	152.0	82.2			
-16			146/84	5.9	4.7			
-17			147/78					
-18			154/75					
178-03-19	102" chip	Repad	151/85					
-20			150/83	148.8	80.0			
-21			149/75	4.7	4.2			
-22			148/78					
-23			142/77					
-24			147/76					

TI-NHTSA 003390

[illegible]

TI-NHTSA 003391

PRESSURE SWITCH DATA

Form 21605

TEST NO. 179-03-30

DEVICE 77PS	DATE REQUESTED 10/30/91	REQUESTED BY Steve Off. 10V	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey DiDonato	DATE STARTED 11/1/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford MY '92 Electronic Speed Control Deactivates PS			

CUSTOMER:

PURPOSE OF TEST: Attempt to control the clamping and wetting of the Kapton.

PROCEDURE: over

- all use 8 cut washers for quick results
- all crimped on AMI
- counter @ 0

COUNTER RESET TO 0 @ 970K

COUNTER RESET TO 0 @ 1700K TOTAL CYCLES

" " " " 2222K " "

Initial 454K Counter reset @ 2545K

Device #	Report	Kapton	Act/Rol	Act/Rol				Failure	Suspended
179-03-01	Standard	Square	126/60					1429K	
-01			145/61					970K	
-02			128/62					1112K	
-07			122/59					1866K	
-08			126/60					1056K	
-06			137/57					1121K	
179-03-07	Standard	Round	159/88					2601K	
-08			154/87					2316K	
-09			146/89					2591K	
-10			148/85					1933K	
-11			151/84	137/72				2247K	
-12			155/84					2245K	
179-03-13	100° step	Round	142/87					1672K	
-14			149/83	140/73				2096K	
-15			157/86					2577K	
-16			146/84					1866K	
-17			147/79					2015K	
-18			159/75					1493K	
179-03-19	100° step	Round	151/85					2545K	
-20			150/83					2545K	
-21			147/75					2631	
-22			158/78					2661K	
-23			142/83	137/75				2267K	
-24			147/76					2544K	


(OVER)

TI-NHTSA 003392

Modified Kapton Clamps around Kapton

* Modify Headers

NTS



Lot A: .007
Lot B: .005
Lot C: .007

Qty 10 each

- * Build into devices w/ full round Kapton.
include control 105 w/ round and square Kapton.
- * Lot Len's off of each to examine Kapton wetting. This information will be used in determining which, if not any groups will be impaled.
- * Impulse to failure

J.A.D.

11/30/91

DEVICE #	HEXPORT	KAPTON	INITIAL ACT /REL	454K CYC. ACT /REL	CYC. TO FAILURE
178-03-01	STANDARD	SQUARE	136 / 60		1424K
178-03-02	STANDARD	SQUARE	145 / 61		970K
178-03-03	STANDARD	SQUARE	134 / 62		1113K
178-03-04	STANDARD	SQUARE	133 / 59		1866K
178-03-05	STANDARD	SQUARE	136 / 60		1056K
178-03-06	STANDARD	SQUARE	137 / 57		1131K
178-03-07	STANDARD	ROUND	154 / 88		2601K
178-03-08	STANDARD	ROUND	154 / 87		2316K
178-03-09	STANDARD	ROUND	160 / 84		2591K
178-03-10	STANDARD	ROUND	162 / 85		1933K
178-03-11	STANDARD	ROUND	151 / 84	137 / 72	2247K
178-03-12	STANDARD	ROUND	155 / 84		2245K
178-03-13	.003" STEP	ROUND	149 / 87		1672K
178-03-14	.003" STEP	ROUND	159 / 83	140 / 73	2096K
178-03-15	.003" STEP	ROUND	157 / 86		2577K
178-03-16	.003" STEP	ROUND	146 / 84		1866K
178-03-17	.003" STEP	ROUND	147 / 78		2015K
178-03-18	.003" STEP	ROUND	154 / 75		2083K
178-03-19	.005" STEP	ROUND	151 / 85		254K
178-03-20	.005" STEP	ROUND	150 / 83		454K
178-03-21	.005" STEP	ROUND	147 / 75		2631K
178-03-22	.005" STEP	ROUND	156 / 78		2661K
178-03-23	.005" STEP	ROUND	142 / 83	137 / 75	2267K
178-03-24	.005" STEP	ROUND	147 / 76		2544K
178-03-25	.007" STEP	ROUND	149 / 81		294K
178-03-26	.007" STEP	ROUND	157 / 85	139 / 75	2441K
178-03-27	.007" STEP	ROUND	154 / 83		105K
178-03-28	.007" STEP	ROUND	155 / 88		1693K
178-03-29	.007" STEP	ROUND	157 / 80		2222K
178-03-30	.007" STEP	ROUND	151 / 83		2225K

PRESSURE SWITCH DATA

Form 21605

TEST NO. 179-15-28

DEVICE 77 PS	DATE REQUESTED 11/10/91	REQUESTED BY Steve Offiler	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey DiDomenico	DATE STARTED 11/21/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford MY '92 Electronic Speed Control Deactivate PS			

CUSTOMER:

PURPOSE OF TEST:

Asymmetric Crimp Study

PROCEDURE:

Device #	1	Next	Qir 1st						
179-15-01			Yes						
-02 Pressure	2								
-03 negative	3								
-04 Paper	4								
-05	5								
-06	6								
-07	7								
-08	8								
-09	9								
-10	1								
-11	2								
-12	3								
-13	4								
-14	5								
-15	6								
-16	7								
179-15-17			Yes						
-19 Tear test	2								
-19 relative	3								
-20 to	4								
-21 orientation	5								
-22 in series	6								
-23 test	7								
-24	8								
179-15-25			NO						
-26 Tear test	2								
-27 Formation	3								
-28 Dissection	4								

TI-NHTSA 003396

(OVER)

ASYMMETRIC CRIMP STUDY

PURPOSE: To attempt to correlate teardrop formation with asymmetry in the crimp procedure, which possibly arises from deflections of the table / "C" frame, and possibly manifests itself as measurable differences in sensor height and/or diameter around the circumference.

SCOPE: Four areas of information will be explored: presence of teardrop, height and diameter of crimp, and pressure sensitive paper readings, all correlated with position; and crimp without air-blast to examine the Kapton before it is wetted.

PROCEDURE:

- Place an indelible mark on the outer circumference of 28 Pass Car cups, which will be used to align the uncrimped sensor assemblies in the crimper dial (mark pointing towards center of dial).
- Cut 16 sets of pressure-sensitive paper by tracing a washer with an X-acto knife. Place small marks on the outer surface for alignment with hexports and cups.
- Place alignment marks on the outer edge of 16 hexports, and kit sensors with pressure paper between Kapton and washer. Align marks on hexport, paper, and cup.
- Kit another 12 sensors normally, with the marked cups.
- Crimp all 16 pressure paper parts on AMI. Record which nest was used for each (the nests are numbered on the dial 1 thru 8 with a marker). We will use these to look for nest-to-nest variations.
- Crimp 8 of the 12 normal sensors, recording which nest was used.
- Disable air blast and crimp the 4 remaining sensors (or, remove them from dial before the air blast station). Nest info not important.
- Decrimp the pressure paper parts. Examine the pressure paper for evidence of asymmetric crimp relative to the mark, as well as for nest-specific variations.

ASYMMETRIC CRIMP STUDY

- Lathe cut the hexports on the other 12 devices.
- Look for teardrop on the 8 air-blast parts and location relative to the mark. Also, look for nest-related correlations between these and the pressure paper results. If no teardrops show up, we'll need to rebuild this portion of the test.
- On 8 air-blast parts, place small marks around the outer circumference at 45 degree intervals beginning with original cup mark. Measure the crimp height at each of these points with a dial indicator, and take four diameter readings across 1-5, 2-6, 3-7, and 4-8.
- Examine the parts with no air blast to get an idea of the shape/condition of the Kapton before it ever sees any pressure. Look for any evidence of the beginnings of teardrop, as a function of the precrimp or crimp processes.



Nest 1

179-15-01

179-15-02



Nest 2

179-15-03

179-15-04



Nest 3

179-15-05

179-15-06



Nest 4

179-15-07

179-15-08



Nest 5

179-15-09

179-15-10



Nest 6

179-15-11

179-15-12



Nest 7

179-15-13

179-15-14



Nest 8

179-15-15

179-15-16

Center of Dot



Test 179-15-17
Asymmetric Triap Study

TI-NHTSA 008399

23-141 50 SHEETS
23-142 100 SHEETS
23-143 200 SHEETS
23-144 500 SHEETS



PRESSURE SWITCH DATA

Form 21605

TEST NO. 175-03-24

DEVICE 77PS	DATE REQUESTED 10/30/91	REQUESTED BY Steve Offley	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. DeDore	DATE STARTED 11/1/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford 117 Electronic Speed Control Rebuild PS			

CUSTOMER:

PURPOSE OF TEST: Attempt to control the clamping and unclamping of the Kaptan.

PROCEDURE: Over

- all use flat washers for quick results
- all clamped on AMT
- counter @ 0.

COUNTER RESET TO 0 @ 970K

COUNTER RESET TO 0 @ 1700K TOTAL CYCLES

2544K

Total 454K Counter reset @ 2545K

Pressure	Height	Kaptan	Art/Rol	Art/Rol			Failure	Surround
175-03-01	Standard	Square	126/60				1424K	
-02			145/61				970K	
-03			124/62			53	1113K	
-04			122/59			134	1866K	
-05			126/60			49.523	1056K	
-06			127/57				1131K	
175-03-07	Standard	Round	154/88				2681K	
-08			154/87				2316K	
-09			140/84			117	2591K	
-10			148/85			2028	1933K	
-11			151/84	137/76		49.9999	2247K	
-12			155/84			(0.586K)	2245K	
175-03-13	103" 147	Round	147/87				167K	
-14			149/88	140/73		8.9	2096K	
-15			150/86			2170	2577K	
-16			146/84			49.9999	1866K	
-17			147/78			49.9999	2015K	
-18			154/75			49.9999	2097K	
175-03-19	103" 147	Round	151/85				254K	
-20			150/83			12.0	459K	
-21			147/75			2144	2325K	2312K
-22			151/78			49.9999	2661K	
-23			142/83	137/75		(0.661)	2267K	
-24			147/76				2544K	

TI-NHTSA 003400

Device	Height	Position	Lat/Lon	Alt	Speed	Heading	Roll	Yaw	Pitch	Roll Rate	Yaw Rate	Pitch Rate
175-01-25	107" Top	Right	149/71									
-21			152/75	179/75								
-22			154/73						6.9			105K
-23			155/73						22.6			1693K
-24			157/80									2222K
-25			151/71						79.994%			2225K
AVERAGE FOR 19 DANCES FROM ALL QND KATTIN GROVES →												
									9.2			
									2350			
									79.999%			2

Ford Motor Company
17000 Oakwood Blvd.
P.O. Box 1586-D-2015
Dearborn, Michigan 48121

October 31, 1991

Attn: Mr. Mark Scholler

Subj: Initial IER Submission NOBC Deactivation Switch
Ford Part Number F3TA-9F924-AA Light Truck Series
1.85 - 2.06 Dimensional Discrepancy
PIST/PIPC Data For F2VC-9F924-AB

Ref: My September 25, 1991 Letter

Dear Mark,

My initial September 25, 1991 letter noted a discrepancy on the 1.85 - 2.06 dimension due to an error in transferring that dimension from the envelope drawing to the component drawing.

Enclosed, please find our subsequent measurements for the 1.85 - 2.06 dimension and some sample bases from each of the four corrected base mold cavities. We have also included the PIST/PIPC data for the F2VC-9F924-AB switch.

Please let me know if you have any questions or if I may be of any further assistance.

Regards,

Jim Watt
QRA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Andy McGuirk, MS 12-27
Joe Schuck, TI Farmington Hills, Michigan

encl: 1.85 - 2.06 Measurements
Sample bases
PIST/PIPC Data

(Rev 0, 10/31/91)

TI-NHTSA 003402

Ford Part Number NGSC Deactivation Switch

Base Measurements (Dimension Specification: 1.85 - 2.06)

Part Number F2VC-9F924-AB

Cavity	Sample #1	Sample #2
A	1.92	1.94
B	1.99	1.98
C	2.00	1.98
D	1.99	1.97

Part Number F3TA-9F924-AA

Cavity	Sample #1	Sample #2
A	1.92	1.95
B	1.99	1.97
C	2.00	1.98
D	1.97	1.97

(Rev 0, J. Watt, 10/31/91)

TI-NHTSA 003403

cc = Elaine R.
Tyz / comments
Jhx,
Jim W

Ford Motor Company
17000 Oakwood Blvd.
P.O. Box 1586-D-2015
Dearborn, Michigan 48121

October 31, 1991

Attn: Mr. Mark Scheller

Subj: Initial ISR Submission NGSC Deactivation Switch
Ford Part Number F3TA-9F924-AA Light Truck Series
1.85 - 2.06 Dimensional Discrepancy
PIST/PIPC Data For F2VC-9F924-AB

Ref: My September 25, 1991 Letter

Dear Mark,

My initial September 25, 1991 letter noted a discrepancy on the 1.85 - 2.06 dimension due to an error in transferring that dimension from the envelope drawing to the component drawing.

Enclosed, please find our subsequent measurements for the 1.85 - 2.06 dimension and some sample bases from each of the four corrected base mold cavities. We have also included the PIST/PIPC data for the F2VC-9F924-AB switch.

Please let me know if you have any questions or if I may be of any further assistance.

Regards,

Jim Watt
QRA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Andy McGuirk, MS 12-27
Jim Shuck, TI Farmington Hills, Michigan

encl: 1.85 - 2.06 Measurements
Sample bases
PIST/PIPC Data

(Rev 0, 10/31/91)

TI-NHTSA 003404

PRESSURE SWITCH DATA

Form 21605

TEST NO. 175-15-12

DEVICE <i>CCT</i>	DATE REQUESTED <i>10/10/91</i>	REQUESTED BY <i>Steve Off. 101</i>	REQUESTED COMPL. DATE
PERFORMED BY <i>Officer DiDomenico</i>	DATE STARTED <i>11/11/91</i>	DATE COMPLETED	APPROVED BY
PROJECT TITLE: <i>Ford 1979 Electronic Speed Control React. valve ps</i>			

CUSTOMER:

PURPOSE OF TEST:

Next Page

PROCEDURE:

Pass. Car. Sensors hand built and crimped on hard line

TORQUE TESTING

Sensor #	Hex nut	Bars	10610	10621
175-15-01	10A 41	7900	437	52
-02		8100	40	51
-03		7900	41	47
-04		8100	42	56
-05		8000	41	48
-06		7900	41	52
			42	43
175-15-07	2C940	7600	49	54
-08		7800	47	56
-09		7800	4	51
-10		7600		
-11		7700		
-12		7600		

TI-NHTSA 003405

PRESSURE SWITCH DATA

FORM 21605

TEST NO. 172-15-24

DEVICE 77 PSL 2-1	DATE REQUESTED 11/1/91	REQUESTED BY Steve Duffin	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. Bonarico	DATE STARTED 11/1/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford MY '91 Electronic Speed Control Diagnostics 15			

CUSTOMER:

PURPOSE OF TEST: Review of Validation testing which failed the first trial.

PROCEDURE: Impulse and Fluid Res./Impulse Test per Ford ES Parts Crimped on head-line.

1182 MAY
45 31

LARGE PRESSURE - MEASURE NOTED AREA?

Device #	Org. date	Act/Rel	Mr Prop	2nd Test Location			Pilot	
				A	B	C		
172-15-01	9/1/91	112/42	5.9	1.97-A	1.50-A	1.66-A	Pass	
02		116/41	5.8	1.92	1.46	1.67		
03		118/41	6.3	1.92	1.49	1.69		
04		119/45	4.6	1.91	1.46	1.67		
05		115/43	4.7	1.83	1.47	1.70		
06		116/49	4.2	1.92	1.51	1.71		
07		127/42	3.9	1.95	1.51	1.70		
08		113/44	3.1	1.97	1.47	1.70		
09		125/41	5.6	1.92	1.45	1.71		
10		120/47	5.7	1.91	1.49	1.76		
11		113/50	4.3	1.91	1.48	1.71		
12		124/47	3.5	1.91	1.47	1.71		
172-15-17	9/1/91							
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								

TI-NHTSA 003406

PRESSURE SWITCH DATA

FORM 21605

TEST NO. 172-15 24

DEVICE 77 PSL 2-1	DATE REQUESTED 11/1/91	REQUESTED BY Steve Off. 100	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. Bonarico	DATE STARTED 11/2/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford HT '91 Electronic Speed Control Diagnostic PS			

CUSTOMER:

PURPOSE OF TEST: Return of Validation testing which failed the first time

PROCEDURE: Impulse and Fluid Res./Tap-off test per Ford ES Parts Crimped on head-line

Device #	Date	Act/Rel	Mr Drop	Cur A	Cur B	Cur C	Pilot	
172-15-01	7/1/02	112/40	5.9	1.97 mA	1.50 mA	1.66 mA	Pass	
02		116/41	5.0	1.95	1.46	1.67		
03		118/41	6.7	1.92	1.44	1.68		
04		118/45	4.6	1.91	1.46	1.67		
05		115/43	4.7	1.83	1.47	1.70		Fluid Res.
06		118/49	4.2	1.82	1.51	1.71		
07		124/42	5.4	1.85	1.51	1.70		2nd Impulse
08		113/44	3.1	1.87	1.47	1.72		
09		125/41	5.6	1.90	1.45	1.71		
10		120/47	5.7	1.91	1.49	1.76		
11		113/50	4.3	1.91	1.48	1.71		
12		114/47	3.3	1.91	1.47	1.71		
172-15-17	9/1/02	112/42	2.7	1.58	1.34	1.74	Pass	
14		116/42	4.5	1.61	1.37	1.77		
15		125/45	2.7	1.78	1.43	1.71		
16		111/42	4.4	1.58	1.38	1.78		
17		119/51	2.7	1.58	1.36	1.86		
18		124/48	3.1	1.67	1.41	1.85		
19		119/53	2.9	1.60	1.37	1.83		Impulse
20		120/47	3.2	1.67	1.38	1.86		
21		114/47	3.6	1.80	1.40	1.85		
22		124/42	3.2	1.63	1.41	1.79		
23		119/45	4.7	1.75	1.42	1.89		
24		119/43	3.7	1.74	1.45	1.79		

(OVER)

TI-NHTSA 003407

PRESSURE SWITCH DATA

FORM 21605

TEST NO. 173-15-24

DEVICE 7785L2-1	DATE REQUESTED 11/11/91	REQUESTED BY Steve Offiler	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. Deane, CO	DATE STARTED 11/12/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford 173 1st Election & Speed Control Deactivation P3			

CUSTOMER:

PURPOSE OF TEST: Review of Validation testing which failed the first time

PROCEDURE: Impulse test and Fluid Res/Impulse test per Ford ES. All parts crimped on AMI.

Dev. or #	Build Date	Act/Rtl	Mvding	Current Loops			Proof	
				A	B	C		
173-15-01	9/1/90	121/57	3.9	1.88	1.50	1.72	Pass	
-02		124/57	6.3	1.82	1.49	1.72		
-03		125/52	5.3	1.84	1.52	1.78		
-04		122/57	4.3	1.86	1.84	1.79		
-05		129/56	3.6	1.86	1.52	1.77		
-06		120/49	4.1	1.83	1.50	1.74		Fluid Res.
-07		126/59	4.4	1.93	1.52	1.75		
-08		125/59	4.1	1.72	1.48	1.74		and Impulse
-09		127/52	4.3	1.84	1.50	1.75		
-10		123/57	5.0	1.86	1.51	1.75		
-11		121/54	4.8	1.81	1.52	1.83		
-12		128/53	6.2	1.87	1.50	1.77		
173-15-13	9/1/91	121/58	3.3	1.70	1.46	1.79	Pass	
-14		122/57	2.4	1.70	1.44	1.76		
-15		118/61	9.3	1.60	1.36	1.81		
-16		125/61	4.0	1.75	1.46	1.84		
-17		127/55	7.1	1.78	1.41	1.69		
-18		118/50	3.7	1.44	1.34	1.83		
-19		128/57	4.5	1.67	1.42	1.82		Impulse
-20		122/62	2.9	1.67	1.48	1.82		
-21		112/55	3.9	1.59	1.38	1.79		
-22		118/51	4.2	1.74	1.47	1.75		
-23		111/60	3.7	1.57	1.34	1.82		
-24		119/52	8.8	1.53	1.33	1.80		

(OVER)

TI-NHTSA 003409

PRESSURE SWITCH DATA

Form 21605

TEST NO. 172-10-14

DEVICE 77PSL 2-9	DATE REQUESTED 11/1/91	REQUESTED BY Steve Oshier	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. Brown	DATE STARTED 11/1/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford MT '92 Electronic Speed Control Deactivate ES			

CUSTOMER:

PURPOSE OF TEST: Review of Validation testing which failed the first trial.

PROCEDURE: 2 impulse and Fluid Res. Impulse test per Ford ES Parts Crimped as hand-laid.

Device #	Op. #	Alt/Rel	No. Imp	A	B	C	Proof
172-10-01	91102	112/42	5.9	1.97-A	1.50-A	1.66-A	Pass
17		116/41	6.0	1.95	1.46	1.67	
01		118/41	6.7	1.92	1.44	1.68	
04		118/45	4.6	1.91	1.46	1.69	
05		115/43	4.7	1.82	1.47	1.72	
16		110/49	4.0	1.91	1.51	1.71	
02		114/42	5.9	1.95	1.51	1.70	
03		113/44	3.1	1.97	1.47	1.72	
09		115/41	5.6	1.90	1.45	1.71	
08		120/42	5.7	1.91	1.49	1.76	
11		113/50	4.3	1.91	1.48	1.71	
12		114/47	3.3	1.91	1.47	1.70	
172-10-17	91401	117/42	2.7	1.58	1.29	1.79	Pass
17		116/42	4.5	1.61	1.27	1.77	
15		115/45	2.7	1.78	1.43	1.71	
16		111/42	4.4	1.58	1.38	1.88	
17		118/51	2.7	1.58	1.26	1.86	
18		114/49	3.7	1.69	1.41	1.85	
19		119/53	2.9	1.60	1.37	1.93	
20		110/47	3.2	1.67	1.39	1.86	
21		110/47	3.6	1.61	1.40	1.85	
21		114/42	3.2	1.63	1.41	1.79	
22		119/45	4.1	1.75	1.42	1.89	
22		119/42	3.4	1.74	1.45	1.79	
		118/45.6					
		2.8 1.7					

TI-NHTSA 003411

PRESSURE SWITCH DATA

Form 21605

TEST NO. 173-15-24

DEVICE 7785LJ-1	DATE REQUESTED 11/1/91	REQUESTED BY Steve Off-100	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey DiDonato	DATE STARTED 11/1/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford 91Y '91 Electronic Speed Control Diagnostic PS			

CUSTOMER:

PURPOSE OF TEST: Review of Validation testing which failed the first time

PROCEDURE: Impulse test and Fluid Res/Impulse test per Ford ES. All parts replaced on AMI.

122.8 55.1 HIGHER PRESSURE = SMALLER WATER AREA?
2.7 1.3

Device #	Build Date	Act/Air	Pressure	Current Voltage			Proof		
A	B	C							
173-15-01	9/1/90	121/57	2.8	1.90	1.50	1.72	Base		
-02		124/52	6.3	1.92	1.49	1.72			
-03		125/52	5.3	1.84	1.52	1.72			
-04		122/57	4.3	1.86	1.54	1.79			
-05		128/56	3.6	1.88	1.52	1.72			
-06		120/49	4.1	1.92	1.50	1.74			
-07		122/59	4.4	1.93	1.52	1.75			
-08		125/59	4.1	1.72	1.48	1.74			
-09		124/52	4.3	1.84	1.50	1.75			
-10		123/57	5.0	1.86	1.51	1.75			
-11		121/54	4.8	1.88	1.52	1.82			
-12		118/53	6.2	1.82	1.50	1.79			
173-15-13	9/1/90								
-14									
-15									
-16									
-17									
-18									
-19									
-20									
-21									
-22									
-23									
-24									

(OVER)

TI-NHTSA 003412

PRESSURE SWITCH DATA

Form 21605

TEST NO. 173-15-24

DEVICE 776SL2-1	DATE REQUESTED 11/1/91	REQUESTED BY Steve Hoffman	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. Denarico	DATE STARTED 11/2/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford MY '91 Electronic Speed Control Deactivation PS			

CUSTOMER:

PURPOSE OF TEST: Resub of Validation testing which failed the first time

PROCEDURE: Impulse test and Fluid Res/Impulse test per Ford ES. All parts cleaned in A.M.I.

Dev. #	Build Date	Act/Rel	Fluid Res	Current	A	B	C	Pass	
173-15-01	21/11/02	121/57	2.8	1.98	1.50	1.72		Pass	
-02		114/57	6.3	1.92	1.47	1.72			
-03		115/52	5.3	1.94	1.52	1.79			
-04		122/57	4.3	1.96	1.54	1.79			
-05		119/56	3.6	1.96	1.52	1.77			
-06		120/48	4.1	1.93	1.50	1.74			
-07		124/59	4.4	1.93	1.52	1.75			
-08		125/59	4.1	1.72	1.48	1.74			
-09		124/52	4.3	1.84	1.50	1.75			
-10		123/57	5.0	1.96	1.51	1.75			
-11		122/54	4.8	1.88	1.52	1.73			
-12		121/53	6.2	1.82	1.50	1.72			
173-15-13	9/11/02	121/55	3.3	1.78	1.46	1.79		Pass	
-14		122/57	2.9	1.70	1.44	1.46			
-15		119/51	9.3	1.60	1.36	1.81			
-16		125/61	4.0	1.75	1.46	1.84			
-17		127/55	7.1	1.70	1.41	1.69			
-18		115/50	2.7	1.44	1.34	1.83			
-19		128/57	7.5	1.67	1.42	1.82			
-20		122/62	2.9	1.67	1.40	1.82			
-21		112/55	3.9	1.59	1.38	1.79			
-22		118/51	4.0	1.74	1.49	1.75			
-23		119/60	3.9	1.57	1.34	1.82			
-24		119/52	8.8	1.53	1.33	1.70			
		1210/54.3							
		4.1 / 4.1							

(OVER)

TI-NHTSA 003413

Final Char


	Proof	A-1/Rel	mu Dep	Carry over							
				A	B	C					
173-15-01											
-02											
-03											
-04											
-05											
-06											
-07											
-08											
-09											
-10											
-11											
-12											
173-15-11	101.5	112/57	20	1.60	1.37	1.75					
-12		112/60	29.2	1.69	1.42	1.94					
-13		110/58	15	1.61	1.37	1.80					
-14		111/54	43.6	1.45	1.25	1.86					
-15		115/55	97.9	1.56	1.35	1.71					
-16		105/57	21.3	1.55	1.28	1.89					
-17		117/59	92.6	1.49	1.28	1.77					
-18		115/61	1.8	1.58	1.36	1.79					
-19		112/58	21.4	1.73	1.47	1.78					
-20		101/55	47.2	1.58	1.36	1.75					
-21		111/56	40.2	1.25	1.48	1.70					
-22		101/55	35.1	1.61	1.39	1.69					
-23		117/58.1									
-24		21/2.2									

TI-NHTSA 003414

TEST #173 BLD 9/11/02

6/0 FAIL - 2 SUSP. FOR ANALYSIS #20 & 23 @ 1361K

AMI CRIMP w/ HL TOOLS



Enter desired confidence level(%)? ■


Rel @ 500K = 100 %

(Note: Rel of 99.9999 corresponds to 532 K cycles)

TEST # 172 BLD 9/11/02

Q/10 FAIL - 2 SUSP FOR ANALYSIS #14 & #19 @ 1306 K

HAND-LINE CRIMP



TJ-NHTSA 003418

PRESSURE SWITCH DATA

Form 21605

TEST NO. 176-02-24

DEVICE CCPS	DATE REQUESTED 11/1/91	REQUESTED BY Steve Off. Tex	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. Banaice	DATE STARTED 11/1/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford 1979 Electronic Speed Control Reactivate PS			

CUSTOMER:

PURPOSE OF TEST: **Cycle to failure validation 2-pulse parts from tests 172-15-24 and 173-15-24**

PROCEDURE: **2-pulse per Ford ES until leak occurs**

172-15-18 thru -24 : Counter + 525K

173-15-18 thru -24 : counter + 500K

Remaining Parts From 173-15-24 : Counter + 1971

Device #	Crimp	Sniff date	Failure	Supported
172-15-13	Hard-	9/1/82	1069K	1386K
-17	line		opened - not cycled	
-18			953K	
-19			opened - not cycled	
-20			110K	
-21				1381K
-22			1326K	
-23			1031K	
-24			129K	
173-15-17	AMT	9/1/82	1477K	
18			1622K	
19			opened - not cycled	
20			opened - not cycled	
21			opened - not cycled	
22			1222K	
23			opened - not cycled	1381K
24			1387K	
25			1628K	1381K
26			1477K	

(OVER)

TI-NHTSA 003417

HIGHLIGHTS

Steve OFFICER
W/E 91-11-01

DIAPHRAGM LIFE:

Results of washer test (using 0 out Zn plate; 2 out Zn plate; and 0 out Ni plate) all crimped on Arms & "normal" pressure:

	LOT	β	θ	
a)	0 out Ni	2.4	1630	(first fail @ 603K)
b)	2 out Zn	2.4	1472	(first fail @ 607K)
c)	0 out Zn	3.3	960	(first fail @ 436K)

Mixed failure modes were apparent from the Weibull graphs;... the first failures seemed to be on a different curve than the latter ones. The above β and θ therefore actually represent averages of the mixed modes combined.

Results of crimp tool swap:

	LOT	β	θ	
A)	Hand tie tools on Arms	10.4	709	OUT OPEN
a)	Hand tie tools on HL	5.3	670	
c)	Arms tools on Arms	6.6	668	
D)	Arms tools on HL	7.9	540	

Contrary to washer test, mixed modes did not appear to be a factor. It seems that the hand tie tools produce a higher θ , while the Arms produces a higher β . All above used 0 out washers based on results of washer test. However, lot C of washer test should be identical to lot C of crimp tool swap.

Based on a combination of the above, it would appear that hand-tie tools on the Arms dial with 2-out washers will produce our best shot at good devices. Of course, we still have no concrete idea why.

Jeff DeDomenico has developed a very good hypothesis which explains leadchip formation. He suggests that the washer & support bonding is quite possibly asymmetric, leading to greater clamp in some areas and less in others. Those areas clamped less would allow the Kapton to pull out, producing the "point" of the leadchip. We're experimenting with this hypothesis using stepped reliefs in the support combined w/ full-round Kapton.

TI-NHTSA 003418

Using the relatively new technique of cutting away the top layer to observe the top Kapton layer while the device is still fully crimped, we have opened up the worst and best devices from the three wafer lots. This was done to attempt to understand the apparent differences in failure mode. Evidence of leachdown shape was fairly subtle, but nonetheless the three low-life parts had a fairly narrow area of perforation, apparently at the peak of the leachdown (but this is questionable, since the leachdown could be a result of the perforation rather than the cause.) In contrast, the high-life parts showed the top layer to be fairly uniform all the way around.

It is unfortunate that we are at our drop-dead point to build ISR parts, because all indications seem to be pointing to the leachdown as the fundamental problem, and we are only just beginning to understand the cause and remedy to this phenomenon. With Joe Schuck's departure, it might be wise for Marketing to place a call to Bruce Pease to update him on our status and request an extension to our 90-day deadline.

PRESSURE SWITCH DATA

Form 21605

TEST NO. 5--15-6

DEVICE EX-3445-16, 20	DATE REQUESTED 11/01/91	REQUESTED BY D CZARN	REQUSTED COMPL. DATE
PERFORMED BY R PUSSE / R-URNER	DATE STARTED 11/05/91	DATE COMPLETED	APPROVED BY

PROJECT TITLE: TEMP - PRESSURE AGE CYCLING

CUSTOMER:

PURPOSE OF TEST:

PROCEDURE: ① OBTAIN VESSEL VOLUME = 1223.0 CM³

② R1360 C-PLATE = 75.0 gm

③ OIL = 435 gm

④ WEIGH VESSEL

⑤ ADD OIL

⑥ FILL R1360

42 CYCLES OF:

(1) HOURS (MIN) @ -25°C

(1) HOUR (MIN) RAMP UP TO 125°C

(3) HOURS (MIN) @ 125°C

(1) HOUR (MIN) RAMP DOWN TO -25°C

10	VESSEL	①	②	③	④	⑤	⑥	⑦	⑧	⑨	⑩
#	#	INIT WT	WT + OIL	WT + R1360	WT + OIL + R1360	% OIL	WT + OIL + R1360	% OIL	WT + OIL + R1360	% OIL	WT + OIL + R1360
PS-209	R1	426.818	431.160	505.072	506.526	0.110	505.072	0.237	505.553	0.501	
PAT 219	R1	428.982	433.324	507.347	507.860	0.096	507.347	0.214	507.829	0.482	
PS-246	R2	428.242	432.882	507.700	511.585	13.012	REMOVED FROM TEST				
N-1	9	408.927	409.287	409.320	409.308	0.001	409.308	0.015	409.248	0.017	
N-2	15	406.308	406.645	406.550	406.531	0.004	406.531	0.013	406.466	0.017	
N-3	16	401.260	401.604	401.477	401.429	0.006	401.429	0.039	401.352	0.196	

WEIGHT A: VESSEL, SW HOUSING, SEALING, ADAPTER (EOL 29 - ONLY)

WEIGHT B: WEIGHT A PLUS ~ 4350 OIL

WEIGHT C: WEIGHT B PLUS R1360 C-PLATE

TI-NHTSA 003420

1. VESSEL RAMP UP TO 125°C, 16 CHARGED BEFORE TEST RUN
 - 0 POSSIBLE LEAK BETWEEN ADAPTER AND VESSEL - N/A
 2. VESSEL RAMP DOWN TO -25°C

[illegible]

PRESSURE SWITCH DATA

Form 21605

TEST NO. 173-15-24

DEVICE 7785L2-1	DATE REQUESTED 11/11/91	REQUESTED BY Steve Officio	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. Donarico	DATE STARTED 11/12/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford 91Y '91 Electronic Speed Control Deactivate PS			

CUSTOMER:

PURPOSE OF TEST: Reason of Validation testing which failed the first time

PROCEDURE: Impulse test and Fluid Res/Impulse test per Ford ES. All Parts crimped on ARM.

123.0 55.1 HIGHER PRESSURE = SMALLER WATERS AREA?
2.7 7.3

Qc. #	Build Date	Act/Al	Modrop	Current (amps)			Port		
				A	B	C			
173-15-01	7/1/82	121/57	2.8	1.98	1.50	1.72	Port		
-02		124/57	6.3	1.92	1.47	1.72			
-03		125/52	5.3	1.84	1.52	1.79			
-04		123/57	4.3	1.96	1.84	1.79			
-05		128/56	3.6	1.86	1.52	1.77			
-06		120/48	4.1	1.83	1.50	1.79			
-07		121/59	4.4	1.93	1.52	1.75			
-08		125/59	4.1	1.72	1.48	1.74			
-09		124/52	4.3	1.84	1.50	1.75			
-10		123/57	5.0	1.86	1.51	1.75			
-11		121/54	4.8	1.88	1.52	1.73			
-12		118/53	6.2	1.82	1.50	1.73			
173-15-13	9/1/82								
-14									
-15									
-16									
-17									
-18									
-19									
-20									
-21									
-22									
-23									
-24									

TI-NHTSA 003422

PRESSURE SWITCH DATA

Form 21605

TEST NO. 175-15-24

DEVICE 778SL2-1	DATE REQUESTED 11/11/91	REQUESTED BY Steve Offiler	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. Deane	DATE STARTED 11/12/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford 1991 Electronic Speed Control Diagnostic PS			

CUSTOMER:

PURPOSE OF TEST:

Reason of Validation testing which failed the first time

PROCEDURE:

Impulse test and Fluidics/Engine test per Ford ES. All Parts cleaned in AMP.

Q-cc #	Build Date	Act/Rel	Mod/Imp	Current Envelope			Perf		
				A	B	C			
175-15-01	9/11/92	121/57	2.9	1.80	1.50	1.72	Pass		
-02		124/57	6.3	1.82	1.49	1.72			
-03		125/52	5.3	1.84	1.52	1.74			
-04		122/57	4.3	1.96	1.84	1.79			
-05		128/56	3.6	1.86	1.50	1.77			
-06		120/49	4.1	1.92	1.50	1.74			
-07		121/59	4.4	1.93	1.52	1.75			
-08		125/59	4.1	1.72	1.48	1.74			
-09		124/52	4.3	1.84	1.50	1.75			
-10		123/57	5.0	1.86	1.51	1.75			
-11		121/54	4.8	1.88	1.52	1.82			
-12		118/53	6.2	1.82	1.50	1.77			
178-15-13	9/11/92	121/56	3.7	1.70	1.46	1.79	Pass		
-14		122/57	2.4	1.70	1.44	1.76			
-15		119/61	4.3	1.60	1.36	1.81			
-16		125/61	4.0	1.75	1.46	1.84			
-17		122/55	7.1	1.20	1.41	1.69			
-18		115/50	2.7	1.44	1.34	1.83			
-19		128/57	4.5	1.67	1.40	1.80			
-20		123/62	2.9	1.67	1.40	1.90			
-21		118/55	3.9	1.59	1.38	1.79			
-22		118/51	4.0	1.79	1.47	1.75			
-23		119/60	2.9	1.57	1.39	1.82			
-24		119/52	8.8	1.33	1.33	1.80			
		11.0 55.3							
		9.1 9.1							

TI-NHT8A 003423

PRESSURE SWITCH DATA

Form 21605

TEST NO. 175-15-24

DEVICE 77PSL2-1	DATE REQUESTED 11/1/91	REQUESTED BY Steve Officio	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. Donarico	DATE STARTED 11/1/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford FY '91 Electronic Speed Control Deactivator PS			

CUSTOMER:

PURPOSE OF TEST: Reason of Validation testing which failed the first time

PROCEDURE: Impulse test and Fluid Res / Impulse test per Ford ES. All ports crimped on AMS.

Dev. #	Serial #	Alt/Alt	Mod/Mod	Current (amps)	A	B	C	Port	
123-15-01	311102	121/57	2.9	1.98	1.50	1.72	Pass		
-02		114/57	1.3	1.92	1.49	1.52			
-03		115/57	5.3	1.84	1.52	1.59			
-04		122/57	4.3	1.86	1.50	1.79			
-05		118/56	3.6	1.86	1.52	1.77			
-06		120/49	4.1	1.83	1.50	1.74			Fluid Res
-07		121/59	4.4	1.83	1.52	1.75			
-08		125/59	4.1	1.72	1.48	1.74			and Impulse
-09		124/52	4.3	1.84	1.50	1.75			
-10		123/57	5.0	1.86	1.51	1.75			
-11		121/54	4.8	1.83	1.52	1.73			
-12		114/52	6.2	1.82	1.50	1.72			
123-15-07	911102	121/57	3.2	1.78	1.71	1.79	Pass		
-08		122/57	2.8	1.70	1.44	1.76			
-09		119/61	9.9	1.60	1.36	1.81			
-10		125/61	9.0	1.75	1.46	1.84			
-11		127/55	7.1	1.78	1.41	1.62			
-12		115/50	2.7	1.44	1.34	1.83			
-13		128/57	7.5	1.67	1.42	1.82			Impulse
-14		122/62	2.9	1.67	1.40	1.82			
-15		118/55	3.9	1.59	1.38	1.79			
-16		118/51	4.0	1.74	1.49	1.75			
-17		117/60	5.7	1.57	1.79	1.62			
-18		119/52	7.8	1.53	1.33	1.70			
		121/46.3							
		41/4.1							

(INVEST)

TI-NHTSA 003424

Final Char

	Proof	A.1/P.1	mu Dep	Carryover							
				A	B	C					
22-15-01											
-02											
-03											
-04											
-05											
-06											
-07											
-08											
-09											
-10											
-11											
-12											
3-15-11	Res	112/57	2.0	1.60	1.37	1.75					
-13		112/60	39.2	1.69	1.42	1.84					
-14		110/58	1.5	1.61	1.37	1.80					
-15		111/54	73.6	1.45	1.25	1.86					
-16		115/55	97.9	1.56	1.35	1.71					
-17		115/57	2.3	1.55	1.39	1.99					
-18		117/59	97.6	1.77	1.28	1.77					
-19		115/61	1.8	1.58	1.36	1.79					
-20		112/58	21.4	1.73	1.47	1.78					
-21		110/55	47.2	1.58	1.36	1.75					
-22		111/56	40.2	1.75	1.48	1.70					
-23		111/55	35.1	1.61	1.39	1.69					
-24		112/57									
-25		21/1.7									
-26											
-27											
-28											
-29											
-30											
-31											
-32											
-33											
-34											
-35											
-36											
-37											
-38											
-39											
-40											
-41											
-42											
-43											
-44											
-45											
-46											
-47											
-48											
-49											
-50											
-51											
-52											
-53											
-54											
-55											
-56											
-57											
-58											
-59											
-60											
-61											
-62											
-63											
-64											
-65											
-66											
-67											
-68											
-69											
-70											
-71											
-72											
-73											
-74											
-75											
-76											
-77											
-78											
-79											
-80											
-81											
-82											
-83											
-84											
-85											
-86											
-87											
-88											
-89											
-90											
-91											
-92											
-93											
-94											
-95											
-96											
-97											
-98											
-99											
-100											

PRESSURE SWITCH DATA

Form 21605

TEST NO. 173-15-24

DEVICE 778542-1	DATE REQUESTED 11/11/91	REQUESTED BY Steve off-las	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. Dugan, CO	DATE STARTED 11/11/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford 1979 Electronic Speed Control Reaction to PS			

CUSTOMER:

PURPOSE OF TEST: Review of Validation testing which failed the first time

PROCEDURE: Impulse test and Fluid Res/Impulse test per Ford ES. All parts cleaned in AMS.

Dev. Co. #	Dev. ID	Act/Rel	Fluid Res	Impulse	A	B	C	Pass/Fail	
173-15-01	21482	121/57	2.8	1.88	1.50	1.72		Pass	
-02		122/57	6.3	1.92	1.49	1.72			
-03		123/57	5.3	1.89	1.52	1.73			
-04		122/57	7.5	1.86	1.54	1.73			
-05		121/57	3.6	1.86	1.52	1.73			
-06		120/57	4.1	1.83	1.50	1.74			Fluid Res.
-07		121/57	4.4	1.83	1.51	1.75			
-08		125/57	4.1	1.72	1.48	1.79			and Impulse
-09		120/57	4.3	1.84	1.50	1.75			
-10		123/57	5.0	1.86	1.51	1.75			
-11		121/57	4.8	1.88	1.52	1.75			
-12		124/57	6.2	1.72	1.50	1.72			
173-15-17	911162	121/57	3.2	1.78	1.46	1.79		Pass	
-18		122/57	3.4	1.70	1.44	1.76			
-19		118/57	9.3	1.60	1.36	1.81			
-20		125/57	4.0	1.75	1.46	1.84			
-21		122/57	2.1	1.78	1.41	1.69			
-22		118/57	3.7	1.44	1.34	1.82			
-23		123/57	7.5	1.67	1.42	1.82			Impulse
-24		121/57	2.3	1.62	1.38	1.88			
-25		121/57	3.9	1.59	1.37	1.79			
-26		121/57	4.0	1.79	1.49	1.75			
-27		121/57	3.7	1.57	1.39	1.82			
-28		121/57	1.8	1.53	1.33	1.80			

TI-NHTSA 003426

Final Char


Proof	A ₁ /A ₁	mu Avg	A	B	C
123-15-01	Pass	111/56	6.2	2.04	1.53
02		112/58	2.3	1.55	1.22
03		113/59	2.0	1.82	1.81
04		114/59	1.8	1.60	1.37
05		117/60	5.9	1.71	1.42
06		117/55	2.0	1.75	1.45
07		119/62	21.5	1.86	1.83
08		120/57	2.9	1.57	1.22
09		121/57	4.2	1.58	1.27
10		122/59	34.2	1.88	1.55
11		124/56	4.5	1.60	1.34
12		110/52	2.6	1.64	1.35
1245-11	Pass	112/57	2.0	1.60	1.37
02		112/60	29.2	1.63	1.42
03		118/58	1.5	1.61	1.27
04		111/54	73.6	1.45	1.25
05		115/55	97.9	1.56	1.35
06		116/57	2.3	1.55	1.24
07		114/59	92.1	1.79	1.28
08		115/61	1.9	1.58	1.36
09		113/58	21.9	1.73	1.42
10		110/55	47.2	1.58	1.26
11		111/56	40.2	1.75	1.48
12		111/55	35.1	1.61	1.29

TI-NHTSA 003427

TEST #173 BLD 911102

6/B FAIL - 2 SUSP. FOR ANALYSIS #20 & 23 @ 1361K

AMI CRIMP W/ HL TOOLS



Enter desired confidence level(%)? ■

Beta=15.3

Theta= 1579

Rel @ 500K = 100 %


(Note: Rel of 99.9999 corresponds to 532 K cycles)

TI-NHTSA 003428

TEST # 172 BLD 911102

8/10 FAIL - 2 SUSP FOR ANALYSIS #14 & #19 @ 1386 K

HAND-LINE CRIMP



TI-NHTSA 003428

Gave Bruce a # IV group item

11/4/91 - 16.32.1 P126

Grouped

Give smile time chart to Bruce

→ smile tools in PRI/hand crings

HAND-LINE VS. AMI CRIMP (VAL PARTS)

	ACT	σ	REL	σ
HANDLINE	118.2	4.5	44.3	3.1
AMI	122.8	2.7	55.1	3.3

THESE PARTS ARE IDENTICAL EXCEPT FOR CRIMP. TO FIND OUT IF THE MARTIN WETTED AREA IS DIFFERENT:

- TAKE 2 SENSORS FROM EACH LOT
- CHARACTERIZE VERY CAREFULLY (THIS ASSUMES THE DEVICES HERE FOLLOW THE TRENDS ABOVE)
- HAVE STEVE S. DO F/A ON DEVICES BY REACHING THRU HOXPOST TO CONVERTER GUTTING
- AREA CAN BE CALCULATED FROM FORCE AND PRESSURE. DIFFERENCES, IF ANY, MAY PROVIDE A CLUE TO DIAPHRAGM LIFE PROBLEMS (?)



So
711106

Form 21605

TEST NO. 177-K-04

DEVICE 77PS	DATE REQUESTED 11/6/91	REQUESTED BY S. Lee Off. 10 v	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey A. Benise	DATE STARTED 11/19/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford 1979 Electronic Speed Control Reactivate PS			

CUSTOMER:

PURPOSE OF TEST:

PROCEDURE

[illegible]

TI-NHTSA 003432

(OVER)

HAND-LINE VS. AMI CRIMP (VAL PARTS)

	ACT	σ	REL	σ
HANDLINE	118.2	4.5	44.3	3.1
AMI	122.8	2.7	55.1	3.3

THESE FACTS ARE IDENTICAL EXCEPT FOR CRIMP. TO FIND OUT IF THE KAPTON WETTED AREA IS DIFFERENT:

- TAKE 2 SENSORS FROM EACH LOT
- CHARACTERIZE VERY CAREFULLY (THIS ASSUMES THE DEVICES HERE FOLLOW THE TRENDS ABOVE)
- HAVE PETE S. DO F/A ON DEVICES BY REACHING THRU H&P201 TO CONVERTER BUTTON
- AREA CAN BE CALCULATED FROM FORCE AND PRESSURE. DIFFERENCES, IF ANY, MAY PROVIDE A CLUE TO DIAPHRAGM LIFE PROBLEMS (T)

So
911106

77PS IMPULSE TEST LOG SHEET

DISC LOT	DEVICE	START	STOP	DATE
12-1/12-2	77PS L2-1	5:00 AM	9:30 PM	12/5/91
12-3/12-4	77PS L2-1	9:30 PM	11:00 AM	12-5-91 12/6/91
12-6/12-8	77PS L2-1	8:10 AM	7:55 AM	12/7/91 12/9/91 12-9-91
12-5	77PS L2-1	8:00 AM		
12-10/12-11	77PS L2-1	6:00 PM	9:30 AM	12-11-91 12-11-91 12-11-91
12-7/12-9	77PS L2-1	8:00 AM		
12-12/12-13	77PS L2-1	5:30 PM	6:50 AM	12-12-91 12-13-91 12-13-91
12-14/12-15	77PS L2-1	8:30 AM		12-13-91
12-16/12-17	77PS L2-1	10:05 PM		
12-18/12-19	77PS L2-1	1:00 AM	1:10 PM	12-16-91 12-18-91
12-23	57PS-F3-5	4:50 PM		

77PS IMPULSE TEST LOG SHEET

DISC LOT	DEVICE	START	STOP	DATE
1-1/1-7	77PSL2-1	10:25 PM	11:45 AM	1-1-92 1-2-92
1-1/1-2	77PSL2-1	4:30 PM	5:30 AM	1-2-92 1-3-92
1-5/1-6	77PSX2-1	10:21 PM	11:45 AM	1-5-92 1-6-92 1-6-92
1-3	77PSL2-1	2:30 PM	3:30 AM	1-7-92
1-7/1-8	77PSX2-1	11:17 PM	12:45 PM	1-7-92 1-8-92 1-8-92
1-9/1-10	77PSL2-1	12:50 PM	2:00 AM	1-8-92 1-9-92
11-20/11-21	77PS F3.3	6:00 PM	7:25 AM	1-9-92 1-10-92
1-11/1-12	77PSL2-1	10:30 A.M.	12:05 AM	1-14-92 1-15-92
1-15/1-16	77PSL2-1	12:10 AM	1:45 PM	1-15-92 1-15-92
1-17/1-18	77PSL2-1	2:00 PM	1:45 AM	1-16-92 1-15-92
1-14	77PSL2-1	11:50 A.M.	1:45 AM	1-20-92 1-29-92

77PS

IMPULSE TEST LOG SHEET

DISC LOT	DEVICE	START	STOP	DATE
1-22	L2-1	^{needed 35.00} 4:45 PM	1:15	1-20-92 1-31-92
1-23	L2-1	↓	7:15	1-31-92
1-21	L2-1	⁰¹³¹⁻⁹² 4:00 PM	6:30 AM	2-1-92
1-24/1-25	L2-1	9:25 AM	10:45	2-4-92
1-26/1-27	L2-1	11:00 PM	12:20 PM	2-4-92 2-5-92
1-28/1-29	L2-1	1:15 PM		2-5-92
2-4/2-3	L2-1	12:00 PM	1:00 AM	2-10-92 2-11-92
2-5/2-6	L2-1	1:45 AM		2-11-92
2-9/2-10	L2-1	8:00 AM	9:00 PM	2-12-92
2-7/2-8	L2-1	9:35		2-13-92
2-13/2-11	L2-1	6:15 PM	7:00 AM	2-13-92 2-14-92

77PS IMPULSE TEST LOG SHEET

DISC LOT	DEVICE	START	STOP	DATE
2-13/2-14	77PS	8:00 AM	9:30 PM	2-14-92
2-6/2-15	L2-2	10:00 PM		2-14-92
2-1/2-18	X2-3/X2-1	4:25 AM		2-14-92
2-5/2-19	L2-3/L2-1	6:45 PM	8:00 AM	2-17-92
2-3/2-4	L2-3	8:10 AM		2-18-92
2-6	X2-3	10:00 PM		2-18-92
2-20/2-21	L2-1	3:30 PM	11:45 AM	2-21-92
1-20	X2-3	1:20 AM	1:15 AM	2-22-92
2-27	77PS	2:40 PM	9:50 AM	2-24-92
2-24/2-25	77PS	3:05		2-24-92
2-28/2-29	77PS L2-1	11:45 AM	11:40 AM	2-27-92
				2-28-92

77PS

IMPULSE TEST LOG SHEET

DISC LOT	DEVICE	START	STOP	DATE
5-26/5-27	L3-1	3:30 PM	5:05 ^{AM}	5-27-92
3-24/3-25	L2-3	9:00 AM	11:00 ^{PM}	5-28-92
3-26/5-30	22-3 / 23-1	11:00 PM	12:05 PM	6-02-92
				6-29-92
5-31	L3-1	4:45 PM		6-03-92
6-2 & 6-3	L2-3	11:30 AM	12:30 AM	06-03-92
6-4	L2-3	11:30 AM	12:30 AM	06-04-92
5-29/5-32	L3-1	7:50 AM	approx. 9:00 PM	6-5-92
6-6	L3-3	2:00 PM	approx. 3:00 AM	06-05-92
6-8/6-9	L3-3	6:15 PM	8:05 AM	6-6-92
6-10/6-9	L3-3	9:00 PM	10:00 AM	06-09-92
6-11/6-12	L2-3	9:00 AM		06-10-92
				6-17-92
				06-18-92
				06-19-92
				6-22-92
				6-23-92
				6-23-92

77PS IMPULSE TEST LOG SHEET

DISC LOT	DEVICE	START	STOP	DATE
6-13 & 6-14 6-15	L3-3	9:00 AM	10:10 PM	6-29-92
	L3-3	10:23 PM	11:10 AM	6-29-92 6-30-92
6-16	+ 5PCS L3-3 ENS. SAMPLE	3:25 PM		6-30-92
		5:25 PM		6-30-92
7-3 / 7-2 7-4	L2-3	2:00 PM	approx 11:30 AM	7-08-92
	L2-3	4:45 AM		7-9-92 7-11-92
100 / 102	L3-1	8:45 AM		7-23-92
101 / 102	L2-3	10:30 PM	11:55 PM	7-23-92 7-24-92
102 / 104	L3-1	11:40 PM		7-24-92
105 / 101	L3-1	9:10 AM		7-27-92
109 / 111	L3-1	9:00 AM		7-28-92

7PS IMPULSE TEST LOG SHEET

DISC LOT	DEVICE	START	STOP	DATE
112 / 113	L3-1	8:15 AM		7-29-92
114	L3-1	10:22 PM	1:50 PM	7-29-92 7-30-92
115 / 116	L3-1	2:00 PM	5:50 AM	8-04-92 8-5-92
117 / 118	L2-3 / L3-3	6:30 PM	8:00 AM	8-5-92 8-06-92
119 / 120	L3-1	5:45 PM	7:30 AM	8-07-92
121 / 122	L3-3 / L2-3	3:15 PM	5:00 AM	8-10-92 8-11-92
123 / 124	L2-3 /	5:20 PM	9:00 AM	8-11-92 8-12-92
126 / 130	L3-3 / L3-1	5:30 PM	7:00 AM	8-12-92
129	L3-1	7:00 AM		8-12-92
128 / 133	L3-3 / L3-1	2:25 PM		8-19-92
134	L3-1	5:00 AM		8-20-92

77PS IMPULSE TEST LOG SHEET

DISC LOT	DEVICE	START	STOP	DATE
249	L2-3	7:15 PM	8:46 AM	10-26-92 10-27-92
250A / 251A	L3-3	3:30 PM	5:15 AM	10-27-92
253 / 254	L2-1	2:30 PM	3:45 AM	10-28-92
252 / 255	L2-1	3:50 AM		10-29-92
256 / 257	L3-3	8:00 PM	9:30 AM	10-29-92 10-30-92
258 / 259	L3-3	9:45 AM		
260	L2-3	10:00 PM	11:10 AM	11-1-92 11-3-92
262 / 261	L2-1	2:30 PM	5:31 AM	
263	L5-2	5:10 AM		11-4-92
265 / 266	L3-3	7:00 PM	8:05 AM	11-5-92
267 / 268	L3-3	7:11 PM	8:10 AM	11-5-92 11-06-92

TI-NHTSA 003442

77PS IMPULSE TEST LOG SHEET

DISC LOT	DEVICE	START	STOP	DATE
243	23-3	10:00 PM	11:10 AM	11-27-92 11-27-92 11-30-92
297/298	L3-3	6:45 PM	8:25 AM	12-1-92
300	L3-3	9:00 PM	1:15 PM	12-2-92 12-01-92
303/302	L3-3 / L2-3	3:30 PM	4:45 AM	12-03-92 12-12-92
896AA	L5-2	4:50 AM		12-03-92
305/306	L3-3	6:15 PM	7:40 AM	12-04-92 12-03-92
307	L2-1	8:00 AM	9:30 PM	12-04-92
308-309	L2-3	10:00 PM	10:55 AM	12-05-92
810	L9-1	10:55 PM	12:30 AM	12-08-92 12-9-92
312/311	77PS L3-3	10:15 AM	11:35 AM	12-9-92 12-11-92
317/318	L3-3 / L2-1	2:35 PM		12-11-92

77PS

IMPULSE TEST LOG SHEET

DISC LOT	DEVICE	START	STOP	DATE
325/319	X3-3 / X2-1	10:15 PM	11:40 AM	12-15-92
321/322	L2-1	11:50 AM	approx 1:00 PM	12-16-92
323/331	X2-1 / X2-3	1:00 AM	2:50 PM	12-16-92
320/324	L2-1	3:00 PM	approx 4:15 AM	12-17-92
326A/327A	L3-3	5:15 AM	7:00 PM	12-17-92
332/333	L3-3	7:30 P.M.	3:50 AM	12-18-92
334/335	L2-3 / L2-1	11:00 AM	12:30 AM	12-19-92
334/337	X2-1	10:15 PM	11:45 AM	12-20-92
296AA	L5-2	6:00 PM	7:20 AM	12-21-92
3-30	L3-3	7:40 AM	11:30 AM	12-22-92
338A/339A	P3 3	10:15 PM	11:30 AM	1-3-93
				1-4-93

HIGHLIGHTS

Stephen B. Offiler
Week Ending 91-11-08

Handwritten initials and date:
11/11/88



FORD MY92 ELECTRONIC SPEED CONTROL DEACTIVATE PS

PASS-CAR REVALIDATION:

Two lots of parts were constructed to undergo the combined Fluid Resistance and Impulse testing, which was compromised in the original validation attempt. One lot uses the desired production technique (AMI) whereas the other uses the technique we were forced into as a fallback during the original validation (57PS Hand Line). Based on results of failure testing over the last several weeks, the best-performing crimp dies and washers were used. Half of each lot was precharacterized and delivered to the Chem Lab on time to begin the Fluid Resistance test on schedule Tuesday. The other half, which undergo only impulse, started cycling on Wednesday. These will complete their 475K mechanical cycles early Saturday, and Jeff will come in to set up and run the 25K powered cycles. Post-characterizations will be done early next week, then all parts will be run to failure in order for the sake of information. An interesting observation was made regarding actrel pressure. Parts crimped on the head-line were lower on average than the AMI parts, by about 3 psi on act and 11 psi on release. We plan to take a closer look at this phenomenon to see if it provides any clues to the diaphragm life issue.

KAPTON DIAPHRAGM LIFE:

We're continuing to work on the teardrop shape in the Kapton surface as a contributor to early life failures. We've seen the perforation in the diaphragm to generally coincide with the apex of the teardrop if present; if absent the diaphragm wear is well distributed around the perimeter. We're looking into the possible mechanisms that promote teardrop formation, including pre-crimp, gasket friction, and asymmetric clamping. We're also looking into whether teardrop formation is an issue with Light Truck parts.

CUSTOMER ISSUES, SAMPLES:

For the Ford of Australia samples, the M10 x 1.0 hexports were completed by an outside house, placed in B11, and have been built into devices. We planned to test these on the production tester, but apparently it would not seal properly. We're making an adapter so we can manually test these on our Life Test check station. They will ship today, on-time per the revised schedule. They were originally promised for 91-09-17 until confusion over thread spec's arose.

Charlie Douglas met with Bruce Pease earlier this week to discuss the Kapton life / revalidation issue. Charlie reports that the meeting went well, and Bruce is convinced we're making good progress on the solution to this problem. It looks like an extension to the 90-day slot is possible, if required. On another subject, Charlie hand-delivered the SREA for the change to blue-colored environmental seals for PC devices.

MECHANIZATION:

John Kourtesis and crew are presently working on eliminating the rivet from the Eastern Automation movable-terminal assembly machine. The two options being considered are ultrasonic welding and resistance welding. I'm working on a quick sketch of the terminal/spring redesign for presentation at a meeting John will hold early next week. Of course, this change will require revalidation. I propose that we use our P & DFMEA's to drive the justification for this change, possibly rethinking the PRN's associated with the rivet and riveting process relative to a welding process.

TI-NHTSA 003445

-MSG #=- 72120 FR-SBO1 TO-CPPC SENT=11/08/91 10:44 AM
R/-105 ST=C DIV=0050 CC=00101 BY-SBO1 AT=11/08/91 10:44 AM

TO: Tom Burke MFPC Steve Major WHLZ
Jeff DiDomenico ELB Matt Sellers PCME
Charlie Douglas CPPC Rusty Struble RCS2
Paul Kotch PRK1 Jim Watt PCQA

CC: Tom Charboneau (delivered separately)
Dave Czarn

FR: Steve Offiler SBO1

SJ: Weekly Highlights

FORD MY'92 ELECTRONIC SPEED CONTROL DEACTIVATE PS

PASS-CAR REVALIDATION:

Two lots of parts were constructed to undergo the combined Fluid Resistance and Impulse testing, which was compromised in the original validation attempt. One lot uses the desired production technique (AMI) whereas the other uses the technique we were forced into as a fallback during the original validation (S7PS Hand Line). Based on results of failure testing over the last several weeks, the best-performing crimp dies and washers were used. Half of each lot was precharacterized and delivered to the Chem Lab on time to begin the Fluid Resistance test on schedule Tuesday. The other half, which undergo only Impulse, started cycling on Wednesday. These will complete their 475K mechanical cycles early Saturday, and Jeff will come in to set up and run the 25K powered cycles. Post-characterizations will be done early next week, then all parts will be run to failure in order for the sake of information. An interesting observation was made regarding act/rel pressures. Parts crimped on the hand-line were lower on average than the AMI parts, by about 3 psi on act and 11 psi on release. We plan to take a closer look at this phenomenon to see if it provides any clues to the diaphragm life issue.

KAPTON DIAPHRAGM LIFE:

We're continuing to work on the teardrop shape in the Kapton surface as a contributor to early life failures. We've seen the perforation in the diaphragm to generally coincide with the apex of the teardrop if present; if absent the diaphragm wear is well distributed around the perimeter. We're looking into the possible mechanisms that promote teardrop formation, including pre-crimp, gasket friction, and asymmetric clamping. We're also looking into whether teardrop formation is an issue with Light Truck parts.

CUSTOMER ISSUES, SAMPLES:

For the Ford of Australia samples, the M10 x 1.0 hexports were completed by an outside house, plated in B11, and have been built into devices. We planned to test these on the production tester, but apparently it would not seal properly. We're making an adapter so we can manually test these on our Life Test check station. They will ship today, on-time per the revised schedule. They were originally promised for 91-09-17 until confusion over thread spec's arose.

Charlie Douglas met with Bruce Pease earlier this week to discuss

TI-NHTSA 003448

the Kapton life / revalidation issue. Charlie reports that the meeting went well, and Bruce is convinced we're making good progress on the solution to this problem. It looks like an extension to the 90-day alert is possible, if required. On another subject, Charlie hand-delivered the SREA for the change to blue-colored environmental seals for PC devices.

MECHANIZATION:

John Kourtesis and crew are presently working on eliminating the rivet from the Eastern Automation movable-terminal assembly machine. The two options being considered are ultrasonic welding and resistance welding. I'm working on a quick sketch of the terminal/spring redesign for presentation at a meeting John will hold early next week. Of course, this change will require revalidation. I propose that we use our P & DFMEA's to drive the justification for this change, possibly rethinking the PRN's associated with the rivet and riveting process relative to a welding process.

Regards,
Steve O.

DIAPHRAGM LIFE: WASHER LOTS TEST 169-03-14 JAD 11/08/91

DEVT #	WASHER	BUILD DATE	CYC. TO FAILURE	SUSPENDED
169-03-01	0 CUT	911017	1328K	
169-03-02	NICKLE		1166K	
169-03-03	PLATE		603K	
169-03-04			1673K	
169-03-05				1670K
169-03-06			1548K	
169-03-07	2 CUT	911017	1166K	
169-03-08	ZINK		603K	
169-03-09	PLATE			1670K
169-03-10			902K	
169-03-11			1632K	
169-03-12			1404K	
169-03-13	0 CUT	911017	771K	
169-03-14	ZINK		426K	
169-03-15	PLATE		888K	
169-03-16			1166K	
169-03-17			1212K	
169-03-18			602K	

TI-NHTSA 003448

PRESSURE SWITCH DATA

Form 21605

TEST NO. 176-05-08

DEVICE CCPS	DATE REQUESTED 11/14/91	REQUESTED BY Steve Offley	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. Bonarise	DATE STARTED 11/11/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford 1972 Electronic Speed Control Pressure PS			

CUSTOMER:

PURPOSE OF TEST: **Cycle to failure validation input parts from tests 172-15-24 and 173-15-24**

PROCEDURE: **Inputs per Ford ES until leak occurs**

172-15-12 thru -24 : Control + 525K

173-15-13 thru -24 : control + 700K

Remain of Parts From 173-15-24 : Control + 1971

Device ID	Cramp	1-11	1-11	Failure	Success
172-15-12	Hard-	9111-2		1069	
-17	line				1386 K
-18			opened - not cycled	953K	
-19			opened - not cycled	970K	
-20					1386 K
-21				1326K	
-22				1629K	
-23				1630K	
-24				1639K	
-25				1674K	
173-15-13	AMT	91401		1471K	
-14				1697K	
-15			opened - not cycled		
-16			opened - not cycled		
-17			opened - not cycled		
-18				1772K	
-19			opened - not cycled		
-20					1361 K
-21				1361K	
-22				1620K	
-23					1361 K
-24				1972K	

TI-NHTSA 003449

PRESSURE SWITCH DATA

FORM 21605

TEST NO. 176-03-01

DEVICE CCPS	DATE REQUESTED 11/14/91	REQUESTED BY Steve Off. Key	REQUESTED COMPL. DATE
PERFORMED BY Jeffrey D. Penner	DATE STARTED 11/14/91	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Ford 1972 Electronic Speed Control Pressure PS			

CUSTOMER:

PURPOSE OF TEST: **Cycle to failure validation intake parts from tests 172-15-24 and 173-15-24**

PROCEDURE: **Intake per Ford ES until leaks occur**

172-15-18 then -24 : Control T 525K

173-15-18 then -24 : control T 700K

Remain. of Parts From 173-15-24 : Control T 1971

Pressure	Cycle	in. Hg	Failure	Suspected
172-15-17	Hard	91402	1525K	
-17	1100			1525K
-18			opened - not cycled	
-19			1525K	
-20			opened - not cycled	
-21			1525K	
-22			1525K	1525K
-23			1525K	
-24			1525K	
173-15-17	AMT	91402	1475K	
18			1475K	
19			opened - not cycled	
20			opened - not cycled	
21			opened - not cycled	
22			1475K	
23			opened - not cycled	
24			1475K	1475K
25			1475K	
26			1475K	
27			1475K	1475K
28			1475K	
29			1475K	

TI-NHTSA 003450

PRESSURE SWITCH DATA

Form 21605

TEST NO. 175-15-12

DEVICE <i>COPS</i>	DATE REQUESTED <i>11/10/91</i>	REQUESTED BY <i>Steve Off: 101</i>	REQUESTED COMPL. DATE
PERFORMED BY <i>Officer DiBenedictis</i>	DATE STARTED <i>11/17/91</i>	DATE COMPLETED	APPROVED BY
PROJECT TITLE: <i>Ford FX '92 Electronic Speed Control Reactivate PS</i>			

CUSTOMER:

PURPOSE OF TEST:

Next Page

PROCEDURE:

Pass - Cori Sensors hand built and crimped on hand line

DRIVE TESTING

Sensor #	Hex part	Barst				10410		10021
175-15-01	10021	7900				2.37	7	53
-02		8100				38		51
-03		7900				41		47
-04		9100				42		56
-05		8000				41		48
-06		8000				41		57
						42		45
175-15-07	25900	7600				39		54
-08		7600				47		50
-09		7900				41		51
-10		7600						
-11		7700						
-12		7600						

(OVER)

TI-NHTSA 003451

10B21 HEXPORT EVALUATION

PURPOSE: To make an initial determination of the relative suitability of 10B21 steel as a replacement for the current hexport material, 10L10.

SCOPE: Two basic tests of mechanical strength will be used to get a rough comparison of the two materials: a burst test, and a torque test. For the burst test, sensors will be built using 10B21 hexports and standard 36900's as a control, using either standard or rebump cups, either AMI or handline crimp (just be consistent). For the torque test, bare hexports may be used.

PROCEDURE:

(BURST)

Build 6 sensors with 10B21 hexports, and 6 sensors with 36900 hexports.

Burst all using the normal procedure.

Create a Weibull plot for each test lot.

(TORQUE)

Obtain a peak-hold torque wrench capable of roughly 50 ft-lb or better.

Place a 3/8-24 nut in a vise.

Thread in a hexport fully, and tighten to failure with the torque wrench. Record results, including failure mode, which is likely to be fracture at the O-ring gland, but may involve stripped threads in some situations. Of course, replace the nut if it becomes damaged.

Perform this test on about 10 of each. Present raw data to me for consideration whether Weibull plots or something else might be appropriate or even necessary.

SBO 911112 filename: hexeval.001

So 9/11/12

21 EXPORT EVALUATION TEST 175-15-12 JAN 11/15/91

BURST TEST			TORQUE TEST	
DEVICE #	EXPORT	BURST	10L10	10L21
175-15-01	10L21	7900	37	53
175-15-02	10L21	8100	38	51
175-15-03	10L21	7800	41	47
175-15-04	10L21	8100	42	56
175-15-05	10L21	8000	41	48
175-15-06	10L21	8000	41	57
			42	45
175-15-07	10L10	7600	39	54
175-15-08	10L10	7600	47	56
175-15-09	10L10	7800	41	51
175-15-10	10L10	7600		
175-15-11	10L10	7700		
175-15-12	10L10	7600		

TI-NHTSA 003453

HEXPORT MATERIAL EVALUATION 10L10 VS. 10B21

In order to determine if 10B21 steel is a suitable replacement/substitute for the present production 10L10 steel hexport material, three different types of tests were run. One involved cross-sectioning one hexport of each material and performing Diamond Pyramid Hardness readings in various areas, specifically at the roots and crests of the threads. The second test involved affixing the threaded portion in a vise and applying a measured torque to the hex until failure occurred. The third involved a burst test of actual pressure switches built with hexports of each material.

The results of the DPH test, using a 200-gram indenter, showed the average reading in the threaded area to be 244 for the 10B21 vs. 194 for the 10L10. A higher reading means greater hardness.

The torque test was run on ten hexports of each material. During this test, shear failure occurred at the thread undercut (similar geometry to the O-ring gland on hexports so intended) in all cases. 3/8-24 nuts were affixed to the male hexport thread with Loctite and held firmly in a vice to ensure that hexport failure would occur. (Preliminary testing showed the female thread would strip otherwise.) Torque was increased in 1 ft-lb increments with a limit-release type torque wrench, and the sequence of test parts was randomized to remove any potential effects of calibration drift. The average torque to reach shear failure was 51.8 ft-lb for 10B21 vs. 41.3 ft-lb for 10L10.


The burst test was run on 12 pressure switches total, using 6 hexports of each material. The procedure involves slowly increasing hydraulic pressure while observing a gage, and recording the peak value attained at the point of yield. This is signalled by a sudden drop in test pressure of several hundred psi, and is due to plastic deformation of some internal component(s) which results in a larger fluid volume, hence the pressure drop. The hexport is generally involved in the failure mode, showing some deformation in the flange area. Results show the average burst strength of devices built with 10B21 hexports was 7983 psi vs. 7650 for 10L10.

As can be seen above, in each of the three functional tests the 10B21 was shown to be superior. The magnitude of the improvement in physical properties is not extremely large, but significant nonetheless. The 10B21 material has higher carbon content, and contains boron to improve heat-treatability. Even without a heat-treat, this material will cold-work to a greater hardness than the 10L10 which accounts for the observed differences. There is no reason to expect any difference whatsoever in other properties, such as the level of corrosion protection offered by zinc and chromate plating.

Sign off
Stephen B. Offler, Design Engineer
Texas Instruments Inc.

TI-NHTSA 003454

Torque to failure of 70B21 Hexports



TI-NHTSA 003456

**TEXAS INSTRUMENTS**

INCORPORATED

MATERIALS AND CONTROLS GROUP

- ☐ ATTLEBORO, MA 01901 ☐ VERSAILLES, KY 40383
☐ JOHNSON CITY, TN 37601 ☐ CENTRAL LAKE, MI 49632

Shipping OrderDATE: / / S.O. # **214070**REF. # DATE SHIPPED / / SHIPPED VIA: SHIP
TO:

KELSEY-HAYES COMPANY
9475 Center Road
Fenton, Michigan 48430

Attn: Ms. Rita Gunia
Purchasing Dept.

CHARGE
TO:

Texas Instruments Inc.

USE (CHECK ONE)

- ☐ SCRAP SALES
☐ SALE OF ASSETS
☐ OUTSIDE PROCESSING
☐ TRANSFERS BETWEEN TI LOCATIONS
☐ EXPENSE MATERIAL
☒ OTHER, EXPLAIN: *implan*

DIV/ACCT. # 050 CC: 149

QUANTITY	DESCRIPTION/PART #/PC	UNIT PRICE	TOTAL
	One complete package One partial package 6 Samples	N/C	
GROSS WEIGHT	NO. OF CONTAINERS	ORIGINATOR'S NAME (TYPED) Elaine Rose MS 12-27	ORIGINATOR'S SIGNATURE <i>Elaine Rose</i>

S-075146 5/84

TI-NHTSA 003456

#5, #15, #23
Add CHAR.

#32, #33, #37,
#38, #39, #40, #51

Give - I'll draw it
on a following
Is your
want to write
PIST - if we
on the F3-3?
E -

F2UC-2F924-AB

MATERIAL ANALYSIS

PARTS LIST

	PART NAME	PART #	CERTIFIED
1	BASE	46515-2	YES
2	STA. TERM.	36888-1	YES
3	MOVE. CONTACT	74406-1	YES
4	RIVET	74171-1	YES
5	MOVE. TERM.	36887-1	YES
6	SPRING ARM	36889-1	YES
7	US12 HEXPORT	36900-1	YES
8	GASKET	74353-1	YES
9	CUP	27713-1	YES
10	SEAL	74176-1	YES
11	KAPTON STRIP	27225-1	YES
12	WASHER	27639-1	YES
13	CONVERTER	27406-1	YES
14	KAPTON TAPE	74224-1	YES
15	SPACER	73958-2/+3	YES
16	CRIMP RING	74797-1	YES
17	TRANSFER PIN	74078-SEL	YES
18	ENVIO. SEAL	74247-2	YES
19	THREAD CAP	74179-2	YES

TI-NHTSA 003458

K-H
PKG.
11-15-91

11-15-91

Jim -

77 P/C out of
spec issues
that need
to be
addressed.

Eric

**TEXAS
INSTRUMENTS**



ISIR SUBMISSION

*Office
Copy*

**TO KELSEY HAYES
FOR PART NUMBER F2VC-9F924-AB
NEXT GENERATION SPEED CONTROL**

NOVEMBER 15, 1991

TEXAS INSTRUMENTS INCORPORATED • 34 FOREST STREET • ATTLBORO, MA 01701
508-899-3800 • TELEX 210801 • CABLE TEXINS

*Prod. or Doc#
TI 20275-20587*

TI-NHTSA 003460

1-9-92

Resubmitted to K-H:

① FAT DATA Rewritten
to K-H Print & marked
print

② Copy of Ford PEST/PEAC
PPQI summary Data
sheet with significant
characteristics Identified

③ DFMEA & PFMEA

④ New Cert for -4

Enviro. Seal

Jim -
to send
this separate

1-9-92

K-H PKG 57F3-3

Included :

- ① PIPC
- ② R+R
- ③ Material Anal.

? may have
used PIPC
from L/T ?
??

11-15-91

TEXAS INSTRUMENTS

cc: E/line R.



Kelsey-Hayes Company
101 Oak Street
Milford, Michigan 48381

January 20, 1992

Attn: Mr. Clay Bailey
Manufacturing Engineer

Subj: Part Number E7BC-3N824-AA Pressure Switch *5-772-2*
Part Number F3TA-9F924-AA Pressure Switch *"7" 2-9-3*

Ref: Your 01/20/92 Telephone Call

Dear Clay,

The purpose of this letter is to substantiate our discussion concerning the above referenced pressure switches. The switches are to be assembled with the threaded metal hexport onto the application. Installation torque is to be applied only to the metal hexport part of the switch.

There is to be no torque applied to the plastic connector part of the switch. Any torque applied to the plastic connector may cause abnormal operation, damage, or destruction of the switch function.

Please let me know if you have any questions or if I can be of any further assistance.

Regards,

[Signature]
Jim Watt
PRA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Thomas Dan, Kelsey-Hayes Supplier Quality, Fenton, Mi.
Rita Gunia, Kelsey-Hayes Purchasing Dept., Fenton, Mi.
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

C. = Elavick

TEXAS INSTRUMENTS



December 19, 1991

Kelsey-Hayes Company
9475 Center Road
Fenton, Michigan 48430

Attn: Mr. Thomas B. Dan
Supplier Quality Assurance

Subj: Part Number 12590701 Pressure Switch (F2VC-9F924-AB)
Supplier Manufacturing Change Request (SMCR)

Ref: Your 12/17/91 Telephone Call

Dear Tom,

Enclosed, please find the SMCR describing the proposed change for the Kelsey-Hayes part number 12590701. We believe that the errors were inadvertently created from the recent ECN No. 25136.

After reviewing the SMCR, please let me know if you have any questions or if I can be of any further assistance.

Regards,

[Signature]
Jim Watt
SQA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Rita Gunia, Kelsey-Hayes Purchasing Dept., Fenton, MI.
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

enc: SMCR, ECN no. 25136



KELSEY-HAYES

SUPPLIER MANUFACTURING CHANGE REQUEST

PART NAME: Pressure Switch	REQUEST NUMBER:	BUYER: Rita Gunia	DATE: 12/18/91
PART NUMBER: 12590701	PRODUCT LINE:	P.O.C.N. NUMBER:	R/P LEVEL: A
SUPPLIER: Texas Instruments Inc	K-H USING PLANT: Milford	SUPPORTING DATA ATTACHED?	YES ☐ NO ☒

REASON FOR CHANGE/PURPOSE: 1.) Update and correct Kelsey-Hayes drawing to reflect correct Ford part number and Ford ES specification number.

2.) Kelsey-Hayes ECM No. 25136 (9/5/91) created error.

ECM No. 25136 copy is attached.

ORIGINATOR: Jim Watt *JW* TITLE: QRA Engr. CONCURRENCE: Charife Douglas TITLE: Prod. Specia

DESCRIPTION: Kelsey-Hayes drawing no. 12590701-A should be changed to reflect:

1.) Ford Motor Co. Part No. V F2VC-9F924-AB

2.) Ford Motor Co. Specification No. V ES-F2VC-9F924-AA

PLAN FOR VERIFICATION & TESTING: Validation of these changes made with Ford Motor Co.

DISPOSITION - BY KELSEY-HAYES

APPROVE	REJECT	DISTRIBUTION	INSTRUCTIONS, QUALIFICATIONS AND/OR REASON FOR REJECTION:
		K-H PURCHASING	
		PLANT MANUFACTURING ENGINEERING	
		PLANT QUALITY CONTROL	
		K-H PRODUCT ENGINEERING	
		K-H SALES	
		PROCUREMENT or DIVISIONAL QUALITY ASSURANCE	

TI-NHTSA 003465

SIGN LEVEL REQUIRED-

☐ NONE ☐ 1 ☐ 2 ☐ 3

10/30/91 PQA-S-1.7



KELBEY-HAYES

ENGINEERING

CHANGE NOTICE

PRIO. AREA: VALVES	SUBJECT: FN-10 PRESSURE SWITCH	PROGRAM: DUAL PROP	MODEL YEAR: 93	CUSTOMER(S): FORD	ECN NO.: 25136 PAGE 1 OF 1
NATURE OF CHANGE: REVISE THE T.I. PRESSURE SWITCH - NEW AUTOMATED VERSION IS AVAILABLE. NOTE: THIS IS A CHANGE TO CUSTOMER DRAWING. REASON: CUSTOMER REQUEST: ☒ PLANT REQUEST: ☐ VENDOR/PURCHASING REQUEST: ☐ T.I. NOW HAS THEIR AUTOMATED ASSY GOING. - NEED TO UPDATE PRINTS SO ISIR WILL REFLECT PRODUCTION LEVEL SWITCH. KS TEST WILL BE PERFORMED ON ENTIRE VALVE FOR 1000 TO FIND.				EPA NO.: 48011-B CLASSIFICATION: REF. DOCUMENTS: REGULAR ☒ CUST. CHG.: RECORD ☐ K-H DEV./MCR: MANDATORY ☐ K-H EST.: EXPEDITED ☐ K-H NTR.: VEHICLE APPLICATION: ATTACHMENTS: PASSENGER ☒ DISTRIBUTION CODE: TRUCK ☐ SERVICE ☐	
IS TEST REQUIRED: YES ☒ NO ☐ CONCURRENT ☐ TEST DURATION, DAYS: 30				INITIATED BY: J. COSSINS 8-2 DATE: 9-5-91	
APPROVED BY:					
PRODUCT ENGINEERING		DATE	DATE		DATE
NEW ENGINEER	J.H. COSSINS	8-2-91	DA	T. PRYOR/LV	8-20-91
MATERIALS	NR		CALLS	D. CLINE/CD	8-8-91
MANAGER	C.A. WILLI	8-2-91	CUST. AUTHORIZATION YES ☐ NO ☐		8-13-91
CHG. ENGINEER	C. BONDING	8-2-91	COST RECOVERABLE? YES ☐ NO ☐		8-20-91
SEE ENGINEERING MANUAL SECTION 2.811			SERVICE MANUAL REVIEWED? NO		
AFFECTED DESIGN DATA BANK: REVIEWED? YES REVISED? NO			FMEA REVIEWED? YES FMEA REVISED? NO		
DELETE	REPLACE	RELEASE	CHANGE	CHG. LEVEL	PART NAME / REVISION
			D-12590701	AS	ASSY - PRESSURE SWITCH - REVISE TO T.I. PRINT 77PSL2-1 WAS TO 57PSL5-3. NOTE THE ONLY VISIBLE CHANGE IS THE OVERALL LENGTH ON SWITCH. SO SPECIFIC CHANGES ARE: 1) CHANGE TO "57.15 MAX" WAS "62.23 MAX" 2) CHANGE TO "F2VC-9P924-AA" WAS "F3VC-9P924-AA" 3) CHANGE T.I. P/N TO "77PSL2-1" WAS "57PSL5-3" 4) REMOVE "FOR FINAL ASSY SEE DWG. 12575501" ASSY 'S - FN-10 DUAL PROP - REFLECT ABOVE CHANGES ON THESE DRAWINGS AND PARTS LIST
			D-12603101	B	
			D-12603101	B	
			D-12603401	B	
			P-12603401	B	
			P-12603101	B	
APPROVED					
PLANT(S) INVOLVED: AUG 20 1991				N.H. FORD	
				ECN NO.: 25136	

TI-NHTSA 003486

DO NOT ATTEMPT TO RE-TEST OR RE-TEST ETC. ALSO RELATING TO DEPARTMENTS CONCERNED



KELSEY-HAYES

SUPPLIER MANUFACTURING CHANGE REQUEST

PART NAME: <u>Pressure Switch</u>	REQUEST NUMBER:	BUYER: <u>Rita Gunia</u>	DATE: <u>12/18/91</u>
PART NUMBER: <u>12590701</u>	PRODUCT LINE:	P.O.C.N. NUMBER:	S/P LEVEL: <u>A</u>
SUPPLIER: <u>Texas Instruments</u>	K-H USING PLANT: <u>FORD</u>	SUPPORTING DATA ATTACHED: ☒ YES ☐ NO	

REASON FOR CHANGE/PURPOSE: ① Update and correct Kelsey-Hayes drawing to reflect correct Ford part no. and Ford EE specification number.

② N-H ECN NO 25136 (2/5/91) correct error.

ORIGINATOR: Jim Watt TITLE: QA Engineer CONCURRENCE: Charlie Dangle TITLE: Product Engineer

DESCRIPTION: Kelsey-Hayes Drawing No. 12590701-A should be changed to reflect:

1) Ford Motor Part No. F52YC-9F924-AB

2) Ford Motor Spec No. FE-52YC-9F924-AA

PLAN FOR VERIFICATION & TESTING: Validate that change with Ford motor.

DISPOSITION - BY KELSEY-HAYES

APPROVE	REJECT	DISTRIBUTION	INSTRUCTIONS, QUALIFICATIONS AND/OR REASON FOR REJECTION:
		K-H PURCHASING	
		PLANT MANUFACTURING ENGINEERING	
		PLANT QUALITY CONTROL	
		K-H PRODUCT ENGINEERING	
		K-H SALES	
		PROCUREMENT or DIVISIONAL QUALITY ASSURANCE	

K-H LEVEL REQUIRED:

☐ K-H ☐ P ☐ Q ☐ R

10/28/91 P&A, L-1, P&A

TI-NHTSA 003457

TEXAS
INSTRUMENTS



Kelsey-Hayes Company
101 Oak Street
Milford, Michigan 48361

January 13, 1992

Attn: Mr. John Shorkey
Quality Engineer

Subj: Part Number E78C-3N824-AA Pressure Switch
Part Number F3TA-9F924-AA Pressure Switch

Ref: Your 01/14/92 Telephone Call

Dear John,

We have confirmed the actuation pressures for
Kelsey-Hayes part number numbers as follows:

Part number	Actuation Pressure
E78C-3N824-AA	350-450 psi
F3TA-9F924-AA	200-300 psi

I have also enclosed a copy of Mr. Thomas Dan's 12/20/91
letter as you requested.

Please let me know if you have any questions or if I
can be of any further assistance.

Regards,


Jim Watt
QRA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Thomas Dan, Kelsey-Hayes Supplier Quality, Fenton, Mi.
Rita Gunia, Kelsey-Hayes Purchasing Dept., Fenton, Mi.
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

cc: Elaine R.

TEXAS INSTRUMENTS



December 13, 1991

Kelsay-Hayes Company
9475 Center Road
Fenton, Michigan 48430

Attn: Mr. Thomas G. Dan
Supplier Quality Assurance

Subj: Part Number 12604301 Pressure Switch (E7SC-3N824-4A)
Part Number 12590701 Pressure Switch (F2VC-9F924-AB)
ISIR Submissions

Ref: Your 12/11/91 Telephone Conversation

Dear Tom,

Confirming your agreement that the ISIR submission documents that Texas Instruments uses need not be Kelsay-Hayes specific documents. We currently utilize Ford formatted documents for our ISIR submissions. In the event that Kelsay-Hayes has content specific requirements that are different from our current ISIR submission, we will provide those specific requirements on Kelsay-Hayes' documents.

After reviewing the ISIR submissions, please let me know if you have any questions or if I can be of any further assistance.

Regards,


Jim Watt
SQA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Rita Gunia, Kelsay-Hayes Purchasing Dept., Fenton, MI.
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

TEXAS
INSTRUMENTS



CC = E1.2.1.1.1.2.

December 10, 1991

Kelsey-Hayes Company
9475 Center Road
Fenton, Michigan 48430

Attn: Mr. Thomas G. Dan
Supplier Quality Assurance


Subj: Part Number 12604301 Pressure Switch (E7SC-3NB24-AA)
Part Number 12580701 Pressure Switch (E211C-9F924-AB)
ISIR Submissions

Dear Tom,

Just a short note to thank you for your efforts in locating the ISIR submission packages for the two pressure switches that were sent to Kelsey-Hayes on November 20, 1991 and signed for by " P. Ovington " at the Kelsey-Hayes receiving location.

After reviewing the submissions, please let me know if you have any questions or if I can be of any further assistance.

Regards,


Jim Watt
ORA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Rita Gunia, Kelsey-Hayes Purchasing Dept., Fenton, MI.
Andy McQuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

**TEXAS
INSTRUMENTS**



cc = ELINER.

December 03, 1991

Kelsey-Hayes Company
9475 Center Road
Fenton, Michigan 48430

Attn: Ms. Mary Cooney
Shipping Department

Subj: Part Number 12604301 Pressure Switch (E78C-3NB24-AA)
Part Number 12590701 Pressure Switch (F2VC-9F924-A3)
ISIR Submissions

Dear Mary,

A package containing pressure switches and test documents was sent via UPS to Ms. Rita Gunia of your purchasing department on November 20, 1991. The package was signed for by "P. Ovington" at the Kelsey-Hayes receiving location.

Could you please let me know if the package was inadvertently routed to someone other than Ms. Rita Gunia, or if you know of the individual "P. Ovington"? A copy of the shipping document is attached.

I can be reached at: (508) 699-1719. Thank you in advance for your help.

Regards,


Jim Watt
CNA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Rita Gunia, Kelsey-Hayes Purchasing Dept., Fenton, MI.
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

encl: UPS Shipping Document # 214070

SHIP
TO:

WASHTON-NTS
SITE Center Box
Hudson, Michigan
Attn: Mr. Rita Smith
Purchasing Dept

UNCLASSIFIED
DATE 12-31-87

GROSS WEIGHT	NO. OF CONTAINERS	ORIGINATOR'S NAME (TYPED)	ORIGINATOR'S SIGNATURE
2.4	1 CIV	Elaine Rose MS 12-37	

U.S. GOVERNMENT

ORIGINATOR COPY

TI-NHTSA 003472

MASA

C_i

C_{pk}

.22

3.15

MASR

.16

4.14

$$C_i = C_p$$

$$1 \div .15 = 6.66$$

$$C_i = C_p$$

$$1 \div .24 = 4.16$$

57PSMASA

$\bar{X} \neq R$ ✓

Histo's ✓

57PSMASR

$\bar{X} \neq R$

Histo's

~~1.14~~

cc = Elaine L.

TEXAS INSTRUMENTS



March 16, 1992

Kelsey-Hayes Company
9475 Center Road
Fenton, Michigan 48430

Attn: Mr. Thomas G. Dan
Supplier Quality Assurance

Subj: Part Number 12590701 Pressure Switch (F2VC-9F924-AB)
ISIR Approval

Ref: Your 03/09/91 Telephone Call

Dear Tom,

Enclosed, please find the approved ISIR signed by Ford SQA
for the Kelsey-Hayes part number 12590701.

After reviewing the ISIR, please let me know if you
have any questions or if I can be of any further assistance.

Regards,

Jim Watt
SQA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Rita Dunia, Kelsey-Hayes Purchasing Dept., Fenton, MI.
Andy McGuirk, MS 12-27
Norm Frede, TI Farmington Hills, Michigan

encl: ISIR No. 112364

INITIAL SAMPLE WARRANT

No. 112384

PART INFORMATION

Part Name NEXT GENERATION SPEED CONTROL Part Number F2VC-9F924-AB
 Control Item ☒ Yes ☐ No Engineering Change Level G Date 4-11-91
 Engineering Change Authorization PRICE - PLEASE Date _____
 Shown on Drawing No. F2VC-9F924-AB Part Weight 062

Reason for Initial Sample:

☐ Initial Submission ☐ Change in Optional Construction or Material ☐ Process Change
☐ Engineering Change(s) ☐ Additional Replacement, or Refurbished Tooling ☐ Change in Subcontractor or Source
☐ Tooling Transfer ☒ Correction of Discrepancy (Resubmission No. SEE BELOW) ☐ Parts Produced at Additional Location
☐ Other - Please Specify _____

SUPPLIER INFORMATION (Manufacturing Location)

Supplier Name TEXAS INSTRUMENTS Street Address 34 FOREST STREET
 City ATTLEBORO State MA Postal Code 02703 Country USA
 Supplier Mfg. Location Code - CUNS T097K Customer Assigned FORD MOTOR CO - EED

CUSTOMER INFORMATION

Customer Name FORD MOTOR CO - EED Buyer FRED HENDERSHOT Buyer Code 165
 Purchase Order Number _____ Sample Acceptance Level 7
 Application NEXT GENERATION SPEED CONTROL

RESULTS

The results for dimensional measurements ☒ material tests ☒ and functional (ES) tests ☒ meet or drawing and specification requirements ☒ Yes ☐ No

Submission Checked:

☐ Checked Print ☐ Material Test Results ☐ Control Plan
☐ Auxiliary Drawings/Sketches ☐ Certifications ☐ Process Capability Results
☐ Correct Number of Samples ☒ Functional (ES) Test Results ☐ Process Flow Diagram
☒ Dimensional Results ☐ Product Engineering Approval ☐ Gage (Measurement) Studies

Supporting data for all requirements are available upon request.

COMMENTS:

ISR SUPPLEMENT WITH ADDITIONAL TESTING TO CLOSE OUT ALERT NO. A10166193;
ALSO, CORRECTED BASE MOLD DIMENSIONS. PART PREVIOUSLY APPROVED ON
ISN # 112384, DATED 7/21/91

DECLARATION

I affirm that the samples represented by this warrant are representative of our parts and have been made to the applicable customer drawings and specifications from specified materials, on regular production tooling with no operations other than the regular production process.

Authorized Signature Jim Watt Date 12/30/91
 Title JIM WATT Title QA ENGINEER Phone No. 508-699-1719

APPROVAL (when required by customer drawings)

☒ Approved ☐ Rejected
 Signature [Signature] Date 1/14/92
 Part No. 202C Vendor VEHICLE CONTROLS E&A

TEXAS INSTRUMENTS



Kelsey-Hayes Company
9475 Center Road
Fenton, Michigan 48430

January 09, 1992

Attn: Mr. Thomas G. Dan
Supplier Quality Assurance

Subj: Part Number 12590701 Pressure Switch (F2VC-9F924-AB)
IBIR Addendum

Ref: Your 12/20/91 Letter

Dear Tom,

Enclosed, please find the dimensional layout for the pressure switch, Kelsey-Hayes part number 12590701. Please refer to the SMCR that was submitted on 12/19/91 to correct the 12590701 release drawing.

We have also included copies of the design FMEA, process FMEA, and designated key characteristics list. We believe this completes the IBIR submission requirements for part number 12590701.

After reviewing the IBIR addendum, please let me know if you have any questions or if I can be of any further assistance.

Regards,

Jim Watt
DRA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Rita Gunia, Kelsey-Hayes Purchasing Dept., Fenton, Mi.
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

encl: IBIR Addendum For 12590701

TEXAS INSTRUMENTS

cc= E/IND R.

FyI: JF



November 15, 1991

Kelsey-Hayes Company
9475 Center Road
Fenton, Michigan 48430

Attn: Ms. Rita Gonia
Purchasing Department

Subj: Part Number 12604301 Switch (E7SC-3N824-AA)
Part Number 12590701 Switch (F2VC-9F924-AB)
ISIR Submissions

STP 3-3
TEL 2-1

Dear Rita,

Enclosed, please find the ISIR for the 12604301 and 12590701 switches. Both ISIR submissions were accomplished on Ford forms as we are in the process of transferring data to Kelsey-Hayes forms.

The 12590701 submission has several dimensional issues on the layout that are being addressed.

The 12604301 submission needs dimensional layout, control plan, manufacturing flow diagram, PIST, PIPC, and PV testing that are being addressed.

Please let me know if you have any questions or if I may be of any further assistance.

Regards,


Jim Matt
SRA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Gary Snyder, MS 12-33
Charlie Douglas, MS 12-33
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

encl: ISIR submissions

**TEXAS
INSTRUMENTS**



ISIR SUBMISSION

**TO KELSEY HAYES
FOR PART NUMBER F2VC-9F924-AB
NEXT GENERATION SPEED CONTROL**

NOVEMBER 15, 1991

A1-1

77PSL2-1

K-H

TEXAS INSTRUMENTS, INC. ISIR SUBMISSION
TO KELSEY HAYES
FOR PART NUMBER F2VC-9F924-AB (77PSL2-1)

K-H PKG 57F3-3

Included :


① PIRC

② R+R

③ Material Anal.



H-75-91



TEXAS INSTRUMENTS

cc: E/WWR



Kelsey-Hayes Company
101 Oak Street
Milford, Michigan 48381

January 20, 1992

Attn: Mr. Clay Bailey
Manufacturing Engineer

Subj: Part Number E78C-3N824-AA Pressure Switch 5-7F3-3
Part Number F3TA-9F924-AA Pressure Switch 77.10-3

Re: Your 01/20/92 Telephone Call

Dear Clay,

The purpose of this letter is to substantiate our discussion concerning the above referenced pressure switches. The switches are to be assembled with the threaded metal hexport onto the application. Installation torque is to be applied only to the metal hexport part of the switch.

There is to be no torque applied to the plastic connector part of the switch. Any torque applied to the plastic connector may cause abnormal operation, damage, or destruction of the switch function.

Please let me know if you have any questions or if I can be of any further assistance.

Regards,


Jim Watt
DFA Engineer

Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Thomas Dan, Kelsey-Hayes Supplier Quality, Fenton, MI.
Rita Gunia, Kelsey-Hayes Purchasing Dept., Fenton, MI.
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

cc = Blain, R.

TEXAS INSTRUMENTS



December 19, 1991

Kelsey-Hayes Company
9475 Center Road
Fenton, Michigan 48430

Attn: Mr. Thomas G. Dan
Supplier Quality Assurance

Subj: Part Number 12590701 Pressure Switch (P2VC-9F924-AB)
Supplier Manufacturing Change Request (SMCR)

Ref: Your 12/17/91 Telephone Call

Dear Tom,

Enclosed, please find the SMCR describing the proposed change for the Kelsey-Hayes part number 12590701. We believe that the errors were inadvertently created from the recent ECN No. 25136.

After reviewing the SMCR, please let me know if you have any questions or if I can be of any further assistance.

Regards,


Jim Watt
SQA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Rita Gunis, Kelsey-Hayes Purchasing Dept., Fenton, MI.
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

encl: SMCR, ECN no. 25136



KELSEY-HAYES

SUPPLIER MANUFACTURING CHANGE REQUEST

PART NAME: Pressure Switch	REQUEST NUMBER:	BUYER: Rita Gunia	DATE: 12/18
PART NUMBER: 12590701	PRODUCT LINE:	P.O.C.N. NUMBER:	S/P LEVEL: A
SUPPLIER: Texas Instruments Inc	K-H USING PLANT: Milford	SUPPORTING DATA ATTACHED ☐ YES ☐ NO	

REASON FOR CHANGE/PURPOSE: 1.) Update and correct Kelsey-Hayes drawing to reflect correct Ford part number and Ford ES specification number.

2.) Kelsey-Hayes ECN No. 25136 (9/5/91) created error.

ECN No. 25136 copy is attached.

ORIGINATOR: Jim Watt ~~SA/DA~~ TITLE: QRA Engr. CONCURRENCE: Charlie Douglas TITLE: Prod. Specia

DESCRIPTION: Kelsey-Hayes drawing no. 12590701-A should be changed to reflect:

1.) Ford Motor Co. Part No. V P2VC-9F924-AB

2.) Ford Motor Co. Specification No. V ES-P2VC-9F924-AA

PLAN FOR VERIFICATION & TESTING: Validation of these changes made with Ford Motor Co.

DISPOSITION - BY KELSEY-HAYES

APPROVE	REJECT	DISTRIBUTION	INSTRUCTIONS, QUALIFICATIONS AND/OR REASON FOR REJECTION:
		K-H PURCHASING	
		PLANT MANUFACTURING ENGINEERING	
		PLANT QUALITY CONTROL	
		K-H PRODUCT ENGINEERING	
		K-H SALES	
		PROCUREMENT or DIVISIONAL QUALITY ASSURANCE	

THIS LEVEL REQUIRED:

☐ PMK ☐ Q ☐ CA ☐ CP

10/25/91 PMA, L-1, PC

TI-NHTSA 003484



KELSEY-HAYES ENGINEERING CHANGE NOTICE

PROD. AREA: VALVES	SUBJECT: FM-10 PRESSURE SWITCH	PROGRAM: DUAL PROP	MODEL YEAR: 93	CUSTOMER(S): FORD	ECN NO.: 25136			
NATURE OF CHANGE: REVISE THE T.I. PRESSURE SWITCH - NEW AUTOMATED VERSION IS AVAILABLE.				EPA NO.: 48011-B	CLASSIFICATION: REGULAR ☒ RECORD ☐ MANDATORY ☐ EXPEDITED ☐			
NOTE: THIS IS A CHANGE TO CUSTOMER DRAWING.				CUST. CHG.: K-H DEV./MCR.	VEHICLE APPLICATION: PASSENGER ☒ TRUCK ☐ TRAILER ☐ SERVICE ☐			
REASON: CUSTOMER REQUEST: ☒ PLANT REQUEST: ☐ VENDOR/PURCHASING REQUEST: ☐ T.I. NOW HAS THEIR AUTOMATED ASSY GOING. - NEED TO UPDATE PRINTS SO ISIR WILL REFLECT PRODUCTION LEVEL SWITCH. ES TEST WILL BE PERFORMED ON ENTIRE VALVE FOR ISIR TO FORD.				K-H EST.: K-H NTR:				
IS TEST REQUIRED? YES ☒ NO ☐ CONCURRENT ☐ TEST DURATION, DAYS: 30				ATTACHMENTS:				
APPROVED BY: PRODUCT ENGINEERING				DISTRIBUTION CODE:				
DESIGNED BY: J.M. COSSINS				INITIATED BY: J. COSSINS 8-2	DATE: 9-5-91			
DATE: 8-2-91								
CHECKED BY: C. DOWLING								
DATE: 8-2-91								
SALES: D. CLINE/CD								
DATE: 8-8-91								
CUST. AUTHORIZATION: YES ☐ NO ☒								
COST RECOVERABLE? YES ☐ NO ☒								
ENGINEERING SERV. CAW								
(SEE ENGINEERING MANUAL SECTION 2.81)								
AFFECTED DESIGN DATA BANK: REVIEWED? YES ☒ NO ☐								
SERVICE MANUAL REVIEWED? NO								
FMEA REVIEWED? YES ☒ NO ☐								
DELETE	REPLACE	RELEASE	CHANGE	CHG. LEVEL	PART NAME / REVISION	CO-DR. CHG.	PURCH. PART X	STOCK DISPOSITION
			D-12590701	A5	ASSY - PRESSURE SWITCH - REVISE TO T.I. PRINT 77PSL2-1 WAS TO 57PSL5-3. NOTE THE ONLY VISIBLE CHANGE IS THE OVERALL LENGTH ON SWITCH. SO SPECIFIC CHANGES ARE: 1) CHANGE TO "57.15 MAX" WAS "62.23 MAX" 2) CHANGE TO "7F2VC-9F924-AA" WAS "F2VC-9F924-BA" 3) CHANGE T.I. P/N TO 77PSL2-1 WAS "57PSL5-3" 4) REMOVE "FOR FINAL ASSY SEE DWG. 12575501"	1...	X...	NO. STK.
			O-12603101	B	ASSY 'S - FM-10 DUAL PROP	1		NO. STK.
			D-12603101	B	- REFLECT ABOVE CHANGES ON THESE DRAWINGS AND PARTS LIST			
			D-12603401	B				
			P-12603401	B				
			P-12603101	B				
APPROVED								
POINTS INVOLVED: AUG 20 1991						HILFORD		ECN NO. 25136

COMPLETE ATTACHED COST SHEET, COST/LEAD ETC. INFO. RELATING TO DEPARTMENTS CONCERNED

TI-NHTSA 003485

KELSEY-HAYES SUPPLIER MANUFACTURING CHANGE REQUEST

PART NAME: <u>Pressure Switch</u>	REQUEST NUMBER:	DATE: <u>8/18/91</u>	DATE: <u>12/18/91</u>
PART NUMBER: <u>12590701</u>	PRODUCT LINE:	P.O.C.B. NUMBER:	R/P LEVEL: <u>A</u>
SUPPLIER: <u>Kelco Instrument</u>	K-H USING PLANT: <u> </u>	SUPPORTING DATA ATTACHED?	☒ YES ☐ NO

REASON FOR CHANGE/PURPOSE: (1) Update and correct Kelsey-Hayes drawing to reflect correct Ford Part No. and Ford ES Specification Number.
 (2) K-H ECN No 25136 (9/5/91) created error.

ORIGINATOR: JIM WATT TITLE: DRAWING CONCURRENCE: CHARLIE DAVIS TITLE: PRODUCT SPECIM

DESCRIPTION: Kelsey Hayes Drawing No. 12590701-A should be changed to reflect:
 1.) FORD MOTOR Part No. VF2VC-9F924-AB
 2.) FORD MOTOR Spec No. VES-F2VC-9F924-AA

PLAN FOR VERIFICATION & TESTING: VALIDATE these changes with Ford Motor Co.

DISPOSITION - BY KELSEY-HAYES

APPROVE	REJECT	DISTRIBUTION	INSTRUCTIONS, QUALIFICATIONS AND/OR REASON FOR REJECTION:
		K-H PURCHASING	
		PLANT MANUFACTURING ENGINEER	
		PLANT QUALITY CONTROL	
		K-H PRODUCT ENGINEERING	
		K-H SALES	
		PROCUREMENT or DIVISIONAL QUALITY ASSURANCE	

TECH LEVEL REQUIRED:

☐ 1 ☐ 2 ☐ 3 ☐ 4

(8/28/78) ASA 1-1.00

cc = Elmer

TEXAS INSTRUMENTS



Kelsey-Hayes Company
101 Oak Street
Milford, Michigan 48361

January 15, 1992

Attn: Mr. John Shorkey
Quality Engineer

Subj: Part Number E78C-3N824-AA Pressure Switch
Part Number F3TA-9F924-AA Pressure Switch

Ref: Your 01/14/92 Telephone Call

Dear John,

We have confirmed the actuation pressures for
Kelsey-Hayes part number numbers as follows:

<u>Part number</u>	<u>Actuation Pressure</u>
E78C-3N824-AA	350-450 psi
F3TA-9F924-AA	200-300 psi

I have also enclosed a copy of Mr. Thomas Dan's 12/20/91
letter as you requested.

Please let me know if you have any questions or if I
can be of any further assistance.

Regards,


Jim Watt
QA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Thomas Dan, Kelsey-Hayes Supplier Quality, Fenton, Mi.
Rita Gunia, Kelsey-Hayes Purchasing Dept., Fenton, Mi.
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

TEXAS
INSTRUMENTS



cc Elaine R.

December 13, 1991

Kelsey-Hayes Company
9475 Center Road
Fenton, Michigan 48430

Attn: Mr. Thomas G. Dan
Supplier Quality Assurance

Subj: Part Number 12604301 Pressure Switch (E78C-3N824-AA)
Part Number 12590701 Pressure Switch (F2VC-9F924-AB)
ISIR Submissions

Ref: Your 12/11/91 Telephone Conversation

Dear Tom,

Confirming your agreement that the ISIR submission documents that Texas Instruments uses need not be Kelsey-Hayes specific documents. We currently utilize Ford formatted documents for our ISIR submissions. In the event that Kelsey-Hayes has content specific requirements that are different from our current ISIR submission, we will provide those specific requirements on Kelsey-Hayes' documents.

After reviewing the ISIR submissions, please let me know if you have any questions or if I can be of any further assistance.

Regards,


Jim Watt
SQA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Rita Gunia, Kelsey-Hayes Purchasing Dept., Fenton, Mi.
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

cc - Elaine R.

**TEXAS
INSTRUMENTS**



December 10, 1991

Kelsey-Hayes Company
9475 Center Road
Fenton, Michigan 48430

Attn: Mr. Thomas G. Dan
Supplier Quality Assurance

Subj: Part Number 12604301 Pressure Switch (E78C-3NB24-AA)
Part Number 12590701 Pressure Switch (F2VC-9F924-AB)
ISIR Submissions

Dear Tom,

Just a short note to thank you for your efforts in locating the ISIR submission packages for the two pressure switches that were sent to Kelsey-Hayes on November 20, 1991 and signed for by " P. Ovington " at the Kelsey-Hayes receiving location.

After reviewing the submissions, please let me know if you have any questions or if I can be of any further assistance.

Regards,

[Signature]
Jim Watt
DMA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Rita Gunia, Kelsey-Hayes Purchasing Dept., Fenton, Mi.
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

✓ c/c Elaine R.

TEXAS INSTRUMENTS



December 05, 1991

Kelsey-Hayes Company
9475 Center Road
Fenton, Michigan 48430

Attn: Ms. Mary Cooney
Shipping Department

Subj: Part Number 12604301 Pressure Switch (E78C-3N824-AA)
Part Number 12590701 Pressure Switch (F2VC-9F924-AB)
ISIR Submissions

Dear Mary,

A package containing pressure switches and test documents was sent via UPS to Ms. Rita Gunia of your purchasing department on November 20, 1991. The package was signed for by "P. Ovington" at the Kelsey-Hayes receiving location.

Could you please let me know if the package was inadvertently routed to someone other than Ms. Rita Gunia, or if you know of the individual "P. Ovington"? A copy of the shipping document is attached.

I can be reached at: (508) 699-1719. Thank you in advance for your help.

Regards,


Jim Watt
DMA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Rita Gunia, Kelsey-Hayes Purchasing Dept., Fenton, Mi.
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

encl: UPS Shipping Document # 214070

TEXAS INSTRUMENTS

Shipping Sheet

INCORPORATED

- ☐ DELIVERY TO BE MADE BY AIR
☐ DELIVERY TO BE MADE BY WATER

SHIP TO:

HELENY-RAYNE COMPANY
9475 Center Road
Easton, Michigan 48820

Attn: Mr. Rich Smith
Purchasing Dept.

Take Eastern

USE FOR:

☐ RETAIL SALES

☐ SALE BY AGENTS

☐ SALE BY DEALERS

☐ SALE BY OTHERS

☐ SALE BY OTHERS

GROSS WEIGHT	NO. OF CONTAINERS	ORIGINATOR'S NAME (TYPED)	ORIGINATOR'S SIGNATURE
8.2	1014	Elaine Rose MS 12-77	<i>[Signature]</i>

3-77001-001

TI-NHTSA 003491

Submitted to NHTSA

① EAT Data submitted
to K-H Point & printed
print

② Copy of Ford Post/PPQ
PPQI summary Data
sheet with significant
contributions identified

③ DEPT. OF
TRANSPORTATION
NHTSA
7-1-84

cc = Elaine R.

TEXAS INSTRUMENTS



March 16, 1992

Kelsey-Hayes Company
9475 Center Road
Fenton, Michigan 48430

Attn: Mr. Thomas G. Dan
Supplier Quality Assurance

Subj: Part Number 12590701 Pressure Switch (F2VC-9F924-AB)
ISIR Approval

Ref: Your 03/09/91 Telephone Call

Dear Tom,

Enclosed, please find the approved ISIR signed by Ford SQA
for the Kelsey-Hayes print number 12590701.

After reviewing the ISIR, please let me know if you
have any questions or if I can be of any further assistance.

Regards,


Jim Watt
SQA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czern, MS 12-29; Charlie Douglas, MS 12-33
Rita Dunia, Kelsey-Hayes Purchasing Dept., Fenton, Mi.
Andy McGuire, MS 12-27
Norm Prada, TI Farmington Hills, Michigan

encl: ISIR No. 112364

TEXAS INSTRUMENTS INCORPORATED • 12000 TI DRIVE • DALLAS, TEXAS 75243
214-343-3000 • TELEX 730000 • CABLE TEXINS

TI-NHTSA 003493

INITIAL SAMPLE WARRANT

PAGE.002

No. 112384

PART INFORMATION

Part Name NEXT GENERATION SPEED CONTROL Part Number P2VC-9F924-AB
 Control Item ☒ Yes ☐ No Engineering Change Level G Date 4-11-91
 Engineering Change Authorization PRICE-PRASE Date _____
 Shows on Drawing No. P2VC-9F924-AB Part Weight 062

Reason for Initial Sample:

☐ Initial Submission ☐ Change in Optional Construction or Material ☐ Process Change
☐ Engineering Change(s) ☐ Additional, Replacement or Refurbished Tooling ☐ Change in Subcontractor or Source
☐ Tooling Transfer ☒ Change of Discrepancy (Resolution No. SEE BELOW) ☐ Parts Produced at Additional Location
☐ Other - Please Specify _____

SUPPLIER INFORMATION (Manufacturing Location)

Supplier Name TEXAS INSTRUMENTS Street Address 34 FOREST STREET
 City ATTLEBORO State MA Postal Code 02703 Country USA
 Supplier Mfg. Location Code - OUNS T097K Customer Assigned FORD MOTOR CO - EED

CUSTOMER INFORMATION

Customer Name FORD MOTOR CO - EED Buyer FRED HENDERSHOT Buyer Code 165
 Purchase Order Number _____ Sample Acceptance Level 1
 Application NEXT GENERATION SPEED CONTROL

RESULTS

The results for dimensional measurements ☒ material tests ☒ and functional (SIS) tests ☒ meet all drawing and specification requirements ☒ Yes ☐ No

Submission Checklist

☐ Checked Print ☐ Material Test Results ☐ Control Plan
☒ Auxiliary Drawings/Sketches ☐ Certifications ☐ Process Capability Results
☐ Correct Number of Samples ☒ Functional (SIS) Test Results ☐ Process Flow Diagram
☒ Dimensional Results ☐ Product Engineering Approval ☐ Gage (Measurement) Studies

Supporting data for all requirements are available upon request.

COMMENTS:

ISK SUPPLEMENT WITH ADDITIONAL TESTING TO CLOSE OUT ALERT NO. A10166193;

ALSO, CORRECTED DASH MOLD DIMENSIONS. PART PREVIOUSLY APPROVED ON

ISN # 112384, DATED 4/1/91

DECLARATION

I certify that the samples represented by this warrant are representative of our parts and have been made to the applicable customer drawings and specifications from specified materials, on regular production tooling with no operations other than the regular production process.

Authorized Signature JIM VATT Date 12/20/91
 Part Name JIM VATT Title QA ENGINEER Phone No. 508-699-1719

APPROVAL (please provide to customer) ☒ Approved ☐ Rejected

Signature [Signature] Date 1/14/92
 EHS 2020 PARCEL 112384-504

TI-NHTSA 003494

TEXAS INSTRUMENTS



Kelsey-Hayes Company
9475 Center Road
Fenton, Michigan 48430

January 09, 1992

Attn: Mr. Thomas G. Dan
Supplier Quality Assurance

Subj: Part Number 12590701 Pressure Switch (F2VC-9F924-AB)
ISIR Addendum

Re: Your 12/20/91 Letter

Dear Tom,

Enclosed, please find the dimensional layout for the pressure switch, Kelsey-Hayes part number 12590701. Please refer to the SMCR that was submitted on 12/19/91 to correct the 12590701 release drawing.

We have also included copies of the design FMEA, process FMEA, and designated key characteristics list. We believe this completes the ISIR submission requirements for part number 12590701.

After reviewing the ISIR addendum, please let me know if you have any questions or if I can be of any further assistance.

Regards,


Jim Watt
ARA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czarn, MS 12-29; Charlie Douglas, MS 12-33
Rita Gunia, Kelsey-Hayes Purchasing Dept., Fenton, Mi.
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

encl: ISIR Addendum For 12590701

TEXAS
INSTRUMENTS

cc = Elaine R.
FYE/TE



November 15, 1991

Kelsey-Hayes Company
9475 Center Road
Fenton, Michigan 48430

Attn: Ms. Rita Gunia
Purchasing Department

Subj: Part Number 12604301 Switch (E7SC-3N824-AA)
Part Number 12590701 Switch (F2VC-9F924-AB)
ISIR Submissions

STEF-3
TIE-12-1

Dear Rita,


Enclosed, please find the ISIR for the 12604301 and 12590701 switches. Both ISIR submissions were accomplished on Ford forms as we are in the process of transferring data to Kelsey-Hayes forms.

The 12590701 submission has several dimensional issues on the layout that are being addressed.

The 12604301 submission needs dimensional layout, control plan, manufacturing flow diagram, PIST, PIPC, and PV testing that are being addressed.

Please let me know if you have any questions or if I may be of any further assistance.

Regards,


Jim Watt
CRA Engineer
Precision Controls Department
Control Products Division

cc: Dave Czern, MS 12-29; Gary Snyder, MS 12-33
Charlie Douglas, MS 12-33
Andy McGuirk, MS 12-27
Steve Majors, TI Farmington Hills, Michigan

encl: ISIR submissions

WARRANT

TI-NHTSA 003497

FAI/PRINT

TI-NHTSA 003498



KELSEY-HAYES ENGINEERING CHANGE NOTICE

PROD. AREA: VALVES	SUBJECT: FN-10 PRESSURE SWITCH	PROGRAM: DUAL PROP	MODEL YEAR: 83	CUSTOMER(S): FORD	ECN NO.: 25136
NATURE OF CHANGE: AVAILABLE.				EPA NO.: 48011-B REF. DOCUMENTS: CUST. CHG.: K-H DEV./MCR: K-H EST.: K-H NTR: ATTACHMENTS: DISTRIBUTION CODE:	
NOTE: THIS IS A CHANGE TO CUSTOMER DRAWING.				CLASSIFICATION: REGULAR ☒ RECORD ☐ MANDATORY ☐ EXPEDITED ☐	
REASON: CUSTOMER REQUEST ☒ PLANT REQUEST ☐ VENDOR/PURCHASING REQUEST ☐ T.I. NOW HAS THEIR AUTOMATED ASSY GOING. - NEED TO UPDATE PRINTS SO ISIR WILL REFLECT PRODUCTION LEVEL SWITCH. RS TEST WILL BE PERFORMED ON ENTIRE VALVE FOR ISIR TO FORD.				VEHICLE APPLICATION: PASSENGER ☒ TRUCK ☐ TRAILER ☐ SERVICE ☐	
IS TEST REQUIRED: YES ☒ NO ☐ CONCURRENT ☐ TEST DURATION, DAYS:				INITIATED BY: J. COSSINS 8-2 DATE: 9-5-91	
APPROVED BY: PRODUCT ENGINEERING				DATE	
RESP ENGINEER	J.M. COSSINS	8-2-91	DATE	DATE	
MATERIALS	NH		SALES	D. CLINE/CD	8-20-91
MANAGER	G.A. WILLI	8-2-91	CUST AUTHORIZATION	YES ☐ N R ☐	8-13-91
CHIEF ENGINEER	C. DOWDING	8-2-91	COST RECOVERABLE?	YES ☐ NO ☐	8-20-91
(SEE ENGINEERING MANUAL SECTION 2.81) AFFECTED DESIGN DATA BANK: REVIEWED? YES ☐ NO ☐				SERVICE MANUAL REVIEWED? NO FMEA REVIEWED? YES ☐ NO ☐	
DELETE	REPLACE	RELEASE	CHANGE	CHG. LEVEL	STOCK DISPOSITION
			D-12590701	45	NO STK
			O-12603101	8	NO STK
			D-12603101	8	NO STK
			D-12603401	8	NO STK
			P-12603401	8	NO STK
			O-12603101	8	NO STK
ASSY - PRESSURE SWITCH - REVISE TO T.I. PRINT 77PSL-1 WAS TO 57PSL5-3. NOTE THE ONLY VISIBLE CHANGE IS THE OVERALL LENGTH ON SWITCH. SO SPECIFIC CHANGES ARE: 1) CHANGE TO "57-15 MAX" WAS "62-23 MAX" 2) CHANGE TO "P2VC-9P92-AA" WAS "P2VC-9P924-BA" 3) CHANGE T.I. P/N TO "77B-1" WAS "57PSL5-3" 4) REMOVE "FOR FINAL ASSY SEE DWG. 12575501" ASSY 'S - FN-10 DUAL PROP REFLECT ABOVE CHANGES ON THESE DRAWINGS AND PARTS LIST				CO-OR CHG. PART X 1 NO STK	
APPROVED					
PLANT(S) INVOLVED: AUG 20 1991				ECN NO. 25136	
COMPLETE ATTACHED COST SHEET, COST/LEAD ETC. INFO. RELATING TO DEPARTMENTS CONCERNED					

TI-NHTSA 003499

TEXAS INSTRUMENTS



DIMENSIONAL ANALYSIS ON PART NUMBER

F2VC-9F924-AB/12598701

	BLUEPRINT SPEC	CAVITY # 1B ACTUAL	CAVITY # 2C ACTUAL	CAVITY # 3C ACTUAL	CAVITY # 4D ACTUAL	CAVITY # 5D ACTUAL	CAVITY # 6D ACTUAL	COMMENTS
1	2.94 - 3.05	2.93	2.92	2.92	2.92	2.93	2.93	
	0.15	0.041	0.020	0.033	0.031	0.015	0.013	
	1.90	1.839	1.920	1.936	1.869	1.885	1.887	
2	22.86 MAX	18.64	18.57	18.54	18.60	18.63	18.61	
		18.56	18.66	18.66	18.77	18.71	18.67	
3	37.15 MAX	35.63	35.70	35.71	35.70	35.69	35.68	
4	9.66 - 9.39	9.39	9.61	9.57	9.49	9.58	9.55	
5	2.04-1.52 ref	2.040	1.732	1.783	1.727	1.781	1.796	
6	8.03-7.82ref	7.94	7.94	7.97	7.97	7.98	7.96	
		7.50		7.99				
7	10.25030-40 DEB	CAMFER	N/A -	THREADS	HAVE BEEN	ADDED		
8	9/8-24UNF-2A	OK	OK	OK	OK	OK	OK	
	1718, -D-							
9	1.40 - 1.10	1.316	MEASURED	ON A CROSS	SECTIONED	PART		

TEXAS INSTRUMENTS INCORPORATED • 34 FOREST STREET • AUSTIN, TEXAS 78701
 512-835-8000 • TELEEX 85-7700 TWX 710-846-0886 • CABLE TEXINS

TI-NHT5A 003500

TEXAS INSTRUMENTS



DIMENSIONAL ANALYSIS ON PART NUMBER

F2VC-9F924-AB/12590701

	BLUEPRINT SPEC	CAVITY # 1B ACTUAL	CAVITY # 2C ACTUAL	CAVITY # 3C ACTUAL	CAVITY # 4D ACTUAL	CAVITY # 5D ACTUAL	CAVITY # 6D ACTUAL	COMMENTS
1	2.84 - 3.05	2.93	2.92	2.92	2.92	2.93	2.93	
	⊕ 0.1 ⊖ A	0.041	0.020	0.033	0.031	0.015	0.013	
	<u>1.90</u>	1.859	1.920	1.933	1.869	1.885	1.887	
2	22.88 MAX	18.64	18.57	18.54	18.60	18.63	18.61	
		18.56	18.66	18.66	18.77	18.71	18.67	
3	57.15 MAX	55.65	55.70	55.71	55.70	55.69	55.68	
4	9.66 - 9.39	9.59	9.61	9.57	9.49	9.58	9.55	
								<i>Deleted</i>
5	2.04-1.52 ref1	2.040	1.732	1.703	1.727	1.781	1.796	<i>PER J. WAH</i>
6	8.01-7.82ref1	7.94	7.94	7.97	7.97	7.98	7.96	<i>1-9-93</i>
		7.56		7.99				
7	10.25X50-40 DEG CHAMFER	N/A	N/A	THREADS	HAVE BEEN	ADDED		
8	3/8-24UNF-2A	OK	OK	OK	OK	OK	OK	
	1THD. <u>D</u>							
9	1.40 - 1.10	1.316	MEASURED	ON A CROSS	SECTIONED	PART		

TEXAS INSTRUMENTS INCORPORATED • 34 FOREST STREET • ATTLEBORO, MA 02703
508-359-3808 • TELEX 98-7728 TWX 710-348-0568 • CABLE TEXINS

TI-NHTSA 003501

TEXAS INSTRUMENTS



DIMENSIONAL ANALYSIS ON PART NUMBER

F2YC-9F924-AB/12590701

	BLUEPRINT SPEC	CAVITY # 1B ACTUAL	CAVITY # 2C ACTUAL	CAVITY # 3C ACTUAL	CAVITY # 4D ACTUAL	CAVITY # 5D ACTUAL	CAVITY # 6D ACTUAL	COMMENTS
1	2.84 - 3.05	2.93	2.92	2.92	2.92	2.93	2.93	
	⊕ 0.1 ⊖ A	0.041	0.029	0.033	0.031	0.015	0.013	
	1.90	1.859	1.920	1.933	1.869	1.885	1.887	
2	22.00 MAX	18.64	18.57	18.54	18.68	18.63	18.61	
		18.56	18.66	18.66	18.77	18.71	18.67	
3	57.15 MAX	55.65	55.70	55.71	55.78	55.69	55.68	
4	9.66 - 9.39	9.59	9.61	9.57	9.49	9.58	9.55	
		9.63	9.66	9.64	9.62	9.74	9.67	OUT OF SPEC.
5	2.04-1.52 ref	2.040	1.732	1.783	1.727	1.781	1.796	
6	1/8 0.03-7.02ref	7.94	7.94	7.97	7.97	7.98	7.96	
		7.58		7.99				
7	10.25X50-40 DEG CHAMFER		N/A -	THREADS	HAVE BEEN	ADDED		
8	3/8-24UNF-2A	OK	OK	OK	OK	OK	OK	
	1TH. -0-							
9	1.40 - 1.10	1.316	MEASURED	ON A CROSS	SECTIONED	PART		

TEXAS INSTRUMENTS INCORPORATED - 34 FOREST STREET - ATTLEBORO, MA 02703
608-699-5000 • TELEK 88-7700 TWX 710-948-6666 • CABLE TEXINS

TI-NHTSA 003502

FZWC-9F924-AM/12590741

	BLUEPRINT SPEC	CAVITY # 1B ACTUAL	CAVITY # 2C ACTUAL	CAVITY # 3C ACTUAL	CAVITY # 4D ACTUAL	CAVITY # 5B ACTUAL	CAVITY # 6B ACTUAL	COMMENTS
10	2.10-2.12	2.08	2.10	2.10	2.08	2.08	2.08	
11	2.25	ON -	MEASURED	ON A CROSS	SECTIONED	PART		
12	43DEG-41DEG	41DEG 21MIN	MEASURED	ON A CROSS	SECTIONED	PART		
13	60DEG-25DEG	N/A -	THREADS	HAVE BEEN	ADDED			
14	3.60-3.30	3.45	3.45	3.43	3.45	3.44	3.45	
		3.46	3.43	3.42	3.46	3.47	3.45	
15	7.37-7.23	7.27	7.35	7.33	7.31	7.32	7.37	
		7.28	7.32	7.33	7.37	7.30	7.37	
16	5.05-5.50	5.61	5.72	5.64	5.67	5.60	5.61	
		5.68	5.68	5.66	5.70	5.66	5.63	

Technical drawing of a mechanical part, likely a valve or actuator, showing a side view and a cross-sectional view labeled "VIEW X".

Side View Dimensions:

- Overall length: 57.15 MAX
- Top diameter: 22.88 MAX
- Internal diameter: 8.03 REF
- Thread specification: 3/8-24 UNF-2A THD
- Chamfer: 0.25 X 50° X 40°
- Other dimensions: 9.66, 9.39, 2.04, 1.52, 1.40, 1.10, 2.5/C, 0.16 D, 8.85, 5.58, 7.37, 7.23, 60°, 26°

Cross-sectional View (VIEW X):

- Internal diameter: 8.03 REF
- Internal feature: 0.90

44 45 ▽ CONTROL ITEM - THE ▽ SYMBOL ALSO IDENTIFIES PRODUCT ENGINEERING DESIGNATED CRITICAL CHARACTERISTICS. THESE, AND ADDITIONAL CRITICAL CHARACTERISTICS IDENTIFIED BY PROCESS CONTROL REVIEWS, MUST APPEAR ON THE D-101 CONTROL PLAN(S) WHICH REQUIRE PRODUCT ENGINEERING APPROVAL.

SPECIFICATION:

DEVICE MUST CONFORM TO FORD MOTOR CO.

SPEC NO. ES-F2VC-9F924-A

ACTUATION PRESSURE---- 862 ±241 kPag (125 ±35 psig).

RELEASE PRESSURE----- 138 kPa_g MIN. (20 psi_g)

		A5	ADDED CONTROL ITEM BLOCK	9-8-91	CS	JT
		A6	REMOVED THE ITEM. ADD IN...	9-8-91	CS	JT
		A3	WAS SUPPLS-3	9-8-91	CS	JT
		A8	WAS F2WC-WF264-8A	9-8-91	CS	JT
8438	85136	A1	WAS 82.39 WAS DDM	9-8-91	CS	JT
8436	301		RELEASED	1-11-91		
EP/LWR	CRG/CH	CH	REVISION		DATE	DR. CK
UNLESS OTHERWISE SPECIFIED		MATERIAL / FINISH				
PART TOLERANCES						
1	SEE PLAN SYMBOL					
2	SEE PLAN SYMBOL					
3	CONTINUE					
4	MATERIAL					
SEE DIM. INTERPRETATION SPED. P.S. SYMBOL		 3RD ANGLE PROJECTION				
SCALE 2 X SIZE						
SEE DIM. PART						
PART DESCRIPTION						
METRIC		ASSY-PRESSURE SWITCH				
OR R. MEMORITARY	DATE 12-15-90			EAC DRAWING FOR ISO 9001 IS ELECTRONIC		
OR R. MEMORANDUM	DATE 1-3-91	NO MANUAL CHANGE				
DESIGN						
APPROVED BY	DATE	REVISION	REVISION	REVISION	REVISION	REVISION
ONE J. JOHNSON	1-11-91					
WTL						
WTC J. GALT	1-11-91	PART NUMBER		DRAWING		
DES. WTL S.A. TULLY	1-11-91	BASE NUMBER		SUFFIX		
		0-259070		LEVEL		

**DRAWINGS AVAILABLE UPON
REQUEST**

TEXAS INSTRUMENTS



DIMENSIONAL ANALYSIS ON PART NUMBER

F2YC-9F924-AN/12590781

	BLUEPRINT SPEC	CAVITY # 1B ACTUAL	CAVITY # 2C ACTUAL	CAVITY # 3C ACTUAL	CAVITY # 4D ACTUAL	CAVITY # 5B ACTUAL	CAVITY # 6D ACTUAL	COMMENTS
1	2.84 - 1.85	2.93	2.92	2.92	2.92	2.93	2.93	
	⊕ 0.1 ⊕ Δ	0.041	0.020	0.033	0.031	0.015	0.013	
2	1.91	1.859	1.920	1.933	1.869	1.885	1.867	
2	22.88 MAX	18.64	18.57	18.54	18.68	18.63	18.61	
		18.56	18.66	18.66	18.77	18.71	18.67	
3	57.15 MAX	55.65	55.70	55.71	55.78	55.69	55.68	
4	9.66 - 9.39	9.59	9.61	9.57	9.49	9.58	9.55	
		9.63	9.66	9.64	9.62	9.74	9.67	OUT OF SPEC.
5	2.84-1.52 ref	2.848	1.732	1.783	1.727	1.781	1.796	
6	7.83-7.82ref	7.94	7.94	7.97	7.97	7.98	7.96	
		7.98		7.99				
7	19.15X50-40 REG CHAMFER	N/A	-	THREADS	HAVE BEEN	ADDED		
8	3/8-24UNF-2A	OK	OK	OK	OK	OK	OK	
	ITH. 0.0							
9	1.48 - 1.18	1.316	MEASURED	ON A CROSS	SECTIONED	PART		

TEXAS INSTRUMENTS INCORPORATED • 54 FOREST STREET • ATTLEBORO, MA 01901
508-498-8800 • TELEX 90-7708 TWX 710-848-0880 • CABLE TEXINS

TI-NHTBA 003506

**TEXAS
INSTRUMENTS**



DIMENSIONAL ANALYSIS ON PART NUMBER

F24C-9F924-AB/12590701

	BLUEPRINT SPEC	CAVITY # 10 ACTUAL	CAVITY # 20 ACTUAL	CAVITY # 30 ACTUAL	CAVITY # 40 ACTUAL	CAVITY # 50 ACTUAL	CAVITY # 60 ACTUAL	COMMENTS
10	2.57	2.57	2.57	2.57	2.57	2.57	2.57	
11	2.57	OK -	MEASURED	ON A CROSS	SECTIONED	PART		
12	43DEG-41DEG	41DEG 21RIN	MEASURED	ON A CROSS	SECTIONED	PART		
13	60DEG-25DEG	N/A -	THREADS	HAVE BEEN	ADDED			
14	3.64-3.30	3.45	3.45	3.43	3.45	3.44	3.45	
		3.46	3.43	3.42	3.46	3.47	3.45	
15	7.37-7.23	7.27	7.35	7.33	7.31	7.32	7.37	
		7.28	7.32	7.33	7.37	7.38	7.37	
16	5.85-5.58	5.61	5.72	5.64	5.67	5.68	5.61	
		5.68	5.68	5.66	5.70	5.66	5.63	

TEKAM INSTRUMENTS INCORPORATED • 84 FOREST STREET • ATTLEBORO, MA 02703
800-555-2800 • TEL: 617-770-1100 FAX: 719-844-0099 • CABLE: TELSONS

TL-NHTSA 003607

**DRAWINGS AVAILABLE UPON
REQUEST**

KYN

KELREY-HAYES ENGINEERING CHANGE NOTICE

PROD. AREA: VALVES	SUBJECT: FN-10 PRESSURE SWITCH	PROGRAM: DUAL PROP	MODEL YEAR: 93	CUSTOMER(S): FORD	ECN NO.: 25136
NATURE OF CHANGE: REVISE THE T.I. PRESSURE SWITCH - NEW AUTOMATED VERSION IS AVAILABLE.				EPA NO.: 48011-B	CLASSIFICATION: REGULAR ☒ RECORD ☐ MANDATORY ☐ EXPEDITED ☐
NOTE: THIS IS A CHANGE TO CUSTOMER DRAWING.				CUST. CHG.: K-H DEV. / MCR. K-H EST. K-H MTR. ATTACHMENTS. DISTRIBUTION CODE.	VEHICLE APPLICATION: PASSENGER ☒ TRUCK ☐ TRAILER ☐ SERVICE ☐
REASON: CUSTOMER REQUEST ☒ PLANT REQUEST ☐ VENDOR/PURCHASING REQUEST ☐ T.I. NOW HAS THEIR AUTOMATED ASSY GOING. - NEED TO UPDATE PRINTS SO ISIR WILL REFLECT PRODUCTION LEVEL SWITCH. KR TEST WILL BE PERFORMED ON ENTIRE VALVE FOR ISIR TO FORD.				INITIATED BY: J. COSSINS 8-2 DATE: 9-5-91	
IS TEST REQUIRED: YES ☒ NO ☐ CONCURRENT ☐ TEST DURATION, DAYS: 30				APPROVED BY: J. COSSINS 8-2 DATE: 9-5-91	
PRODUCT ENGINEERING		DATE	DATE		DATE
RESP ENGINEER	J.M. COSSINS	8-2-91	D A	T. PRYOR/LV	8-20-91
MATERIALS	NR		SALES	D. CLINE/CD	8-8-91
MANAGER	G.A. WELLI	8-2-91	CUST AUTHORIZATION	YES ☐ NO ☐	8-11-91
DESG ENGINEER	G. DOWDING	8-2-91	COST RECOVERABLE?	YES ☐ NO ☐	8-20-91
(SEE ENGINEERING MANUAL SECTION 2.81)		SERVICE MANUAL REVIEWED? NO		SERVICE MANUAL REVISED? NO	
AFFECTED DESIGN DATA BANK: REVIEWED? YES		REVISOR? NO		FMEA REVIEWED? YES	
FMEA REVISED? NO		FMEA REVIEWED? YES		FMEA REVISED? NO	
DELETE	REPLACE	RELEASE	CHANGE	CHG. LEVEL	PART NAME / REVISION
			D-12590701	AS	ASSY - PRESSURE SWITCH - REVISE TO T.I. PRINT 77PSL2-1 WAS TO 57PSL5-3. NOTE THE ONLY VISIBLE CHANGE IS THE OVERALL LENGTH ON SWITCH. SO SPECIFIC CHANGES ARE: 1) CHANGE TO "57.15 MAX" WAS "62.23 MAX" 2) CHANGE TO "772VC-9P924-AA" WAS "72VC-9P924-BA" 3) CHANGE T.I. R/N TO "77PSL2-1" WAS "57PSL5-3" 4) REMOVE "FOR FINAL ASSY, SEE DWG. 12575501" ASSY 'S - FN-10 DUAL PROP - REFLECT ABOVE CHANGES ON THESE DRAWINGS AND PARTS LIST
			D-12603101	B	
			D-12603101	B	
			D-12603401	B	
			P-12603401	B	
			P-12603101	B	
APPROVED					CO-OR CHG. PART X STOCK DISPOSITION
					1 X NO STK
					1 NO STK
PLANT(S) INVOLVED: AUG 20 1991					ECN NO. 25136
COMPLETE ATTACHED COST SHEET, COST/LEAD ETC. INFO. RELATING TO DEPARTMENT'S CONTRIBUTION					

TINHT8A 003510

A1.0 B1002

FILE: 77PSLKH

TEXAS
INSTRUMENTS

ATTORNEYS: BARRISTER & BERN

PAGE ____ OF ____

SAMPLE REPORT

REASON FOR REPORT	VENDOR	P.O.	PART NO. <i>A/c</i>	REV.
NEW PART	REPORT REQ. BY	DATE	77PSL2-1	
REPLACEMENT TOOL.	<i>K-H</i>			DATE
CORRECTED TOOL.				12-16-91
REPAIRED TOOL.	THE DIMENSIONS INDICATED BELOW REPRESENT TEXAS INSTRUMENTS' FINDINGS REGARDING THE ACTUAL VALUES FOR ALL CHARACTERISTICS MEASURED. IN CASES WHERE ACTUAL VALUES DEVIATE FROM THE SPECIFIED DIMENSIONS, THE DISPOSITION MUST INDICATE THE REQUIRED ACTION FOR EACH NON-CONFORMANCE IN THE APPROPRIATE COLUMN.			
REVIEW				
OTHER				

		CIRCLE ALL OUT OF TOLERANCE DIMENSIONS						DISPOSITION	
	K-H	SPEC:	1B	2C	3C	4D	5D	6D	
5	1	2.24-3.08	2.93	2.92	2.92	2.92	2.93	2.93	
		⊕ 0.1 (5) A	0.041	0.022	0.033	0.031	0.015	0.013	
		[1.90]	1.859	1.920	1.933	1.869	1.885	1.887	
15	2	22.88 max	18.57	18.54	18.60	18.62	18.61	18.61	
			18.56	18.66	18.66	18.77	18.71	18.67	
16	3	57.15 max.	55.65	55.70	55.71	55.70	55.69	55.68	
17	4	9.66-9.39	9.59	9.61	9.57	9.49	9.58	9.55	
			9.63	9.66	9.64	9.62	9.74	9.67	out of Spec.
22	5	2.04-2.02 max	2.040	1.732	1.783	1.727	1.781	1.796	
23	6	8.02-7.82 max	7.94	7.94	7.97	7.97	7.98	7.96	
			7.50		7.99				
29	7	0.25 x 50°-40°	N/A - Threads Have Been Added						
		attempt							
30	8	3/8-24 UNF-2A	OK	OK	OK	OK	OK	OK	
		THD							
31	9	1.40-1.10	1.316	measured on a Cross Sectional Part					
32	10	0.16 D	0.051	0.048	0.008	0.008	0.030	0.056	
33	11		OK	measured on a Cross Sectional Part					
34	12	43°-41°	41°21'	"	"	"	"	"	
35	13	60°-25°	N/A - Threads Have Been Added						
38	14	3.60-3.30	3.45	3.45	3.43	3.45	3.44	3.45	
			3.46	3.43	3.42	3.46	3.47	3.45	
39	15	7.37-7.23	7.27	7.35	7.33	7.31	7.32	7.37	
			7.28	7.32	7.33	7.37	7.30	7.37	
40	16	5.85-5.58	5.61	5.72	5.64	5.67	5.60	5.61	
			5.68	5.68	5.66	5.70	5.66	5.63	

REMARKS AND/OR INSTRUCTIONS:

DISPOSITION: TOOL APPROVED FOR PROD.

REVISION REQ'D

SFG. ENG.:

GRA. ENG.:

TI-NHTSA 003511

DIMENSIONAL ANALYSIS ON PART NUMBER

F2WC-9F92A-AB/12590701

	BLUEPRINT SPEC	CAVITY # 1B ACTUAL	CAVITY # 2C ACTUAL	CAVITY # 3C ACTUAL	CAVITY # 4D ACTUAL	CAVITY # 5B ACTUAL	CAVITY # 6D ACTUAL	CAVITY # 7C ACTUAL
1	2.84 - 3.05	2.93	2.92	2.92	2.92	2.93	2.93	
	D 0.1 ± 0.01	0.041	0.020	0.033	0.031	0.019	0.019	
	1.90	1.859	1.920	1.938	1.869	1.885	1.887	
2	22.88 MAX	18.64	18.57	18.54	18.60	18.63	18.61	
		18.54	18.66	18.66	18.77	18.71	18.67	
3	57.15 MAX	55.65	55.70	55.71	55.70	55.69	55.68	
4	9.66 - 9.39	9.59	9.61	9.57	9.49	9.58	9.55	
		9.63	9.66	9.64	9.62	9.74	9.67	OUT OF SPEC.
5	2.04-1.52 ref	2.046	1.732	1.789	1.727	1.781	1.796	
6	10 8.03-7.82 ref	7.94	7.94	7.97	7.97	7.98	7.96	
		7.98		7.99				
7	10.25035-10 THIN CHAMFER	N/A	N/A	THINNESS	HAVE BEEN	ADDED		
8	3/16-24 UNF-2B	OK	OK	OK	OK	OK	OK	
9	1.40 - 1.10	1.816	MEASURED	ON A CROSS	SECTIONED	PART		

TI-NHTSA 003512

F2NC-9F92H-A0/12590701

TI-NHTSA 003613

TEXAS INSTRUMENTS



DIMENSIONAL ANALYSIS ON PART NUMBER

F2UC-9F924-40

	BLUEPRINT SPEC	CAVITY # 10 ACTUAL	CAVITY # 20 ACTUAL	CAVITY # 30 ACTUAL	CAVITY # 40 ACTUAL	CAVITY # 50 ACTUAL	CAVITY # 60 ACTUAL	COMMENTS
1	19.45 - 19.61	19.55	19.61	19.58	19.56	19.57	19.57	
2	16.56 - 16.76	16.59/16.58	16.62/16.64	16.62/16.63	16.58/16.59	16.54/16.56	16.59/16.59	
3	11.93 - 12.21	12.974	13.051	13.035	13.043	13.078	12.946	
4	11.40 - 11.90	11.758	11.808	11.775	11.773	11.756	11.755	
5	2.84 - 3.05	2.93	2.92	2.92	2.92	2.93	2.93	
	0.1 A	1.859/0.041	1.920/0.020	1.933/0.033	1.869/0.031	1.885/0.015	1.867/0.013	
6	11.60 - 11.92	11.69/11.71	11.67/11.71	11.72/11.68	11.60/11.63	11.63/11.67	11.65/11.65	
7	1.24 - 1.45	1.252	1.250	1.280	1.280	1.290	1.265	
8	1.24 - 1.35	1.402	1.397	1.400	1.389	1.397	1.397	
9	1.85 - 2.06	2.004	1.974	1.996	1.984	1.994	1.986	
10	13.43 - 13.85	13.772	13.693	13.800	13.686	13.686	13.556	
11	VALUES +/- 2000 3000 34MIN 2900 33MIN 3100 2900 04MIN 2900 03MIN 3000 06MIN							
12	2.79 - 3.10 2X	2.90/2.89	2.90/2.90	2.90/2.90	2.90/2.90	2.89/2.89	2.90/2.94	
13	0.25 - 0.75	0.508/0.841	0.480/0.800	0.442/0.673	0.498/0.671	0.490/0.744	0.460/0.757	OUT OF SPEC.
14	0.05 - 0.26 2X	0.051/0.049	0.074/0.127	0.140/0.076	0.127/0.135	0.153/0.163	0.071/0.036	
		0.140/0.147	0.092/0.089	0.086/0.114	0.048/0.081	0.038/0.013	0.137/0.165	
15	0 19.05 MAX	18.64	18.56/18.57	18.66/18.54	18.66/18.60	18.77/18.63	18.71/18.61	18.67

TEXAS INSTRUMENTS INCORPORATED • 34 FOREST STREET • ATLENTA, GA 30303
404-555-5555 • TELE 404-7700 FAX 770-345-0000 • CABLE TEXINS

TI-NHT8A 003514

TEXAS INSTRUMENTS



DIMENSIONAL ANALYSIS ON PART NUMBER

F20C-9F924-AB

	BLUEPRINT SPEC	CAVITY # 18 ACTUAL	CAVITY # 20 ACTUAL	CAVITY # 30 ACTUAL	CAVITY # 40 ACTUAL	CAVITY # 50 ACTUAL	CAVITY # 60 ACTUAL	COMMENTS
16	57.15 MAX	55.65	55.70	55.71	55.70	55.69	55.68	
17	12.59 - 13.11	12.74/12.86	12.72/12.84	12.77/12.76	12.76/12.77	12.75/12.81	12.73/12.80	
18	11.65 - 12.17	11.68/11.79	11.85/11.64	11.73/11.79	11.88/11.84	11.78/11.86	11.73/11.88	
19	14.23 MAX	13.66	13.65	13.67	13.65	13.65	13.66	
20	9.39 - 9.66	9.59/9.63	9.61/9.66	9.57/9.64	9.49/9.62	9.58/9.74	9.55/9.67	OUT OF SPEC.
21	8.12 MIN	8.98/9.29	9.13/9.54	9.12/9.18	8.98/9.56	9.14/9.22	9.11/9.14	
22	1.52 - 2.04	2.040	1.732	1.789	1.727	1.781	1.796	
23	7.82-8.03	7.94/7.50	7.94	7.97/7.99	7.97	7.96	7.96	
24	6.64 - 6.81	6.640	6.698	6.693	6.647	6.665	6.642	
24A	29DEB+/ -20B 4Y	29DEB 54MIN	30DEB 24MIN	MEASURED	ON A CROSS	SECTIONED	PART	
		30DEB 57MIN	28DEB 44MIN					
25	1.80-2.21R 21	1.84-1.84	1.84-1.84	1.84-1.84	1.84-1.84	1.84-1.84	1.84-1.84	
26	7.23-7.75	7.74	7.52	7.53	7.54	7.55	7.53	
26A	NO FLASH OR	OK	OK	FLASH	OK	OK	FLASH	
	BURR ALLOWED							
	ON SURFACE							
27	2.79-3.41	3.145	3.099	3.160	3.150	3.119	3.107	
28	0.68-1.30	1.115	1.168	1.179	1.148	1.161	1.153	

TEXAS INSTRUMENTS INCORPORATED • 34 FOREST STREET • ARLINGTON, MA 02109

800-828-8800 • TELEX 88-7708 TWX 710-846-0668 • CABLE TEXINS

TI-NHT8A 003515

TEXAS INSTRUMENTS



DIMENSIONAL ANALYSIS ON PART NUMBER

F2UC-9F924-A0

	BLUEPRINT SPEC	CAVITY # 19 ACTUAL	CAVITY # 20 ACTUAL	CAVITY # 30 ACTUAL	CAVITY # 40 ACTUAL	CAVITY # 50 ACTUAL	CAVITY # 60 ACTUAL	COMMENTS
28A	STAMP DATE	INVERTED	DELTA	OMITTED.	HAS SINCE	BEEN	INCLUDED	
	CODE & PART#	IN CODING	OPERATION.					
29	10.25MIN X 40 -	N/A THREADS	HAVE BEEN	ADDED				
	50DEG CHAMFER							
30	3/8-24UNF-2A	OK	OK	OK	OK	OK	OK	
31	1.10-1.40	1.316	MEASURED	ON A CROSS	SECTIONED	PART		
32	0.16 D	0.051	0.048	0.048	0.008	0.030	0.056	
33	2.5 c	OK	MEASURED	ON A CROSS	SECTIONED	PART		
34	41DEG - 43DEG	41DEG 21MIN	MEASURED	ON A CROSS	SECTIONED	PART		
35	140-50DEG CHAMF	N/A THREADS	HAVE BEEN	ADDED				
36	32.51 MAX	31.64 31.62	31.46 31.48	31.43 31.46	31.50 31.47	31.46 31.48	31.58 31.58	
37	14.02-14.53MAX	14.11	14.11	14.11/14.13	14.12/14.13	14.12/14.13	14.11/14.12	
38	3.30-3.60	3.45 - 3.46	3.45 - 3.43	3.43 - 3.42	3.45 - 3.46	3.44 - 3.47	3.45 - 3.45	
39	7.23-7.37	7.27 7.28	7.35 7.32	7.33 7.33	7.31 7.37	7.32 7.30	7.37 7.37	
40	5.58-5.85	5.61 5.68	5.72-5.68	5.64-5.66	5.67-5.70	5.60-5.66	5.61-5.63	
41	171.50ES +/-	172DEG 30MIN	172DEG 11MIN	172DEG 12MIN	172DEG 24MIN	171DEG 56MIN	172DEG 10MIN	
	2065 21	172DEG 30MIN	172DEG 14MIN	172DEG 50MIN	172DEG 37MIN	172DEG 11MIN	172DEG 36MIN	

TEXAS INSTRUMENTS INCORPORATED • 54 FOREST STREET • ATTLEBORO, MA 01901

808-488-9888 • TELEX 98-4788 TWX 710-848-8888 • CABLE TEXINS

TI-NHT8A 003516

TEXAS INSTRUMENTS



DIMENSIONAL ANALYSIS ON PART NUMBER

F24C-9F924-AD

	BLUEPRINT SPEC	CAVITY # 18 ACTUAL	CAVITY # 20 ACTUAL	CAVITY # 30 ACTUAL	CAVITY # 40 ACTUAL	CAVITY # 50 ACTUAL	CAVITY # 60 ACTUAL	COMMENTS
42	1.42-1.63 2X	1.62-1.62	1.63-1.63	1.58-1.63	1.63-1.60	1.60-1.59	1.60-1.57	
43	0.35-0.66 4X	1.64-0.65	0.57-0.59	0.57-0.60	0.58-0.58	0.38-0.57	0.57-0.59	
		0.57-0.59	0.59-0.55	0.58-0.57	0.59-0.56	0.56-0.55	0.55-0.54	
44	0.30-0.72 2X	0.43-0.46	0.51-0.44	0.41-0.44	0.42-0.42	0.59-0.43	0.42-0.56	
45	2.15-2.42 2X	2.13-2.21	2.18-2.22	2.20-2.15	2.20-2.16	2.16-2.18	2.23-2.16	01 OUT OF SPEC
46	25DEG +/- 2 2X	24DEG 36MIN	24DEG 41MIN	23DEG 14MIN	23DEG 39MIN	23DEG 09MIN	23DEG 34MIN	
		23DEG 04MIN	23DEG 45MIN	24DEG 31MIN	23DEG 53MIN	23DEG 58MIN	24DEG 24MIN	
47	HOLDING BROWN	BROWN	BROWN	BROWN	BROWN	BROWN	BROWN	
48	45DEG +/- 2 4X	44DEG 36MIN	44DEG 47MIN	44DEG 09MIN	45DEG 08MIN	45DEG 37MIN	43DEG	
		45DEG 46MIN	45DEG 15MIN	43DEG 20MIN	45DEG 04MIN	44DEG 11MIN	44DEG 09MIN	
		44DEG 43MIN	45DEG 46MIN	44DEG 46MIN	45DEG 16MIN	44DEG 07MIN	44DEG 01MIN	
		45DEG 12MIN	45DEG 23MIN	45DEG 39MIN	44DEG 48MIN	45DEG 34MIN	44DEG 34MIN	
49	0.96-1.17 4X	0.96-0.95	0.99-1.03	0.97-1.02	0.98-1.02	0.99-1.03	0.99-1.03	
		0.95-0.93	0.96-0.97	0.96-1.00	0.93-1.00	0.97-0.97	0.95-0.96	
50	0.35-0.66 4X	0.54-0.54	0.45-0.44	0.46-0.48	0.46-0.50	0.45-0.54	0.51-0.49	
		0.48-0.51	0.49-0.52	0.54-0.53	0.52-0.52	0.50-0.54	0.51-0.44	

TEXAS INSTRUMENTS INCORPORATED • 50 FOMEST STREET • AUSTIN, TEXAS 78768
512-835-8800 • TELETYPE 512-7788 TWX 710-645-0888 • CABLE TEXINS

TI-NHTBA 003517

**TEXAS
INSTRUMENTS**



DIMENSIONAL ANALYSIS ON PART NUMBER

FBI-9P924-00

[illegible]

TEDEA INSTRUMENTS INCORPORATED • 84 FOREST STREET • ATTLEBORO, MA 01945
508-252-2000 • TELEX 96-7706 TWX F3-266-2000 • CABLE WITHE

TI-NHTSA 003518

**DRAWINGS AVAILABLE UPON
REQUEST**

PIPC/PIST DATA

TI-NHTSA 003620

PROCESS POTENTIAL AND QUALITY INDEXES SUMMARY DATA SHEET

PART #: 72VC-9F92A-AB

SUPPLIER CONTACT: Jim Watt

SUPPLIER: Texas Instruments

CONTACT PHONE: 1-508-689-1719

CODE: 1097K

PART DESCRIPTION: Next Generation

ADDRESS: 34 Forank St.
Attleboro, MA 02703

Speed Control

SQA CODE: (Mark Schiller)

VEHICLE BUILD: EP VP FB OTHER

VEHICLE PROGRAM: PASS Car

CHARACTERISTIC TYPE

▽ = FORD CRITICAL
CHARACTERISTICS

S.C. = FORD OR SUPPLIER SIGNIFICANT
CHARACTERISTICS

NUMBER OF CRITICAL AND SIGNIFICANT CHARACTERISTICS:

1: <u>Activation Pressure</u>	TYPE: <u>SC</u>	Cp = <u>**</u>	Cpk = <u>**</u>
2: <u>Release Pressure</u>	TYPE: <u>SC</u>	Cp = <u>**</u>	Cpk = <u>**</u>
3: <u>3/8-24UNF-2A Thread</u>	TYPE: <u>SC</u>	Cp = <u>A*</u>	Cpk = <u>A*</u>
4: _____	TYPE: _____	Cp = _____	Cpk = _____
5: _____	TYPE: _____	Cp = _____	Cpk = _____
6: _____	TYPE: _____	Cp = _____	Cpk = _____
7: _____	TYPE: _____	Cp = _____	Cpk = _____
8: _____	TYPE: _____	Cp = _____	Cpk = _____
9: _____	TYPE: _____	Cp = _____	Cpk = _____
10: _____	TYPE: _____	Cp = _____	Cpk = _____
11: _____	TYPE: _____	Cp = _____	Cpk = _____
12: _____	TYPE: _____	Cp = _____	Cpk = _____
13: _____	TYPE: _____	Cp = _____	Cpk = _____
14: _____	TYPE: _____	Cp = _____	Cpk = _____
15: _____	TYPE: _____	Cp = _____	Cpk = _____

PIST = $\frac{1265}{1265} \times 100 = 100\%$

PIPC_{Cp} = $\frac{N/A}{N/A} \times 100 = \%$ PIPC_{Cpk} = $\frac{N/A}{N/A} \times 100 = \%$

COMMENTS:

** Calibration check is done 100 percent parts tested 300; defective 0 percent or defect U.

A* threads are checked on a Go/NoGo gage.

PREPARED BY:

Klaudia Boon

DATE: 12/20/91


**DRAWINGS AVAILABLE UPON
REQUEST**

**PROCESS FLOW
CONTROL CHART**

TI-NHTSA 003524

FORD NEXT GENERATION SPEED CONTROL

PROCESS FLOW CHART 77PSL2-1/2-3



MD 05/23/91

TI-NHTSA 003525

FORD NEXT GENERATION SPEED CONTROL (77PS) MANUFACTURING CONTROL PLAN

<u>PROCESS STEP DESCRIPTION</u>	<u>PRODUCT CHARACTERISTICS</u>	<u>EVALUATION METHOD</u>	<u>CONTROL METHOD</u>	<u>FREQUENCY OF TEST</u>	<u>REACTION PLAN</u>
BASE ASSEMBLY (AMI AUTOMATION)	TERMINAL HEIGHT	DIAL INDICATOR	X/R	5pc/Hr.	SORT SINCE LAST CHECK
	TERMINAL PUSHOUT	FORCE GAGE/ DIAL INDICATOR	X/R	5pc/Hr.	SORT SINCE LAST CHECK
	TERMINAL SEPERATION/ ALIGNMENT	PLUG GAGE	X/R	5pc/Hr.	SORT SINCE LAST CHECK
	SPRING CONTACT WIDTH	CALIPERS	X/R	5pc/Hr.	SORT SINCE LAST CHECK
	SPRING TORQUE	FORCE GAGE	X/R	5pc/Hr.	SORT SINCE LAST CHECK
	SPRING BUMP HEIGHT	DIAL INDICATOR	X/R	5pc/Hr.	SORT SINCE LAST CHECK
	RIVET HEIGHT	DIAL INDICATOR	X/R	5pc/Hr.	SORT SINCE LAST CHECK
	CALIBRATION DEFORMATION	CUSTOM CONTINUITY SYSTEM	X/R	5pc/Hr.	SORT SINCE LAST CHECK
	VISUAL QUALITY	VISUAL	X/R	5pc/Hr.	SORT SINCE LAST CHECK
SENSOR ASSEMBLY	CRIMP DIAMETER	CALIPERS	X/R	5pc/Hr.	SORT SINCE LAST CHECK
	CRIMP HEIGHT	CALIPERS	X/R	5pc/Hr.	SORT SINCE LAST CHECK
	VISUAL QUALITY	VISUAL	P	5pc/Hr.	SORT SINCE LAST CHECK

TI-NHTGA 003526

24 September 1991 MJB/cnr 050-0134

FORD NEXT GENERATION SPEED CONTROL (77PS) MANUFACTURING CONTROL PLAN

<u>PROCESS STEP DESCRIPTION</u>	<u>PRODUCT CHARACTERISTICS</u>	<u>EVALUATION METHOD</u>	<u>CONTROL METHOD</u>	<u>FREQUENCY OF TEST</u>	<u>REACTION PLAN</u>
FINAL ASSEMBLY (AMI AUTOMATION)	CRIMP DIAMETER	CALIPER	X/ R	5pc/ Hr.	SORT SINCE LAST CHECK
	CRIMP HEIGHT	CALIPER	X/ R	5pc/ Hr.	SORT SINCE LAST CHECK
	BASE TORQUE	TORQUE GAGE	X/ R	5pc/ Hr.	SORT SINCE LAST CHECK
FUNCTION TESTER (CUSTOM)	ACTUATION/ RELEASE POINTS	MASTERS	X/ R	EACH SHIFT	TOOL ROOM / ENGINEERING EVALUATIONS
	ACTUATION/ RELEASE POINTS	RAMP THROUGH PRESSURE RANGE	X/ R	100%	YIELD TRACKING/ SCRAP CONTROL
Q.C. AUDITS	FUNCTION TESTING DURABILITY TESTING ELEVATED TEMP TESTING ENVELOP DIMENSIONAL CHECKS				

77-NHT8A 003527

TI-NHTSA 003528

GM GAGE STUDY FOR REPEATABILITY AND REPRODUCIBILITY (LONG METHOD)

24-Sep-91

77PS PRESSURE TEST

SITUATION

NUMBER OF OPERATORS 3
NUMBER OF PARTS 4
NUMBER OF TRIALS 2

MIN SPEC 90
MAX SPEC 160
TOLERANCE 70

DATA SUMMARY

OPERATOR	AVERAGE	RANGE
1	114.7875	1.025
2	113.9375	0.775
3	113.025	0.45
4	NA	NA
5	NA	NA
6	NA	NA
7	NA	NA
8	NA	NA
9	NA	NA
10	NA	NA
AVERAGE	113.9166	0.75

MIN XBAR 113.025
MAX XBAR 114.7875
BARDIFF 1.7625

	MEASUREMENT UNIT ANALYSIS	%TOLERANCE
REPEATABILITY:	3.424202	4.89%
REPRODUCIBILITY:	4.595500	6.57%
RPT & REPR (R&R):	5.730949	8.19%

NOTE: ALL CALCULATIONS BASED ON 5.15 SIGMA (99%)

ENTER STUDY TITLES IN CELLS A8,A9,A10, MIN/MAX SPEC IN B12, B13
 87PS PRESSURE TEST
 ACTUATION

MIN SPEC 90
 MAX SPEC 160
 TOLERANCE 70

DATA FOR OPERATOR 1

PART	1	2	TRIAL 3	4	5	AVG	RANGE
1	120.8	121.6				121.2	0.8
2	123.8	123.5				123.65	0.3
3	107.9	106.4				107.15	1.5
4	107.9	106.4				107.15	1.5
5						NA	0
6						NA	0
7						NA	0
8						NA	0
9						NA	0
10						NA	0
11						NA	0
12						NA	0
13						NA	0
14						NA	0
15						NA	0
16						NA	0
17						NA	0
18						NA	0
19						NA	0
20						NA	0
21						NA	0
22						NA	0
23						NA	0
24						NA	0
25						NA	0

GRND AVG: 114.7875

AVG RANGE: 1.025

UCL FOR INDIVIDUAL RANGES

2.45025

TI-NHTSA 003530

DATA FOR OPERATOR 2

PART	1	2	TRIAL 3	4	5	AVG	RANGE
1	120.1	120.9				120.5	0.8
2	122.2	122.9				122.55	0.7
3	107	107.5				107.25	0.5
4	106	104.9				105.45	1.1
5						NA	0
6						NA	0
7						NA	0
8						NA	0
9						NA	0
10						NA	0
11						NA	0
12						NA	0
13						NA	0
14						NA	0
15						NA	0
16						NA	0
17						NA	0
18						NA	0
19						NA	0
20						NA	0
21						NA	0
22						NA	0
23						NA	0
24						NA	0
25						NA	0

GRND AVG: 113.9375

AVG RANGE: 0.775

UCL FOR INDIVIDUAL RANGES 2.45025

DATA FOR OPERATOR 3

PART	TRIAL					AVE	RANGE
	1	2	3	4	5		
1	121.9	123				122.45	1.1
2	118.1	117.8				117.95	0.3
3	107	106.8				106.9	0.2
4	104.9	104.7				104.8	0.2
5						NA	0
6						NA	0
7						NA	0
8						NA	0
9						NA	0
10						NA	0
11						NA	0
12						NA	0
13						NA	0
14						NA	0
15						NA	0
16						NA	0
17						NA	0
18						NA	0
19						NA	0
20						NA	0
21						NA	0
22						NA	0
23						NA	0
24						NA	0
25						NA	0

GRND AVG: 113.025

UCL FOR INDIVIDUAL RANGES

AVG RANGE:

2.45025

0.45

DM GAGE STUDY FOR REPEATABILITY AND REPRODUCIBILITY (LONG METHOD)

24-Sep-91

77PS PRESSURE TEST
RELEASE

NUMBER OF OPERATORS 3
NUMBER OF PARTS 4
NUMBER OF TRIALS 2

MIN SPEC 20
MAX SPEC 160
TOLERANCE 140

DATA SUMMARY

OPERATOR	AVERAGE	RANGE
1	47.725	0.4
2	46.4875	0.475
3	46.9625	0.425
4	NA	NA
5	NA	NA
6	NA	NA
7	NA	NA
8	NA	NA
9	NA	NA
10	NA	NA

AVERAGE 47.05833 0.43333

MIN XBAR 46.4875

MAX XBAR 47.725

STANDARD DIFF 1.2375

	MEASUREMENT UNIT ANALYSIS	%TOLERANCE
REPEATABILITY:	1.978427	1.41%
REPRODUCIBILITY:	3.262574	2.33%
RPT & REPR (R&R):	3.815569	2.73%

NOTE: ALL CALCULATIONS BASED ON 5.15 SIGMA (99%)

TI-NHT8A 003533

ENTER STUDY TITLES IN CELLS A8,A9,A10, MIN/MAX SPEC IN B12, B13
 77PS PRESSURE TEST
 RELEASE

MIN SPEC 20
 MAX SPEC 160
 TOLERANCE 140

DATA FOR OPERATOR 1

PART	TRIAL					AVG	RANGE
	1	2	3	4	5		
1	44.1	43.6				43.85	0.5
2	57.8	57.6				57.7	0.2
3	44	44.2				44.1	0.2
4	45.6	44.9				45.25	0.7
5						NA	0
6						NA	0
7						NA	0
8						NA	0
9						NA	0
10						NA	0
11						NA	0
12						NA	0
13						NA	0
14						NA	0
15						NA	0
16						NA	0
17						NA	0
18						NA	0
19						NA	0
20						NA	0
21						NA	0
22						NA	0
23						NA	0
24						NA	0
25						NA	0

GRND AVG: 47.725

UCL FOR INDIVIDUAL RANGES

AVG RANGE: 0.4

1.4157

TI-NHTSA 003534

DATA FOR OPERATOR 2

PART	TRIAL					AVG	RANGE
	1	2	3	4	5		
1	43.4	43.7				43.55	0.3
2	56	54.9				55.45	1.1
3	43.1	42.9				43	0.2
4	44.1	43.8				43.95	0.3
5						NA	0
6						NA	0
7						NA	0
8						NA	0
9						NA	0
10						NA	0
11						NA	0
12						NA	0
13						NA	0
14						NA	0
15						NA	0
16						NA	0
17						NA	0
18						NA	0
19						NA	0
20						NA	0
21						NA	0
22						NA	0
23						NA	0
24						NA	0
25						NA	0

GRND AVG: 46.4875

AVG RANGE: 0.475

UCL FOR INDIVIDUAL RANGES

1.4157

DATA FOR OPERATOR 3

PART	1	2	TRIAL	3	4	5	AVG	RANGE
1	43.2	43					43.1	0.2
2	58	57.1					57.55	0.9
3	43.6	43.1					43.35	0.5
4	43.8	43.9					43.85	0.1
5							NA	0
6							NA	0
7							NA	0
8							NA	0
9							NA	0
10							NA	0
11							NA	0
12							NA	0
13							NA	0
14							NA	0
15							NA	0
16							NA	0
17							NA	0
18							NA	0
19							NA	0
20							NA	0
21							NA	0
22							NA	0
23							NA	0
24							NA	0
25							NA	0

GRND AVG: 46.9625

AVG RANGE: 0.425

UCL FOR INDIVIDUAL RANGES

1.4137

TI-NHTSA 003536

GM GAGE STUDY FOR REPEATABILITY AND REPRODUCIBILITY (LONG METHOD)

24-Sep-91

DIAL INDICATOR #14508

MOVEABLE TERMINAL

NUMBER OF OPERATORS	2	MIN SPEC	0.459
NUMBER OF PARTS	10	MAX SPEC	0.479
NUMBER OF TRIALS	2	TOLERANCE	0.2

DATA SUMMARY

OPERATOR	AVERAGE	RANGE
1	0.46925	0.0003
2	0.46925	0.0003
3	NA	NA
4	NA	NA
5	NA	NA
6	NA	NA
7	NA	NA
8	NA	NA
9	NA	NA
10	NA	NA
AVERAGE	0.46925	0.0003

MIN XBAR	0.46925
MAX XBAR	0.46925
STANDARD DIFF	0

	MEASUREMENT UNIT ANALYSIS	%TOLERANCE
REPEATABILITY:	0.001369	0.68%
REPRODUCIBILITY:	0	0.00%
RPT & REPR (R&R):	0.001369	0.68%

NOTE: ALL CALCULATIONS BASED ON 5.15 SIGMA (99%)

*Note: Same fixturing / dial indicator
used for Stationary Terminal.*

ENTER STUDY TITLES IN CELLS A8,A9,A10, MIN/MAX SPEC IN B12, B13

DIAL INDICATOR #14508

MOVABLE TERMINAL

MIN SPEC 0.459
MAX SPEC 0.479
TOLERANCE 0.2

DATA FOR OPERATOR 1

PART	TRIAL					AVD	RANGE
	1	2	3	4	5		
1	0.468	0.469				0.4685	0.001
2	0.468	0.468				0.468	0
3	0.469	0.469				0.469	0
4	0.469	0.469				0.469	0
5	0.47	0.47				0.47	0
6	0.469	0.47				0.4695	0.001
7	0.47	0.47				0.47	0
8	0.469	0.469				0.469	0
9	0.47	0.471				0.4705	0.001
10	0.469	0.469				0.469	0
11						NA	0
12						NA	0
13						NA	0
14						NA	0
15						NA	0
16						NA	0
17						NA	0
18						NA	0
19						NA	0
20						NA	0
21						NA	0
22						NA	0
23						NA	0
24						NA	0
25						NA	0

GRND AVG: 0.46925 AVG RND: 0.0003
UCL FOR INDIVIDUAL RANGES 0.000980

TI-NHTSA 003538

DATA FOR OPERATOR 2

PART	TRIAL					AVG	RANGE
	1	2	3	4	5		
1	0.469	0.469				0.469	0
2	0.467	0.468				0.4675	0.001
3	0.469	0.469				0.469	0
4	0.469	0.469				0.469	0
5	0.47	0.469				0.4695	0.001
6	0.469	0.469				0.469	0
7	0.47	0.47				0.47	0
8	0.469	0.47				0.4695	0.001
9	0.471	0.471				0.471	0
10	0.469	0.469				0.469	0
11						NA	0
12						NA	0
13						NA	0
14						NA	0
15						NA	0
16						NA	0
17						NA	0
18						NA	0
19						NA	0
20						NA	0
21						NA	0
22						NA	0
23						NA	0
24						NA	0
25						NA	0

GRND AVG: 0.46925

AVG RANGE: 0.0003

UCL FOR INDIVIDUAL RANGES 0.000980

TI-NHT8A 003539

**MATERIAL
ANALYSIS**

TI-NHT9A 003540

TEXAS
INSTRUMENTS

CERTIFICATION OF COMPLIANCE TEST

CUSTOMER: Kelsey Hays

CUSTOMER ORDER NO.:


TI ORDER NO.:

12590701
CUSTOMER PART NO.:77P5L2-1
TI PART NO.:CUSTOMER SPEC: F2VC-9F924-AB TI SR: _____

QUANTITY: _____ DATE SHIPPED: _____

IT IS HEREBY CERTIFIED THAT THE GOODS SPECIFIED ABOVE CONFORM TO THE
TI ORDER SHOWN ABOVE, AS REVISED BY MUTUALLY AGREED WRITTEN AMENDMENTS,
IF ANY. Further, component parts utilized have been scrutinized
and do not violate Ford Engineering Materials Specifications
WSS-M99P9999-A1/A2/A3 restrictions.

[Signature]
PRECISION CONTROLS QUALITY CONTROLDATED: 01/6/93



(o)perator (p)lot overlay (e)very n (l)imits (z)ones (q)uit

TI-NHT8A 003642

Histogram

77L21ACT

140

f 120

r 100

e 80

q 60

u 40

e 20

n

c

y

20

90.00

104

118

132

146

160

MASTERS ACTUATION

93/01/04 12:09:06

(d)ivisions (l)ast n (c)-index (q)uit

TI-NHTSA 003643

Histogram

77L21REL

175

f 150

r

e 125

q

u 100

e

n 75

c

y 50

25

20.00

40.00

60.00

80.00


100

120

MASTERS RELEASE

93/01/04 12:10:25

(d)ivisions (l)ast n (c)-index (q)uit



THNHTSA 003545

(o)perator (p)lot overlay (e)very n (l)imits (z)ones (q)uit

1-6-93

7742-1

Base 46915-2 Rex Botalho
Starter 36888-1 N/A
Vane Comb 74408-1 ✓
Rings 74401-1 (74416-1) ✓
Washer 27639-1 ✓
Spring 36889-1 N/A
Spring 27716-1 ✓
Hosepart 36900-1 ✓
Gasket 74353-1 ✓
Cup 27713-1 ✓ -1 of 2
Seal 74176-1 ✓
Krypton Strip 27225-1 ✓
Washer 27639-1 ✓
Converter 27406-1 ✓
Spacer 28958-1 ✓
Krypton 74404-1 ✓
CR 74407-1 ✓
TI 74407-1 ✓
HSDP 74407-1 ✓
TI 74407-1 ✓

F2V0-9F924-AB

MATERIAL ANALYSIS

PARTS LIST

	PART NAME	PART #	CERTIFIED
1	BASE	46515-2	YES
2	STA. TERM.	36888-1	YES
3	MOVE. CONTACT	74408-1	YES
4	RIVET	74916-1	YES
5	MOVE. TERM.	36887-1	YES
6	SPRING ARM/MAT'L	36889-1/27716-1	YES
7	J512 HEXPORT	36900-1	YES
8	BASKET.	74353-1	YES
9	CUP	27713-1	YES
10	BEAL	74176-1	YES
11	KAPTON STRIP	27223-1	YES
12	WASHER	27639-1	YES
13	CONVERTER	27406-1	YES
14	KAPTON TAPE	74224-1	YES
15	SPACER	73958-2/-3	YES
16	CRIMP RING	74797-1	YES
17	TRANSFER PIN	74079-SEL.	YES
18	ENVIO. BEAL	74247-4	YES
			Jan. 1993

TI-NHTSA 003547

Hoechst Celanese

46515-2

NOVEMBER 4, 1992

TEXAS INSTRUMENTS INC
ACCTS. PAYABLE DEPT.
PO 666
ATTLEBORO, MA 02730
ATTN: RONALD BOTELETT

Advanced Materials Group
Hoechst Celanese Corporation
28 Main Street
Chatham, NJ 07828
201 636 2600
Telex 136348
Fax 201 636 4330

**HOECHST CELANESE CELANEX
GRADE 4300 NATURAL EF3022**

In reference to your Purchase Order 500059491, our Order No. 907, this is to advise you that the 2205 pounds of CELANEX(R) Thermoplastic Polyester 4300 NATURAL EF3022 lot number LJ21008321 shipped to you on NOVEMBER 3, 1992 is standard product and meets the following requirements:

SPECIFICATION **Ford WBS W4D 354-A1**

LOT RELEASE DATA-Actual Values (Tests performed on all lots)
(Specification Limit) (Actual Values)

Melt Index,			
gm./10min.	4-10		8.3
Ash, %	28-32		30.1

CERTIFIABLE VALUES
(Specification Limit) (Monitored Values)

Tensile Strength, MPa	103 MIN.	134.9
Elongation, %	3 MIN.	4.7
Flexural Strength, MPa	159 MIN.	210
Flexural Modulus, MPa	6,200 MIN.	7940
Notched Izod, J/m	101 MIN.	99

PERIODIC TESTS
(Specification Limit) (Test Values)

Specific Gravity, g/cc.	1.58 MAX.	1.52
HDT @ (1.8 MPa), °C	193 MIN.	207
Melting point, °C	215-225	225

**ADDITIONAL
SPECIFICATIONS**

All test data is generated by standard ASTM test methods.

HOECHST CELANESE CORPORATION
ENGINEERING PLASTICS DIVISION

John K. Morrow
Dr. John K. Morrow
Quality Assurance Officer

Hoechst 

TI-NHTSA 003548

August 20, 1991

To: Donna Moynihan 12-27

From: Beth Kili 10-16

Subject: GP-3 Material Confirmation
TSL Request # 110823

Sample Description:

P/N 36888-1 Stationary Terminal CDA 260 Brass
1/2 Hard

Results:

	P/N 36888-1	Spec. CDA 260
Cu (wt%)	68.5%	68.5 - 71.5%
Fe	0.030	0.05 max
Pb	0.010	0.07 max
Zn	balance	balance
Hardness	73 RB	60 - 77 RB

Results confirm the terminal is made of CDA 260 brass,
1/2 hard.

Regards,


Beth X3069

TI-NHTSA 003549

TEST NO. 116927

TECHNICAL SERVICE LABS

TEST NO. 116927



REPORT OF RESULTS:

silver enday31-01-10-11-12-13-14-15-16

#1 - .0012 .0013 .0011 .0012 - .0012
 2 - .0013 .0012 .0012 .0012 - .0012
 3 - .0015 .0011 .0012 .0011 - .0012
 4 - .0011 .0012 .0012 .0011 .0012

Ave

DATE RECEIVED

12/4/92

DATE OUT

12-7-92 Vue

TECHNICIAN			
HOURS WORKED			
PROCEDURE USED			

*PCC LD.

MC-325
 PC-127
 VERB-168
 AFCC-483
 IMD-430

TM-431
 WIRE-432
 EPD-621
 PEP-622
 CSD-835

JOY-128
 CLKE-122
 CAN-954
 AD DEV-286
 EMCO-877

FACIL-514
 FACIL-521
 FACIL-531
 STAFF-855

DISTRIBUTION: White and Yellow - Lab Pink - Requestor

TI-NHTSA 003550

THE MILFORD GROUP
857 BRIDGEPORT AVE.
MILFORD, CONNECTICUT 06460

TEL: 203-878-4631 * FAX 203-878-5071, 203-876-1346

TO: TEXAS INSTRUMENTS

CERTIFICATE OF COMPLIANCE

ACME MILFORD CERTIFIES THAT:

P.O. NUMBER: 500084023
ACME/MILFORD CONTROL NUMBER: 021874
ACME/MILFORD P/N: 6254-A
QUANTITY: 402218

WAS PROCESSED TO CONFORM TO THE FOLLOWING

PART NUMBER: 74408-1
PART REVISION: D
MATERIAL: COPPER CDA102

HEAT NUMBER:
TENSILE AFTER LIGHT DRAW:
FINISH: PLAIN

SIGNED: *Paul Molinari*

DATE: 12-30-92

PAUL MOLINARI
TITLE: VICE PRESIDENT QUALITY ASSURANCE

SWORN TO AND SUBSCRIBED BEFORE ME THIS/____ DAY ____ MONTH ____ YEAR

NOTARY PUBLIC _____

T-NHTSA 003551



BIGELOW COMPONENTS CORPORATION
74 DIAMOND ROAD, SPRINGFIELD, NEW JERSEY 07081-3190
AREA CODE 201-467-1200

CERTIFICATE OF CONFORMANCE

Texas Instruments Inc.
Materials & Controls
34 Forest Street
Attleboro, MA. 02703

Your P.O. No. - 500086112
Your Part No. - 74916-1 Rev. B
Qty. Shipped - 50,000
Date Shipped - 12-08-92

We certify that all items shipped on this order meet the requirements of the T.I. Purchase Order and T.I. Drawing Specifications.

We certify that the parts shipped were made of CDA 260 Brass, as requested on T.I. Drawing.

Very truly yours,


Frank Serafin



EST. 1948

K. F. BASSLER COMPANY, INC.

PRECISION TOOLING & METAL STAMPINGS

45 John William St. • Attleboro, MA 02703 • (508) 222-1081 • Fax: (508) 222-1805

MATERIAL CERTIFICATION

CUSTOMER: TEXAS INSTRUMENTS, INC. ATTLEBORO
CUSTOMER ORDER NO.: 505112589
CUSTOMER PART NO.: 36887-1
REVISION: B
QUANTITY THIS SHIPMENT: 50,000
LOT NO. THIS SHIPMENT: N/A
SHIPMENT DATE: 10.8.92

WE CERTIFY THAT THE MATERIAL USED TO PRODUCE THE PRODUCT IN THIS SHIPMENT, NAMELY, CDA 260, CONFORMS TO 715 DRAWING AND PURCHASE ORDER REQUIREMENTS.

AUTHORIZED SIGNATURE:

Kathleen A. Penkala
Inside Sales Specialist



TI-NHTSA 003553

A.J. OSTER CO.

Brass Mill Products • Steel • Pewter • Casting Alloys

ORIGINATOR HRA

A J OSTER - WARWICK
445 INDUSTRIAL DRIVE
WARWICK, RI 02886

1982-1

*** CERTIFICATE OF COMPLIANCE ***

AJO ORD#:
0181203

CUST ORD#:
15404

QUANTITY:

2608

DATE SHIPPED:

6-4-82

CUSTOMER NAME:

K. F. BASSLER CO.

CUST PART#:

260-025-112-2

DESCRIPTION:

QDA 260 COIL

GAUGE:

.02500

TEMPER:

2#

WIDTH:

1.1200

CHEMICAL ANALYSIS

#36887

TNO..... 0107936
HEAT#..... 163053
COIL#..... S 44291 A
CU..... 69.40000
ZN..... 30.56000
PB..... .00700
FE..... .01400
SB..... .00100
BI..... .00100

PHYSICAL TEST RESULTS

ROCKWELL..... R30T 63.4-
TENSILE..... 62.4-
YIELD..... 51.7-
ELONGATION..... 27.5

WE HEREBY CERTIFY THAT THE MATERIAL DESCRIBED HERE IN HAS BEEN MADE TO
CONFORM TO SPECIFICATION/ OR REQUIREMENTS OF YOUR ORDER.

June 3, 1982
DATE

A. Arroyo
LAB SUPERVISOR

TI-NHTSA 003554

BRUSH WELLMAN INC. 3 JUST ROAD

FAIRFIELD NJ 07006

201-287-2335

CERTIFICATE OF MATERIAL QUALITY

TEXAS INSTRUMENT
34 FOREST STREET
BUILDING 11 DOOR 16
ATTLEBORO

MA 02703

OUR ORDER NO:
OUR ITEM NO:
YOUR P.O. NO:
YOUR SPEC NO:
YOUR PART NO:

FA6712 CUSTOMER NO:
01 SHIPMENT NO:
300013387
27716-1

897852
002
11/24/92

ALLOY	STRIP	190	HM	35306	0.005	+0.0002	-0.0002	"	THI
		C17200	TM04		0.183	+0.002	-0.002	"	HIC
SHIPMENT NBR 002		100.0 LBS							
HEAT NUMBER 35306									

***** CHEMICAL COMPOSITION (PERCENT) *****

1.88 BE .20 CO .04 NI .06 FE .09 SI .05 AL
(.005 SN (.01 ZN .007 CR (.003 PB

REMAINDER: CU

***** AS SHIPPED PROPERTIES *****

TENSILE (KSI) 139.6 - 142.4
YIELD (KSI) 117.5 - 123.9
ELONGATION % IN 2" 13.0 - 13.0
HARDNESS-1 DPH 284.0 - 287.0
CONDUCTIVITY % IACS 19.2
GRAIN SIZE (MM) .015 - .018

***** PC / LOT OR COIL NUMBER *****

15- B

Paul J. Freund
QUALITY ASSURANCE MANAGER

11/24
DATE

TI-NHTSA 003555

CERTIFICATION

December 30, 1982

PAGE 1 OF 7

TEXAS INSTRUMENTS INC
ACCTS PAYABLE DEPT
P.O. BOX 886
ATTLEBORO, MA 02703

This is to certify the parts furnished on your purchase order have been produced in accordance with specifications listed on your purchase order and/or blueprint. This certification and accompanying documents may not be reproduced, except in full, without written approval of Elco Industries, Inc.

INSPECTION SHEET, SAMPLES, AND MILL SHEET ATTACHED

REV.: B

Records covering material used and the tests and inspection conducted are on file, subject to examination. This is an original certification and has not been amended unless stated below.

Purchase Order No.	505106886
Register No.	50347
Part No.	36900-1
Description	3/8-24 X .81
Quality Control No.	A9341-S
Mfg. Lot No.(s)	14265
Quantity	27,310

CERTIFICATION

Julius A. Stigler
Authorized Signature
Quality Coordinator



ELCO INDUSTRIES, INC.
PRECISION AUTOMOTIVE DIVISION
1111 Sartwell Road • P.O. Box 7000
Riverside, Miss 39185-7000
815-387-5151 • Fax 815-385-4555

P-81-2

TI-NHTSA 003556

O&K COMPANY LIMITED

AIS110L10 SAF

61 C. A 9341-S
S.O. # 14255

Chemical Composition Of Steel	Heat No.	Coil No.	$\frac{1}{16} \times 300$	$\frac{3}{16} \times 180$	$\frac{1}{4} \times 100$	$\frac{5}{16} \times 1000$	$\frac{3}{4} \times 1000$	$\frac{1}{2} \times 100$	$\frac{3}{16} \times 180$	$\frac{1}{4} \times 100$	$\frac{5}{16} \times 1000$	$\frac{3}{4} \times 1000$
	D08703	0021 0022	10	42	7	5	21	1	1	2	PB NK100 25	
Physical Properties	Nominal Diameter		Tolerance of Diameter		Tensile Strength		Decarburization					
	in	mm	in	mm	1,800 psi	kg/mm ²	Dir-T	Dir-F				
	0.585	14.351	+ 0.0040	+ 0.1016	88.9 MAX	48.5 MAX		MAX				
Packing	Coil Weight											
	ABT. 2.142LBS (ABT. 970KGS)											
	WRAPPED WITH POLYPROPYLENE SHEET.											

Sample No.	Diameter mm	Tensile Strength Kg/mm ²	Tensile Strength 1,000psi	Sample No.	Diameter mm	Tensile Strength Kg/mm ²	Tensile Strength 1,000psi
'0021	14.43	33.3	47.4				
0022	14.39	33.4 33.3	47.5				

TI-NHTSA 003557

T7420325

TEXAS INSTRUMENTS, INC.
BUILDING 11-16
34 FORREST STREET
ATTLEBORO, MA 02763

PARKER HANFORD CORPORATION
JBL DIVISION
WEST CROFT CIRCLE
SPARTANBURG, S.C. 29302
TELEPHONE (803) 573-7332

J.B.S. Division of Parker Seal certifies that the material used to produce the product in this shipment, namely EPDM/87104. Conforms to TI drawing and TI purchase order requirements.

PART TITLE... GASKET

CUST P/N... 74363-1

REV B

DATE SHIPPED

P/O... 500033079

J.B.S. P/N... 20215X

D/N... 21053

11-25-82

COMPOUND... 87104

QUANTITY... 100,000

Very Truly Yours,
J.B.S. Division



DENNIS T. JOHNSON
Quality Control Manager

DTJ/MS

TI-NHTSA 003558

VALENTINE TOOL & STAMPING, INC.

171 WEST MAIN ST. NORTON, MASS. 02766
(508) 285-6911 226-0044

CERTIFICATE OF CONFORMANCE

DATE : FRIDAY NOVEMBER 6, 1992

CUSTOMER : TEXAS INSTRUMENTS INC

CUSTOMER P.O. NO : 505111897 SUPPLIER INVOICE NO.: 82792

PART DESCRIPTION : 27713-1 CUP REV.9

SUPPLIER FJO NO. : 19053

QUANTITY SHIPPED : 22,000

SHIPMENT DATE : 11/09/92

WE CERTIFY THAT ALL ITEMS SHIPPED ON THIS ORDER MEET THE REQUIREMENTS
OF THE PURCHASE ORDER AND APPLICABLE DRAWINGS/SPECIFICATIONS. RESULTS
OF REQUIRED MECHANICAL, VISUAL, FUNCTIONAL AND CHEMICAL TESTS ARE ON
FILE IN OUR QUALITY ASSURANCE DEPARTMENT.

SIGNED


Jeanne Lafontaine
Quality Assurance Manager

TI-NHT8A 003559

VALENTINE TOOL & STAMPING, INC.

171 WEST MAIN ST. WORTON, MASS. 02766
(508) 285-6911

MATERIAL CERTIFICATION

DATE : FRIDAY NOVEMBER 6, 1992

CUSTOMER : TEXAS INSTRUMENTS INC

CUSTOMER P.O. NO : 505111897

SUPPLIER INVOICE NO.: 82792

PART DESCRIPTION : 27713-1 CUP REV.8

SUPPLIER FJO NO. : 19053

QUANTITY SHIPPED : 22,000

SHIPMENT DATE : 11/09/92

WE CERTIFY THAT THE MATERIAL USED
TO PRODUCE THE PRODUCT IN THIS
SHIPMENT, NAMELY
[C1004]
CONFORMS TO T.I. DRAWINGS AND
T.I. PURCHASE ORDER REQUIREMENTS.

SIGNED


(Supplier Representative)

Jeanne Laflamme Quality Assurance Manager

TI-NHTSA 003560

30A10V

30NAF

#27713-1

W/DOOR

801214
310-220-0810
310-220-0800
310-2120

ROME STRIP STEEL COMPANY, INC.
590 HENRY ST. BOX 189
ROME, NEW YORK 13440

COMPLIANCE #1

62016

01000000

DATE INVOICE NO.

09/17/92 20883

TO: VALENTINE TOOL & STAMPING, INC.
P.O. BOX 469
NORTON, MA 02766

SHIP TO: VALENTINE TOOL & STAMPING, INC.
171 W MAIN ST
NORTON, MA

ATTN: JEANNE LAFLAMME, QUALITY MGR.

NO. (LBS)	NO. CLS.	NO. ENDS OR SLS	FRONTAL COMPLETY	SHIPPED BY	MT. NO.	C	MM	F	S	SI	MC	CR	NO
3,192	072	12	COMP	J AUSTIN	R44829	04	31	012	014	01	01	03	
									AL	VR	CR	CA	

INSTRUCTIONS OF:

COLOR CODE

COIL NO. 15112

2MM X 50.80MM

2.0000 X 2.0000

TEMPER

B 50 MAX

EDGE

-001 +005 -005

ND3 SLIT

220 PIW 16 36

-025MM +127 -127MM

MILL NO.

74155

COILS ON CART

COIL

LENGTH SPEC

PREPAID
COLLECT

440 LBS

STRAPPING

PAPER W-10

BELS

CRATES

BOX

SKIDS

SKID SIZE

PKG. MT

WASTERS

CORES

3000

RUMBERS

SPACERS

SHROUD

BOARDS

CAPS

BURN

3/4"

CAMBER

FLATNESS

DIL

T-PCB

TEST REPORT

(15.056 KG)

33,192

Certificate of Compliance

I certify that the above figures are a true and
correct copy of those contained in the records
of this corporation.

Signature
ROME STRIP STEEL CO., INC.

TI-NHTSA 003561



CIRCLEVILLE PLANT

P.O. Box 89
Circleville, OH 43113

NO: KC-11
Effective Date: 3/06/92
Expiration Date: 3/06/93
Page 1 of 1

MATERIAL CERTIFICATION

DATE: 12-30-92

CUSTOMER: TEXAS INSTRUMENTS, ATTLEBORO

CUSTOMER ORDER NO. 5000 85037

CUSTOMER PART NO. & REV. 21225-1 (REV. R)

QUANTITY THIS SHIPMENT 104.00

SHIPMENT DATE 12-30-92

We certify that the material used to produce the product in this shipment, namely 500FN131 Kapton*, 3/4" wide, conforms to TI drawing and TI purchase order requirements on file with the HPF Group of the Dupont Company.



SUPPLIER REPRESENTATIVE
ENGINEER - QUALITY CONTROL - TITLE

:dkh/smart no. 387

Charting a Course for Excellence

TI-NHTSA 003562

DIEMASTERS MANUFACTURING, INC.

CERTIFICATE OF CONFORMANCE

DATE: 12-22-92

CUSTOMER: TEXAS INSTRUMENTS

PURCHASE ORDER NUMBER: 505/20270

PART NUMBER: 27639-1 REV/ECO NUMBER: D

PART DESCRIPTION: WASHER

QUANTITY THIS SHIPMENT: 90,000

SHIPMENT DATE: 12-22-92

TRACEABLE LOT NUMBER: TI. 201

.....

WE CERTIFY THAT ALL ITEMS SHIPPED ON THIS ORDER MEET THE REQUIREMENTS OF THE TI PURCHASE ORDER AND TI DRAWINGS/SPECIFICATIONS. RESULTS OF REQUIRED MECHANICAL, VISUAL, FUNCTIONAL, AND CHEMICAL TESTS ARE ON FILE IN OUR QUALITY CONTROL DEPARTMENT.

.....

SIGNED: Jim Nguyen
QUALITY ASSURANCE REPRESENTATIVE

TITLE: Inspector

11-13-92 13104

THOMPSON STEEL COMPANY INC.
9470 KING STREET
FRANKLIN PARK, IL 60131

#27639

SOLD TO DIEMASTERS MFG
767 INDUSTRIAL DRIVE
ELMHURST IL 60126-0000SHIP TO DIEMASTERS MFG
767 INDUSTRIAL DRIVE
ELMHURST IL 60126-0000

SHIP DATE : 12-08-92

ANALYSIS REPORT

CUSTOMER ORDER NO. BL-4762
THOMPSON ORDER NO. 2680800

GRADE	SIZE	T F E	PART NO.	SPEC. NO.
1050X	1.3750 X .0985	A 2 3		

HEAT NO. Y47629

	CI	MN	PI	SI	SI
TEXAS INSTITUTE	.520	.790	.0080	.0060	.210
27639-1	AL	CU	NI	CR	MO
	.033	.020	.020	.030	.010

WEIGHT: 13,101 # COILS: 40
 ROCKWELL: _____
 BEND TEST: _____
 OTHER: _____

EE

NOTE:

QUALITY CONTROL
DEC 09 1992

B/SO

CERTIFIED BY

Richard H. Davis

IT IS CERTIFIED THAT THE ABOVE IS A TRUE STATEMENT
THE TEST DATA CONTAINED IN THE RECORDS OF THIS CONF

TI-NHTSA 003564

DIEMASTERS, INC.
767 INDUSTRIAL DRIVE
ELMHURST IL
60126



PHONE: (708) 838-8118
FAX: (708) 838-4861
FPM CONTINUOUS PROCESSING
220 CARY POINT DRIVE CARY, ILLINOIS 60013

CERTIFICATION

Shop No. 096061
Order No. 111817
Quantity 148,400
Description 27639-1 WASHER TI-LOT 201
Material 1050

The following is certified:

Process AUSTEMPERED TO 40-60RC

INSPECTION RESULTS: 46-47 Rc

QUALITY CONTROL

DEC 28 1992

FPM CONTINUOUS PROCESSING

Authorized Signature: [Signature]

Date: 12/2/92

Belmont PLATING WORKS

DATE 12/9/92

We hereby certify that the Zinc plating on the material described below, was so processed as to meet U.S. Government Specifications.

767 Industrial Drive Elmhurst, Ill. 60126

[illegible]

Tatiana Gudlov

TI-NHTSA 00356

DIEMASTERS MANUFACTURING, INC.
CERTIFICATE OF MATERIAL ANALYSIS

DATE: 12-22-92
CUSTOMER: TEXAS INSTRUMENTS
SUPPLIER PURCHASE ORDER: BL-4762
CUSTOMER PURCHASE ORDER: 505120270
PART NUMBER: 27639-1 REV/ECO: D
PART DESCRIPTION: WASHER
QUANTITY THIS SHIPMENT: 90,000 SHIPMENT DATE: 12-22-92
TRACEABLE LOT NUMBER: TI-201
HEAT NUMBER: Y47629
TYPE OF MATERIAL: CRS 1050

WE CERTIFY THAT THE MATERIAL USED TO PRODUCE THE PRODUCT IN THIS SHIPMENT CONFORMS TO THE TI PURCHASE ORDER AND TI DRAWING/SPECIFICATION REQUIREMENTS. RESULTS VERSUS SPECIFICATION ARE AS NOTED BELOW.

ELEMENTAL CONSTITUENTS	SPECIFIED RANGE	ACTUAL RANGE
1. <u>C</u>	<u>0.47-0.55</u>	<u>.520</u>
2. <u>Al_N</u>	<u>0.60-0.90</u>	<u>.790</u>
3. <u>P_{MAX}</u>	<u>0.040</u>	<u>.0080</u>
4. <u>S_{MAX}</u>	<u>0.050</u>	<u>.0060</u>
5. _____	_____	_____

ROCKWELL HARDNESS: B/80 DPH: _____
TS. K.S.I.: _____

SIGNED: Jim Nguyen
QUALITY ASSURANCE REPRESENTATIVE

TITLE: Inspector

DIEMASTERS MANUFACTURING, INC.

MATERIAL CERTIFICATIONDATE: 12-22-92CUSTOMER: TEXAS INSTRUMENTSSUPPLIER PURCHASE ORDER: BL-4762CUSTOMER PURCHASE ORDER: 505120270PART NUMBER: 27639-1 REV/ECO: DPART DESCRIPTION: WASHERQUANTITY THIS SHIPMENT: 90,000SHIPMENT DATE: 12-22-92TRACEABLE LOT NUMBER: TL-201HEAT NUMBER: Y47629TYPE OF MATERIAL: CRS 1050

WE CERTIFY THAT THE MATERIAL USED TO PRODUCE THE PRODUCT IN THIS SHIPMENT, NAMELY (SPECIFIC NAME/NUMBER OF MATERIAL), CONFORMS TO TI DRAWING AND TI PURCHASE ORDER REQUIREMENTS.

SIGNED: Jim Nguyen
QUALITY ASSURANCE REPRESENTATIVETITLE: Inspector



EST. 1945

K. F. BASSLER COMPANY, INC.
PRECISION TOOLING & METAL STAMPINGS

45 John William St. • Attleboro, MA 02703 • (508) 222-1061 • Fax: (508) 228-1605

MATERIAL CERTIFICATION

CUSTOMER: Texas Instruments, Inc. -- Attleboro

CUSTOMER ORDER NO.: 506118095

CUSTOMER PART NO.: 27406-1

REVISION: "F"

QUANTITY THIS SHIPMENT:

28,750

LOT NO. THIS SHIPMENT:

182

SHIPMENT DATE:

1-4-93

We certify that the material used to produce the product in this shipment, namely, AK 1008 CRS, conforms to TFI's drawing and purchase order requirements

AUTHORIZED SIGNATURE:

Kathleen A. Penkala
Inside Sales Specialist



TI-NHTSA 003569

TELEX 881214
FAX 315-396-8510
PHONE 315-396-8800
CUMUL 225-3128



ROME STRIP STEEL COMPANY, INC.
580 HENRY ST. BOX 189
ROME, NEW YORK 13442-0189

COMPLIANCE #1

SALTS CODE
08072016

0 1 1 0 0 0 0 0

DATE	INVOICE NO.
10/22/92	22122

INVOICE TO: K. F. BASSLER CO., INC.
45 JOHN WILLIAM ST
ATTLEBORO, MA


02703

SHIP TO: K. F. BASSLER CO., INC.
45 JOHN WILLIAM ST
ATTLEBORO, MA

QUANTITY (LBS)	MP. CLS.	MP. SIZE OR BEND	PARTIAL COMPLETE	SHIPPED BY	MT. NO.	C	MM	P	S	M	SI	CH	TH
3,178	021	02	PART	R S S	R44829	D4	31	012	014	01	01	03	
					AL VR CR CA								

HEAVY REQUIREMENTS OF:	COLOR CODE	STRAPPING	PAPER WRAP	ROLLS	CRATES	BOX
CUT. ORDER NO. 19463						
7MM X 25.40MM	B45					
.04600 X 1.0000	8 50 MAX					
TOLERANCE	NO3 SLIT					
+00050-00050+005 -005	200 PIW 16 34					
+013 -013MM +127 -127MM						

CLASS	ANAL. NO.
ALUM KILD	C-1008



TEST REPORT

Certificate of Compliance

ATTEST:
052 06280733 101092

Notary Public, Onondaga County
My commission expires 5/21/94

DATE 10/22/92

I certify that the above figures are a true and correct copy of those contained in the records of this corporation.

[Signature]
ROME STRIP STEEL CO., INC.

TI-NHTSA 003570

TELEX 001214
FAX 518-338-0510
PHONE 518-338-0500
BUREAU 221-1100

ROME STRIP STEEL COMPANY, INC.
530 HENRY ST. BOX 189
ROME, NEW YORK 13442-0189

COMPLIANCE # 1

SALES CODE
08072016

0 1 1 0 0 0 0 0

DATE INVOICE NO.
10/22/92 22123

INVOICE TO: K. F. BASSLER CO., INC.
45 JOHN WILLIAM ST
ATTLEBORO, MA

02703

SHIP TO: K. F. BASSLER CO., INC.
45 JOHN WILLIAM ST
ATTLEBORO, MA

QUANTITY (LBS) 4,636
NO. CTS. 030
NO. SACS OR BLS 03
MATHA COMPLETE COMP
SHIPPED BY R S S

MT. NO. R44232
C 04
WB 29
P 010
S 007
SI 01
RI 01
CR NO 02 01
AL VN CR CA

MEETS REQUIREMENTS OF:
CMT. ORDER NO. 15463

COLOR CODE

7MM X 25.40MM

B⁴/₄₅

MILL NO.
75638

PREPAID
COLLECT
PREPAID

STRAPPING

PAPER WRAP

BRAS

CRATES

BOX

.04600 X 1.0000

8 50 MAX

COILS OR COT

COIL

200 LBS

SDPS

SHAP SIDE

PK. MT

WASTERS

EDGES

TOLERANCE

+00050-00050+005 -005

CODE

N03 SLIT

LENGTH SPEC

200 PIW 16 34

SHAPERS

SPACERS

SHROUD

BOARDS

LAFF

+013 -013MM +127 -127MM

CLASS
ALUM KILD

ANNO
C-1008

SHAP

CAMER
500/096°

FLATNESS

GIL

T-PCR

TEST REPORT

(2,103 KG)

4,636

Certificate of Compliance

ATTEST:

052 0628 33 101092

Notary Public, Oneida County
My commission expires 5/9/94

DATE 10/23/92

I certify that the above figures are a true and correct copy of those contained in the records of this corporation.

Q. J. J. J.
ROME STRIP STEEL CO., INC.

TI-NHTSA 003571



E. I. DU PONT DE NEMOURS & COMPANY
INCORPORATED
CIRCLEVILLE, OHIO 43113

NO: KC-13
Effective Date: 4/3/91
Expiration Date: 4/3/92
Page 1 of 1

MATERIAL CERTIFICATION

DATE: 11-19-92

CUSTOMER: TEXAS INSTRUMENTS, ATTLEBORO

CUSTOMER ORDER NO. 5000 85060

CUSTOMER PART NO. & REV. 74224-1 (REV. F)

QUANTITY THIS SHIPMENT 41.30

SHIPMENT DATE 11-19-92

We certify that the material used to produce the product in this shipment, namely 200HN Kapton[®], 15/16" wide, conforms to TI drawing and TI purchase order requirements on file with the HPF Group of the Dupont Company.



SUPPLIER REPRESENTATIVE
ENGINEER - QUALITY CONTROL - TITLE

ldkh/smart no. 389



PLASTIC FABRICATORS DIVISION
155 NO. MAIN STREET FRANKLIN, N.H. 03235
603-934-2770

CERTIFICATE OF CONFORMANCE

TO: TEXAS INSTRUMENTS

DATE: DEC - 1 1992

ATT: QUALITY CONTROL SUP.

THIS CERTIFIES THAT:

SHIPMENT # 165917

PART # 73958-1 REVISION G

QUANTITY 200,000

MAT'L DESC. KAPTON H.A.

IS IN CONFORMANCE WITH THE REQUIREMENTS, SPECIFICATIONS, AND DRAWINGS
ON YOUR ORDER # 575109357-01A#P

BY: INSULFAB PLASTICS
FRANKLIN, NH 03235

Fred Vignone
QUALITY CONTROL MANAGER

MADELITE
MELAMINE
SILICONES
EPOXIES

DISTRIBUTORS AND FABRICATORS OF
TEFLON • KAPTON • FIMC • PLENDIAS • POLYSTYRENE • GAFIL
NYLON • CLOTH PAPER • RESOLITE • POLYETHYLENE
CELHIN • LEXAN • MYLAR • HYDRA • GENCLER • CONTEMP

TI-NHTSA 003573

VALENTINE TOOL & STAMPING, INC.

171 WEST MAIN ST. NORTON, MASS. 02766
(508) 285-6911 226-0040

CERTIFICATE OF CONFORMANCE

DATE : TUESDAY JANUARY 5, 1993

CUSTOMER : TEXAS INSTRUMENTS INC

CUSTOMER P.O. NO : 505117282

SUPPLIER INVOICE NO.: 83078

PART DESCRIPTION : 74797-1 CRIMP RING REV.8


SUPPLIER FJO NO. : 19120

QUANTITY SHIPPED : 54,400

SHIPMENT DATE : 01/05/93

WE CERTIFY THAT ALL ITEMS SHIPPED ON THIS ORDER MEET THE REQUIREMENTS
OF THE PURCHASE ORDER AND APPLICABLE DRAWINGS/SPECIFICATIONS. RESULTS
OF REQUIRED MECHANICAL, VISUAL, FUNCTIONAL AND CHEMICAL TESTS ARE ON
FILE IN OUR QUALITY ASSURANCE DEPARTMENT.

SIGNED


Jeanne LaPlante
Quality Assurance Manager

TI-NHTSA 003574

VALENTINE TOOL & STAMPING, INC.

171 WEST BATH ST. NORTON, MASS. 02744
(508) 285-4911

MATERIAL CERTIFICATION

DATE : TUESDAY JANUARY 5, 1993

CUSTOMER : TEXAS INSTRUMENTS INC

CUSTOMER P.O. NO : 505117282

SUPPLIER INVOICE NO. 83078

PART DESCRIPTION : 74797-1 CRIMP RING REV.B

SUPPLIER FJO NO. : 19120

QUANTITY SHIPPED : 54,400

SHIPMENT DATE : 01/05/93

WE CERTIFY THAT THE MATERIAL USED
TO PRODUCE THE PRODUCT IN THIS
SHIPMENT, NAMELY
[5052 AL]
CONFORMS TO T.I. DRAWINGS AND
T.I. PURCHASE ORDER REQUIREMENTS.

SIGNED


(Supplier Representative)

Jeanne Laflamme Quality Assurance Manager

TI-NHTSA 003576

#74797-1

8566

**SOLD TO: VA003
 ATTN: DICK WHITNEY**

DATE October 05, 1992
CUST. PO# 15363
ORDER SPECS 5052-O .03200 x 2.312
UA ORDER# 170260D
SPECIFICATIONS ASTM B209, Q2-A-250/8

**VALENTINE TOOL & STAMPING INC.
 PO BX 469, 171 W. MAIN
 NORTON, MA 02766-0469**

CHEMICAL COMPOSITION LIMITS

This is to certify the following chemical composition limits, based on an individual or blanket certification of analysis supplied to United Aluminum by its vendor(s):

	VENDOR CERTIFICATION	
	MIN	MAX
SILICON		0.25
IRON		0.40
COPPER		0.10
MANGANESE		0.10
MAGNESIUM	2.2	2.8
CHROMIUM	0.15	0.35
ZINC		0.10
OTHER ELEMENTS (EACH)		0.05
OTHER ELEMENTS (TOTAL)		0.15
ALUMINUM	REMAINDER	

MECHANICAL PROPERTY RESULTS

This is to certify that the following are the results of the mechanical property test(s) performed by United Aluminum, based on a minimum of one sample for the order:

TENSILE STRENGTH (KSI)	29.2
ELONGATION (%)	24

Any test results reported above are subject to the limitations of the testing process. All sales are subject to United Aluminum's Terms and Conditions contained on the reverse of its Sales Order Acknowledgement.

Copyright (c) 1991 United Aluminum Corp.
 SHIP SHIP 2

10/05/1992 13:51:13
 00124-00002 04496

Paratech, Inc.

MINIATURE TECHNICAL CERAMICS

18940 MINNESOTA AVENUE • P.O. BOX 718 • PARAGUAY, CALIFORNIA 90728
TELEPHONE (213) 633-2045 • FAX (213) 633-8907

MATERIAL CERTIFICATION

DATE: 11-25-92

TEXAS INSTRUMENTS, INC.

ORDER NO.: 505128915

PART NO : 74078-145 REV. NO.: G

QUANTITY THIS SHIPMENT: 75,000

SHIPMENT DATE: 11-25-92

PART DESCRIPTION: PIN

WE CERTIFY THAT THE MATERIAL USED TO PRODUCE THE PRODUCT IN THIS
SHIPMENT, NAMELY PIN / STRATITE - L3, CONFORMS TO T.I.
DRAWING AND T.I. PURCHASE ORDER REQUIREMENTS.


PRODUCTION MANAGER

TI-NHTSA 003577

75220721

TEXAS INSTRUMENTS, INC.
BUILDING 11-16
34 FOREST STREET
ATLANTON, GA 30303

PARKER HANIFIN CORPORATION
JUL DIVISION
WEST CHERRY CIRCLE
SPARTANBURG, S.C. 29302
TELEPHONE (803) 573-7332

J.B.L. Division of Parker Seal certifies that the material used to produce the product in this shipment, namely SILICONE/ 57424. Conforms to TI drawing and TI purchase order requirements.

PART TYPE... ENVIRONMENTAL SEAL

CUST P/N... 74247 4 KEY H

DATE SHIPPED

P/O... 506023000

J.B.L. P/N... 207215

12-11-82

P/N... 18455 & 18457

SILICONE COMPOUND... 57418

QUANTITY... 42,700

Very Truly Yours,
J.B.L. Division



DENNIS F. JOHNSON
Quality Control Manager

DTJ/MS

TI-NHT8A 003578

888 2 001 500023698

09/21/92

p56

井

12/11/

004417-

TEXAS INSTRUMENTS
P O BOX 666

04 0505

ATTLEBORO

NA 02703

TEXAS INSTRUMENTS, INC.
BUILDING 11, DOOR 16
34 FOREST STREET

SECRET

ATTLEBORO

02703 HA

PACKING LIS

APPENDIX

→ Parked

Seat

JBL DIVISION

148

P. O. BOX 15009
WEST CROFT CIRCLE
SPARTANBURG, S.C. 29302

TELEPHONE (803) 573-7332
TELEFAX (803) 583-4288

#74247-4

55

DATE SHIPPED	SHIP VIA	WEIGHT	CARTONS	FREIGHT	HT
12-11-92	UPS	25 ^{lb}	3		15

ITEM	QUANTITY	PAPER PART NUMBER	CUSTOMER P/N - DESCRIPTION	MTS THIS ORDER	POD #	CLARITY S/O	PRICE **	CHC	REQUIRED DATE	DEL
04	55,000	207218 57519	74247-4	154 H	42,760 C	42,600			12/11/92	12
3 BX FLOOR B									** NOT BEFORE	

• **LEGEND**

PARTIAL - P
 COMPLETE - C
 OVERSAMPED - O

WE HEREBY CERTIFY THAT TO THE BEST OF OUR KNOWLEDGE AND BELIEF, THE FINISHED PARTS AND/OR MATERIAL PURSUANT TO PURCHASE ORDERS ISSUED BY YOU AND NUMBERED AS LISTED BELOW CONFORM TO APPLICABLE SPECIFICATIONS OR REQUIREMENTS.

CLAIMS FOR DAMAGES OR REPAIRS MUST BE MADE WITHIN 30 DAYS

THE SALE SUBJECT TO THE TERMS SET FORTH ON THE REVERSE PAGE OF THIS DOCUMENT

— 畢 節 —

77-NHT84 003678

ITEM	BATCH #	QUANTITY	ITEM	BATCH #	QUANTITY
4	17457	27,700			
4	19125	15,000			

F2VC-9F924-AB

MATERIAL ANALYSIS

PARTS LIST

	PART NAME	PART #	CERTIFIED
1	BASE	46515-2	YES
2	STA. TERM.	36888-1	YES
3	MOVE. CONTACT	74408-1	YES
4	RIVET	74171-1	YES
5	MOVE. TERM.	36887-1	YES
6	SPRING ARM	36889-1	YES
7	J512 HEXPORT	36900-1	YES
8	GASKET	74353-1	YES
9	CUP	27713-1	YES
10	SEAL	74176-1	YES
11	KAPTON STRIP	27325-1	YES
12	WASHER	27639-1	YES
13	CONVERTER	27406-1	YES
14	KAPTON TAPE	74224-1	YES
15	SPACER	73958-2/-3	YES
16	CRIMP RING	74797-1	YES
17	TRANSFER PIN	74078-BEL	YES
18	ENVIO. SEAL	74247- 2	YES
19	THREAD CAP	74179-1 74888-1	YES

submitted - 4 cert.
JAN. '92

TI-NHTSA 003580

August 28, 1991

To: Donna Moynihan 12-27

From: Beth Kill 10-16

Subject: GP-3 Material Confirmation
TSL Request # 110822

Sample Description:

P/N 46515-2 Thermoplastic Polyester
Calanex 4300

Results:

	P/N 46515-2	Spec.
Glass Fill	32%	30%

TGA results confirm the base contains slightly high glass fill. DSC results confirm the base material to be a thermoplastic polyester with a melting point at 223 -225 deg. C., and a glass transition at 50 - 60 deg. C., consistent with Calanex 4300.

Regards,

Beth X3069

TI-NHTSA 003581

[illegible]

RECEIVED
JUL 1 1967
JUL 1 1967

[illegible]

August 20, 1991

To: Donna Moynihan 12-27

From: Beth Kili 10-16

Subject: GP-3 Material Confirmation
TSL Request # 110823

Sample Description:

P/N 36888-1 Stationary Terminal CDA 260 Brass
1/2 Hard

Results:

	P/N 36888-1	Spec. CDA 260
Cu (wt%)	69.5%	68.5 - 71.5%
Fe	0.030	0.05 max
Pb	0.010	0.07 max
Zn	balance	balance
Hardness	73 RB	60 - 77 RB

Results confirm the terminal is made of CDA 260 brass,
1/2 hard.

Regards,

Beth X3069



1-9.
O
ACME MILFORD
857 BRIDGEPORT AVE.
MILFORD, CONNECTICUT 06440

TEL: 203-878-4631 * FAX 203-878-3071

TO: TEXAS INSTRUMENTS

CERTIFICATE OF COMPLIANCE

ACME MILFORD CERTIFIES THAT:

P.D. NUMBER: 500011076
ACME/MILFORD CONTROL NUMBER: 17642
ACME/MILFORD P/N: 6254-A
QUANTITY: 915425

WAS PROCESSED TO CONFORM TO THE FOLLOWING

PART NUMBER: 74408-1
PART REVISION: D
MATERIAL: COPPER CDA 102

9
HEAT NUMBER:
TENSILE AFTER LIGHT DRAW:
FINISH: .0011-.0024 SILVER PLATE
1 .0007 MIN OVER VENT

SIGNED:

DATE: 07-06-91

JOHN MICHAUD
TITLE: QUALITY CONTROL MANAGER

SWORN TO AND SUBSCRIBED BEFORE ME THIS/____DAY____MONTH____YEAR

NOTARY PUBLIC,_____

5
TI-NHT8A 003585

RADCLIFF WIRE INC.

FLAT, SQUARE AND CHAPED WIRE

Phosphor Bronze • Brass • Bimetal Steel

RONZO ROAD • P.O. BOX 603 • BRISTOL, CONNECTICUT 06010
TELEPHONE: 203 / 583-1305 • FAX: 203 / 583-8553

ORDER NO.

5321

MATERIAL CERTIFICATE

SOLD
TO

ACME MILFORD
857 BRIDGEPORT AVENUE
MILFORD, CT 06460

SHIP TO

VIA BUNTINGS

YOUR ORDER NO. 347-2	DATE ENTERED 6/28/91	DATE WANTED 7/29/91	DATE PROMISED	P.O. # Bristol
QTY/WEIGHT ORDERED 300 lbs.	SIZE/TOLERANCE .0575 p/m .0005 Dia.			SHAPE Round
TEMPER	MATERIAL ETP 110 Copper		EDGE	FRESH
SPEC	TENSILE 45-55,000 PSI			
SPECIAL CONDITIONS CERTS/NATL.				SPOOL-COA

SHIPPING RECORD

DATE	QUANTITY	PACKAGING	TEST
7/16/91	323#	1 Barrel	46,000 PSI

HEAT	C	MN	SI	S	P	Cr	NI	CU	B	Fe	Al
HARDNESS	TI	CS + TA	Co	MO	V	Mg	Ca	N	Zn	Pb	
TENSILE STR.	ZA	GB	TA	Sn	Be						
46,000 PSI											

*This is to certify that the above wire was processed from raw material and was found to be in compliance with the specifications of your po#347-2.

RADCLIFF WIRE, INC.

Claire Boucher
AUTHORIZED SIGNATURE
Claire Boucher Quality Control Inspector

TI-NHTSA 003586



AMERICAN ELECTRO PRODUCTS INC.
1356 THOMASTON AVENUE
WATERBURY, CT 06704
(203) 755-7051

Certificate of Compliance

NO. 214327
32.9 1

MILFORD RIVET & BUSH
857 BRIMLEY AVE

MILFORD CT 06440

DATE 05/20/71

YOUR ORDER NO. 13352
SHIPPED VIA UNITED P. S.

This is to verify that parts and/or your material furnished against your purchase order number shown above, have been manufactured in accordance with requirements and specification as required.

PART NO.	DESCRIPTION	QUANTITY
6234A	SILVER 0.001100-0.002400 HAZ	725.821 0

Tests to substantiate this have been performed in our plant (or have been performed by our suppliers) and are available upon request from us/or our suppliers.

Very truly yours,

AMERICAN ELECTRO PRODUCTS, INC.

Signed by:

Judy Sullivan
Q.C. Inspector

74408


TITLE

MOVABLE CONTACT

REV.

D


74408

CERTIFIED PRINT
Part Made to This Print Must Conform To

ENG. STD. E9898 REV. E

Date JUL 1 1991

NEITHER THIS PRINT NOR THE INFORMATION CONTAINED THEREIN IS TO BE USED AGAINST THE INTERESTS OF TEXAS INSTRUMENTS INCORPORATED OR AGAINST THE INTERESTS OF ANY OF ITS AFFILIATES OR SUBSIDIARIES OR WHOLLY OWNED SUBSIDIARIES.



NOTES:

1. PARTS MUST BE STORED IN PLASTIC BAGS THROUGH ALL SHIPPING AND HANDLING PROCESSES.
2. MATERIAL & PLATING THICKNESS CERTIFICATION REQUIRED WITH EACH SHIPMENT.
3. DIMENSIONS APPLY AFTER PLATING.
4. MEASURE PLATING THICKNESS BY MOUNTING & CROSS-SECTIONING PART.
5. PLATING THICKNESS APPLIES AT THE INDICATED LOCATION ONLY.
6. TOOL VENT MARK ON .040-.050R ALLOWED. DIMENSIONS MAY NOT EXCEED .001 IN HEIGHT AND .003 IN WIDTH. THERE MUST BE NO VOID IN PLATING IN THIS AREA. .032-.035 DIMENSION MAY MEASURE .036 OVER THIS MARK.
7. PLATING THICKNESS OF .0007 MINIMUM ALLOWED ABOVE TOOL VENT MARK ONLY. ADJACENT AREAS MUST MEET "FINISH" REQUIREMENTS.

56PSL4-1
1ST 120V
2ND 120V
3RD 120V
4TH 120V
5TH 120V
6TH 120V
7TH 120V
8TH 120V
9TH 120V
10TH 120V
11TH 120V
12TH 120V
13TH 120V
14TH 120V
15TH 120V
16TH 120V
17TH 120V
18TH 120V
19TH 120V
20TH 120V
21TH 120V
22TH 120V
23TH 120V
24TH 120V
25TH 120V
26TH 120V
27TH 120V
28TH 120V
29TH 120V
30TH 120V
31TH 120V
32TH 120V
33TH 120V
34TH 120V
35TH 120V
36TH 120V
37TH 120V
38TH 120V
39TH 120V
40TH 120V
41TH 120V
42TH 120V
43TH 120V
44TH 120V
45TH 120V
46TH 120V
47TH 120V
48TH 120V
49TH 120V
50TH 120V
51TH 120V
52TH 120V
53TH 120V
54TH 120V
55TH 120V
56TH 120V
57TH 120V
58TH 120V
59TH 120V
60TH 120V
61TH 120V
62TH 120V
63TH 120V
64TH 120V
65TH 120V
66TH 120V
67TH 120V
68TH 120V
69TH 120V
70TH 120V
71TH 120V
72TH 120V
73TH 120V
74TH 120V
75TH 120V
76TH 120V
77TH 120V
78TH 120V
79TH 120V
80TH 120V
81TH 120V
82TH 120V
83TH 120V
84TH 120V
85TH 120V
86TH 120V
87TH 120V
88TH 120V
89TH 120V
90TH 120V
91TH 120V
92TH 120V
93TH 120V
94TH 120V
95TH 120V
96TH 120V
97TH 120V
98TH 120V
99TH 120V
100TH 120V

74408-1	COPPER	SILVER PLT. .0011/.0024 THK. (SEE NOTE #5)	.0605-.063
PART NO.	MATERIAL	FINISH	DIA. "A"
BY T. Dail 1-6-85	CH. K. Parker 1-13-86	ENG. Ben Barker 1-13-86	
TEXAS INSTRUMENTS INCORPORATED ATTLEBORO, MASS., U.S.A.		KILXON CONTROL PRODUCTS DIVISION	PARTS LIST 74408

TI-NHT8A 003588

ACME MILFORD
857 BRIDGEPORT AVE.
MILFORD, CONNECTICUT 06460

TEL\ 203-878-4631 * FAX 203-878-5071

TO: TEXAS INSTRUMENTS

CERTIFICATE OF COMPLIANCE

ACME MILFORD CERTIFIES THAT:

P.O. NUMBER: 500011502
ACME/MILFORD CONTROL NUMBER: 19095
ACME/MILFORD P/N: 6051-A
QUANTITY: 59,995

WAS PROCESSED TO CONFORM TO THE FOLLOWING

PART NUMBER: 74171-1
PART REVISION: B
MATERIAL: BRASS CDA 260

HEAT NUMBER:
TENSILE AFTER LIGHT DRAW:
FINISH: PLAIN FINISH

SIGNED: *John Michaud* 
JOHN MICHAUD
TITLE: QUALITY CONTROL MANAGER

DATE: 05-30-91

SWORN TO AND SUBSCRIBED BEFORE ME THIS/____ DAY ____ MONTH ____ YEAR

NOTARY PUBLIC _____



SEYMOUR SPECIALTY WIRE COMPANY

(An Employee Owned Company)

15 Franklin Street

Seymour, Connecticut 06483

(203) 855-8773

ANALYSIS REPORT

Customer: Milford River & Machine Co.
Address: P.O. Box 4018
City: Ellettsville, OH 44035
Date: December 21, 1987
Customer P.O.: 37309
Seymour #: S-54718-1
Material: CDA 250 Wire
Size: .060" Rd.
Date Shipped: 12-18-87
Specification: U.S. 56/63,000 PSI GR #17 Heavy Soap Coat
Weight: 585 lbs.
Conforms to UNS# C25000

CHEMICAL ANALYSIS

COPPER	70.03
IRON	0.01
ARSENIC	0.01
ZINC	0.01
TIN	
SILICON	
MANGANESE	
PHOSPHORUS	
NICKEL	
ALUMINUM	

* Less than

PHYSICAL ANALYSIS

TENSILE STRENGTH PSI	63,000
YIELD STRENGTH PSI	
ELONGATION, % in.	20%
ROCKWELL	
BEND TEST	
GRAIN SIZE, AVERAGE	
RESISTIVITY ohm/cm	

CONDUCTIVITY

State of Connecticut
County of New Haven

Exam and subscribed to before me this 21 day of Dec, 1987

79111

TI-NHTSA 003590

August 20, 1991

To: Donna Moynihan 12-27

From: Beth Kili 10-16

Subject: GP-3 Material Confirmation
TSL Request # 110824

Sample Description:

P/N 36887-1 Moving Terminal CDA 260 Brass
1/2 Hard

Results:

	P/N 36887-1	Spec. CDA 260
Cu (wt%)	68.7%	68.5 - 71.5%
Fe	0.020	0.05 max
Pb	0.010	0.07 max
Zn	balance	balance
Hardness	80.5 RB	60 - 77 RB

Results confirm the terminal is made of CDA 260 brass,
and slightly above 1/2 hard.

Regards,

Beth X3069



August 20, 1991

To: Donna Moynihan 12-27

From: Beth Kili 10-16

Subject: GP-3 Material Confirmation
TSL Request # 110825

Sample Description:

P/N 36889-1 Spring C17200 Beryllium Copper

Results:

	P/N 36889-1	Spec. C17200
Be (wt%)	1.87%	1.80 - 2.00%
Fe	0.089	
Ni	0.068	[Fe + Ni + Co <0.6%] [Ni + Co >0.2%]
Co	0.220	
Hardness	300 DPH	285 - 343 DPH

Results confirm the spring is made of C17200 beryllium copper at the specified hardness.

Regards,

Beth X3069

TI-NHTSA 003594

[illegible]



ELCO INDUSTRIES, INC.
PRECISION FORMING DIVISION
 1111 Devonshire Road • P.O. Box 7008
 Rockford, Illinois 61105-7008
 Phone 815/987-8181 • Fax 815/987-8185 Ext. 748

CERTIFICATION

May 18, 1991

TEXAS INSTRUMENTS INC
 ACCTS PAYABLE DEPT
 P.O. BOX 886
 ATTLEBORO, MA 02703

This is to certify the parts furnished on your purchase order have been produced in accordance with specifications listed on your purchase order and/or blueprint.

MATERIAL CERTIFICATION, FINAL INSPECTION AND SAMPLES SENT

Records covering material used and the tests and inspection conducted are on file, subject to examination.

Purchase Order No. 500016587
 Register No. 78825
 Part No. 36800-1
 Description 3/8-24 X .81
 Quality Control No. A9341-S
 Quantity 8.735

36800-1

CERTIFICATION

The times call for quality. Elco quality.

James A. Stign
 Authorized Signature
 Quality Coordinator

P-81

TI-NHTSA 003597

COMPANY LIMITED

Type & Grade

SC-3896

AISI10L10 SAF

36 100-1

Po# 03462

104107

Chemical Composition Of Steel	Heat No.	Coil No.	C % x 100	Mn % x 100	Si % x 100	P % x 1000	S % x 1000	Cu % x 100	Ni % x 100	Cr % x 100	Mo % x 100	Al % x 100
	C78314	0001 - 0018	10	41	6	5	21	1	1	3		
	PB EX100 22											
Physical Properties	Nominal Diameter		Tolerance of Diameter				Tensile Strength		Decarburization			
	in	mm	in		mm		1,000 psi	kg/cm ²	Dec-T		Dec-F	
	0.585	14.351	+ 0.0040		+ 0.1018		68.9 MAX	48.5 MAX			MAX	
Packing	Coil Weight											
	ABT. 2.272LBS (ABT. 1.033KGS)											
	WRAPPED WITH POLYPROPYLENE SHEET.											

Test Results

Sample No.	Diameter mm	Tensile Strength Kg/mm ²	Tensile Strength 1,000psi	Sample No.	Diameter mm	Tensile Strength Kg/mm ²	Tensile Strength 1,000psi
0001	14.36	33.7	47.9				
0002	14.38	33.7	47.9				
0003	14.37	32.7	46.5				
0004	14.41	33.7	47.9				
0005	14.36	32.3	45.9				
0006	14.36	32.9	46.8				
0007	14.37	33.3	47.4				
0008	14.37	33.6	48.1				
0009	14.36	33.1	47.1				
0010	14.38	34.7	49.4				
0011	14.36	33.1	47.1				
0012	14.38	32.7	46.5				
0013	14.38	34.3	48.8				
0014	14.36	33.6	48.1				
0015	14.37	34.2	48.6				
0016	14.36	35.5	50.5				
0017	14.36	35.5	50.5				
0018	14.36	34.2	48.6				

TI-NHTSA 003598

INSPECTION HARDNESS TESTING RESULTS

TEST Rockwell SCALE USED B PART NO. 34700-1
73 min

SAMPLE NO. 1	RESULTS
1	73.3
2	72.5
3	73.7
4	73.8
5	72.7
6	73.5
7	73.9
8	71.7
9	76.0
10	74.3

AVERAGE 72.9
 MAXIMUM 73.9
 MINIMUM 71.0

109407

TECHNICAL SERVICE LABS

TEST NO. 109407

STATE YOUR PROBLEM SAMPLE DESCRIPTION	127 146 060 SANDY 11-11 3021 AT&C 5/23/91 5/24/91 3 COMPOSITION	INFORMATION DESIRED: Please section and 1775 measure 410-420 per attached drawing. Thank you, Sandy 36900-1
--	---	---

REPORT OF RESULTS:

① 410 - 41

② 42 - 41

③ 41 - 41

DATE RECEIVED

5/24/91

DATE OUT

5/24/91, 30.00.00

TECHNICIAN			
HOURS WORKED			
PROCEDURE USED			

*FCC I.D.

MC-325
PC-127
VERB-188
AFCC-483
IMD-430


TM-431
WRE-432
EPD-821
PEP-622
CSO-635

JOCY-126
CLKE-122
CAN-854
AD DEV-288
EMGD-877

FACIL-514
FACL-521
FACL-531
STAFF-858

DISTRIBUTION: White and Yellow - Lab Pink - Requestor

TI-NHTSA 003600



- CERTIFIED PRINT
 DATE JUL 25 1990
 JUL 1 1991

TI-NHTSA 003601

July 29, 1991

To: Donna Moynihan 12-27
From: Beth K111 10-16
Subject: GP-3 Material Confirmation
TSL Request # 110831

Sample Description:

#110831 P/N 74353-1 Gasket Ethylene
propylene rubber

Results:

Akron Rubber Development Laboratory Inc. has analyzed the
above component. The material conforms to specification.
See the enclosed report.

Regards,

Beth X3069

TI-NHTSA 003802



AKRON RUBBER DEVELOPMENT LABORATORY, INC.

300 KENMORE BOULEVARD • AKRON, OHIO 44301
Office (216) 434-6664 Telex (216) 434-8668

July 24, 1991

Ms. Elizabeth Kill
Texas Instruments
34 Forest St.
MS 10-16
Attleboro, MA 02703

SUBJECT: Chemical analysis on sample submitted by the above company.
PO# 500066978

RECEIVED: One sample identified as: #110831 Ethylene Propylene JBL compound
E-7104-70.

POLYMER IDENTIFICATION: ASTM D 3677
Pyrolysis method

SAMPLE

#110831

POLYMER IDENTIFICATION

Ethylene-Propylene Rubber

Janis Seifert
Janis Seifert
Senior Chemical Technician
AKRON RUBBER DEVELOPMENT LABORATORY, INC.

Thomas M. Knowles
Thomas M. Knowles
Vice President, Chemical Services


PN# 11726 INV# 31172601

tk

MEMBER OF AMERICAN COUNCIL OF INDEPENDENT LABORATORIES




TI-NHTSA 003603



TL-NHTBA 003604

SAMPLE	SOLVENT	SCAN	SINGLE B.	REMARKS.
	CONC.	SPLIT	T. D. SPEED.	
CELL PATH	OPERATOR	ORD. EXP.		
REFERENCE	DATE	T. CONST.		
ORIGIN	No. PR 5102-1001	REF. No.		

TI-NHTSA 003605



SAMPLE
Ethylene Propylene Rubber

SOURCE *Polymer*
CONC.
CELL PATH
REFLECTOR
PURITY

SCAN *5*
REF *2*
OPERATOR *Tone*
DATE
1968 (10-10) 1000

SINGLE B.
T.D. SPEED
ORD. EXP.
I. CONST
I.V. No.

REMARKS
Control

VALENTINE TOOL & STAMPING, INC.

131 WEST MAIN ST. NORTON, MASS. 02766
(508) 285-4811

MATERIAL CERTIFICATION

DATE : FRIDAY JUNE 14, 1991

CUSTOMER : TEXAS INSTRUMENTS INC

CUSTOMER P.O. NO : 505063392

SUPPLIER INVOICE NO.: 79580

PART DESCRIPTION : 27713-1 CUP REV.A

SUPPLIER FJO NO. : 18571

QUANTITY SHIPPED : 1,085

SHIPMENT DATE : 06/14/91

WE CERTIFY THAT THE MATERIAL USED
TO PRODUCE THE PRODUCT IN THIS
SHIPMENT, NAMELY
(C1006)
CONFORMS TO T.I. DRAWINGS AND
T.I. PURCHASE ORDER REQUIREMENTS.

SIGNED *Jeanne Laflamme*
(Supplier Representative)

Jeanne Laflamme Quality Control Manager

TI-NHTSA 003807

VALENTINE TOOL & STAMPING, INC.

171 WEST MAIN ST. NORTON, MASS. 02756
(508) 285-6911 226-8040

CERTIFICATE OF CONFORMANCE

DATE : FRIDAY JUNE 14, 1991

CUSTOMER : TEXAS INSTRUMENTS INC

CUSTOMER P.O. NO : 508063392

SUPPLIER INVOICE NO.: 79580

PART DESCRIPTION : 27713-1 CUP REV.A

SUPPLIER FJO NO. : 18571

QUANTITY SHIPPED : 1,085

SHIPMENT DATE : 06/14/91

WE CERTIFY THAT ALL ITEMS SHIPPED ON THIS ORDER MEET THE REQUIREMENTS
OF THE PURCHASE ORDER AND APPLICABLE DRAWINGS/SPECIFICATIONS. RESULTS
OF REQUIRED MECHANICAL, VISUAL, FUNCTIONAL AND CHEMICAL TESTS ARE ON
FILE IN OUR QUALITY CONTROL DEPARTMENT.

SIGNED

Jeanne Laflamme
Jeanne Laflamme
Quality Control Manager

TI-NHTSA 003608

E 318-336
S 223-212

6500 HASTINGS ST
ROME, NEW YORK 13440

SALES CODE
502010

27712
01000000

DATE	INVOICE NO
02/26/91	02740

VOICE TO: VALENTINE TOOL & STAMPING, INC.
171 W MAIN ST
NORTON, MA. 02766

SHIP TO: VALENTINE TOOL & STAMPING, INC.
171 W MAIN ST
NORTON, MA

ATTN: JEANNE LAPLAMME, Q.C. MGR.

QTY (LBS)	NO. CLS	NO. SECS OR BLS	PARTIAL COMPLETE	SHIPPED BY
16,154	040	06	COMP	K S S

MT NO	C	MM	P	S	SI	NI	CR NO
466709	07	34	012	006	01		
	AL	VM	CD	CA			

REQUIREMENTS OF:
ORDER NO. 13428

COLOR CODE

ITEM	QTY	SIZE	TEMP	COIL NO	PREPAID COLLECT	STAMPING	PAPER WRAP	ROLL	KNIFE	BOX
125	127MM X	50.80MM		62456	PREPAID					
	04000 Y	2.0000	4 50 MAX	COIL	440 LBS	3000				
FINANCE			EDGE	LENGTH SPEC						
101	-001	+005 -005	NU3 SLIT	220 P/W 16 30						
125	-025MM	+127 -127MM								
	CLASS			ALUM KILD	QST NO.					
					C-1006					

TEST REPORT

Certificate of Compliance

TEST: *[Signature]*
057107205 14/030291
Notary Public, Oneida County
My commission expires 5/31/92
DATE 2/27/91

I certify that the above figures are a true and correct copy of those contained in the records of this corporation.

[Signature]
ROME STEEL CO., INC.

TI-NHTBA 003609

920.5

September 25, 1991

To: Donna Moynihan 12-27

From: Beth Kell 10-16

Subject: Material Confirmation
TSL Request # 110632

Sample Description:

P/N 74176-1 Seal Teflon and Kapton

Results:

DSC results confirm the presence of Teflon by the characteristic melt point at 316 - 319 degrees C.

Kapton is confirmed in the seal by the IR scan. It shows the same characteristic absorbances exhibited by the sample known to be Kapton. See the enclosed scan.

Finally, the Teflon is confirmed to be on the surface of both sides of the seal by EDAX analysis.

Regards,


Beth X3069

TI-NHTSA 003611

Sample: 75475-S KAPTON TAPE
 Size: 3.3026 mg
 Method: KAPTON
 Comment: TML 110838 1224 QJAL
 0.18

DSC


File: DKAPTON.00
 Operator: K ROSE
 Run Date: 02/25/81 08:18



Sample: 75475-S KAPTON TAPE
 Size: 3.8000 mg
 Method: KAPTON
 Comment: TML 110838 1224 QJAL
 -0.1

DSC


File: DKAPTON.10
 Operator: K ROSE
 Run Date: 02/25/81 08:18



NO. 007-1493

PERKIN-ELMER

CONCENTRATION _____	SCAN MODE	ADY. ☐	SURVEY ☐	SPECTRUM NO. _____
THICKNESS _____		HI ENERGY ☐	CAL ☐	SAMPLE <u>110732</u>
PHASE _____		RESOLUTION ☒		<u>Kepton-Teflon</u>
REMARKS _____	OPERATOR <u>EK</u>	DATE <u>9/23/91</u>	ORIGIN _____	




TI-NHTSA 003813

03.25.91 10:37 AM
SAMPLE

SPECTRUM NO.

P08

IDENTIFICATION	SCAN MODE	ACQ. ☐	SURVEY ☐	SPECTRUM NO.
THICKNESS	HI ENERGY ☐	CAL ☐	SAMPLE <u>DURONT KAPTON</u>	
AGE	RESOLUTION ☒		<u>100EN099</u>	
MARKS	OPERATOR <u>S</u>	DATE <u>3/2/57</u>	ORIGIN	



TI-NHTSA 003614

SAMPLE

SPECTRUM NO.

08.28.81 10:37 AM

705