

# **EA02025**

**TEXAS INSTRUMENTS, INC.'S**

**9/10/03 ATTACHMENT TO ODI**

**BOX 4, PARTS A - N**

**PART J**

DIEMASTERS MANUFACTURING, INC.

CERTIFICATE OF CONFORMANCE

DATE: 07-10-92

CUSTOMER: TEXAS INSTRUMENTS

PURCHASE ORDER NUMBER: 500015400

PART NUMBER: 27639-1 REV/ECO NUMBER: D

PART DESCRIPTION: WASHER

QUANTITY THIS SHIPMENT: 12,367

SHIPMENT DATE: 07-10-92

TRACEABLE LOT NUMBER: TI-163

\*\*\*\*\*

WE CERTIFY THAT ALL ITEMS SHIPPED ON THIS ORDER MEET THE REQUIREMENTS OF THE TI PURCHASE ORDER AND TI DRAWINGS/SPECIFICATIONS. RESULTS OF REQUIRED MECHANICAL, VISUAL, FUNCTIONAL, AND CHEMICAL TESTS ARE ON FILE IN OUR QUALITY CONTROL DEPARTMENT.

\*\*\*\*\*

SIGNED: *Alvin Meyer*  
QUALITY/ASSURANCE REPRESENTATIVE

TITLE: *R/A INSPECTOR*

DIEMASTERS MANUFACTURING, INC.  
CERTIFICATE OF MATERIAL ANALYSIS

DATE: 07-10-92  
CUSTOMER: TEXAS INSTRUMENTS  
SUPPLIER PURCHASE ORDER: 033652  
CUSTOMER PURCHASE ORDER: 500015400  
PART NUMBER: 27639-1 REV/ECO: D  
PART DESCRIPTION: WASHER  
QUANTITY THIS SHIPMENT: 12,367 SHIPMENT DATE: 07-10-92  
TRACEABLE LOT NUMBER: TI- 163  
HEAT NUMBER: 664332  
TYPE OF MATERIAL: CRS 1050

\*\*\*\*\*

WE CERTIFY THAT THE MATERIAL USED TO PRODUCE THE PRODUCT IN THIS SHIPMENT CONFORMS TO THE TI PURCHASE ORDER AND TI DRAWING/SPECIFICATION REQUIREMENTS. RESULTS VERSUS SPECIFICATION ARE AS NOTED BELOW.

\*\*\*\*\*

ELEMENTAL CONSTITUENTS	SPECIFIED RANGE	ACTUAL RANGE
1. <u>C</u>	<u>0.47-0.55</u>	<u>.51</u>
2. <u>Mn</u>	<u>0.60-0.90</u>	<u>.69</u>
3. <u>Phos.</u>	<u>0.040</u>	<u>.013</u>
4. <u>S MAX.</u>	<u>0.050</u>	<u>.002</u>
5. _____	_____	_____

ROCKWELL HARDNESS: B/76 DPH: \_\_\_\_\_  
TS. K.S.I.: \_\_\_\_\_

SIGNED: Phil Krueger  
QUALITY ASSURANCE REPRESENTATIVE

TITLE: Q/A ASPECTE

DIEMASTERS MANUFACTURING, INC.

MATERIAL CERTIFICATION

DATE: 07-10-92

CUSTOMER: TEXAS INSTRUMENTS

SUPPLIER PURCHASE ORDER: 033652

CUSTOMER PURCHASE ORDER: 500015400

PART NUMBER: 27639-1 REV/ECO: D

PART DESCRIPTION: WASHER

QUANTITY THIS SHIPMENT: 12,367

SHIPMENT DATE: 07-10-92

TRACEABLE LOT NUMBER: TL 163

HEAT NUMBER: 664332

TYPE OF MATERIAL: CRS 1650

\*\*\*\*\*

WE CERTIFY THAT THE MATERIAL USED TO PRODUCE THE PRODUCT IN THIS SHIPMENT, NAMELY (SPECIFIC NAME/NUMBER OF MATERIAL), CONFORMS TO TI DRAWING AND TI PURCHASE ORDER REQUIREMENTS.

\*\*\*\*\*

SIGNED: *Phil Nguyen*  
QUALITY ASSURANCE REPRESENTATIVE

TITLE: G/A INSPECTOR

MORANDUM:

PELKEY RMR

July 14, 1992  
1-253

TO: STEVE OFFILER SBO1  
DAVE CZARN ZARN  
NEIL MACKINNON MAPA  
JOHN DEWOLFE MAPA  
AL HOPKINS AHOP

SUBJECT: CORROSION INSIDE OF SWITCH CAVITY  
- TSL # 111745

CONCLUSIONS:

The corrosion on the parts that we examined indicated that a liquid electrolyte, such as tap water, for instance, was present within the cavity. Furthermore, the connector end must have been oriented in the approximate up direction.

RESULTS AND DISCUSSION:

The major component, by far, of the powdery brownish substance (Sample #1) is copper oxide. We also saw some silver particulate present.

A deposit on the badly corroded spring arm (Sample #2) was also predominantly copper oxide. Surprisingly, we also saw a small area that was substantially enriched in aluminum oxide.

The corrosion on the cup (Sample #3) showed zinc oxide (the whitish deposit), copper oxide (probably from the spring arm), iron oxide (probably from the 1006 steel of the cup) and silver from the contact.

If you examine the plastic base you might find a "high water" mark of corrosion products. This might give you a better feel for the exact orientation of the switch.

We didn't see any significant amount of added electrolytes (such as salt).

The data will be sent by Grace Dias (X3044) through the internal mail.

→ THIS IS  
CONFIRMED TO  
BE ASSEMBLY;  
~ 1/4" UP SW.  
CAVITY - ALSO  
CONFIRMS "UP"  
ORIENTATION

TI-NHTSA 006297

--MSG M# 477424 FR=AHOP TO=CCNY SENT=07/14/92 04:47 PM  
ST=C DIV=0050 CD=00673 BY=AHOP AT=07/14/92 04:47 PM

MEMORANDUM

July 14, 1992  
92-253

TO: STEVE OFFILER SBO1  
CC: DAVE CZARN ZARN  
NEIL MACKINNON MAPA  
JOHN DEWOLFE MAPA  
FR: ██████████ AHOP  
SUBJECT: CORROSION INSIDE OF SWITCH CAVITY  
- TSL # 111745

CONCLUSIONS:

The corrosion on the parts that we examined indicated that a liquid electrolyte, such as tap water, for instance, was present within the cavity. Furthermore, the connector end must have been pointed in the approximate up direction.

RESULTS AND DISCUSSION:

The major component, by far, of the powdery brownish substance (Sample #1) is copper oxide. We also saw some silver particulate present.

The deposit on the badly corroded spring arm (Sample #2) was also predominantly copper oxide. Surprisingly, we also saw a small area that was substantially enriched in aluminum oxide.

The corrosion on the cup (Sample #3) showed zinc oxide (the whitish deposit), copper oxide (probably from the spring arm), iron oxide (probably from the 1006 steel of the cup) and silver (from the contact).

If you examine the elastic base you might find a "high water" mark of corrosion products. This might give you a better feel for the exact orientation of the switch.

We didn't see any significant amount of added electrolytes (such as salt).

The data will be sent by Grace Dias (X3044) through the internal

TI-NHTSA 006298

## 4.5. ~~IMPLISE~~

4.5.1

### PROCEDURES:

Per the engineering specification.

4.5.2

### EQUIPMENT:

- Thermotron environmental chamber, model S - 4.
- Twenty-four station manifold.
- Mating electrical connectors.
- Trygon Electronics Dual Power Supply, DL40-1A for the loads.
- Acopian power supply, SE25D-D15E05 for Sensotec transducer.
- Customized designed and built pressure cycler.
- Enerpac hydraulic pump.
- TI 315 Programmable Logic Controller.
- Moog servo valve, 760-552-A.
- Moog controller, MA-X-50.
- Simpson signal generator.
- Sensotec transducer, TJE-744-02, 0-2,500 psig, calibrated semi-annually.
- Nicolet oscilloscope, 310, calibrated semi-annually.

4.5.3

### REQUIREMENTS:

At the completion of this test all switches shall meet the Voltage Drop, Current Leakage, and Creep Time requirements outline in the engineering specification (See Appendix S.1). Additionally, the post-impulse calibration requirements are not define; results of this test will be used to set this requirement.

4.5.4

### RESULTS:

All switches met the requirements outlined in the engineering specification. Data is presented in Appendix S.4.2.

TI-NHTSA 006299

TEST LOT NO.	TEST	DEVICE
TESTED BY		
APPROVED BY	<b>TEXAS INSTRUMENTS</b>  <b>MATERIALS &amp; CONTROLS GROUP</b> ATTLEBORO, MA 01702	DOC.
DATE 7/16/92		PAGE 11

FORM 8299

**HIGHLIGHTS**  
Stephen B. Offiler  
Week Ending 92-07-17

*Handwritten signature and date: 9/28/92*



**VALIDATION ISSUES:**

The writup of 57PSL2-2 was completed. Only an Impulse test was performed; the rest of the report claims similarity to 57PSL11-3. This could have gotten awkward, with the failures experienced in L11-3; however this was avoided by asserting that L11-3 was actually tested to the L2-2 spec. This is generally true since the new, as-yet unfinished L11-3 spec is based largely on the L2-2 spec. Areas where the two specs diverge were explained in the L2-2 report.

We have had the necessary conversations with engineers at Ford, and have obtained verbal agreement on the finalized Power Steering spec which will ultimately cover all Ford PS devices. They have added a leak check at 100% frequency, which is fine since this is presently done on the automatic testing equipment. We ironed out all issues with vibration parameters, and worked away from the time-consuming additional thermal soaks Ford had proposed for the Thermal Cycle test. For drift after Impulse, they do not want to place additional post-test parameters onto the print; rather, they've proposed a blanket allowance of 10% additional tolerance on the low end. We'd like to see a bilateral 10% based on Stan's observations of upward drift; but this will certainly require re-opening of the negotiations and additional time which I do not think we can afford.

The next priority after the spec details are cleaned up and typed up is to produce the validation writup for 87PSL2-2. Creep actuation issues experienced in the original testing have disappeared with the Impulse retest. We will need to use this opportunity to analyze what happened to the original parts, which may help produce a more robust design.

We must submit validation testing to Australia for Capri 77PSL6-1 by the end of September. This is complicated by the need to obtain a colored EPDM O-ring (to avoid production-line confusion). We may need to validate with APT black EPDM O-rings, then go back and retest later with the colored production-invent parts.

**LIGHT TRUCK ISSUES:**

The 600 hour test has experienced four failures to date (301K, 342K, 379K, and 416K) which are classified as "normal" diaphragm life problems. One other failure occurred at 49K which was a misplaced gasket. Without further failures, the projected completion is noon on 920721. However, based on the failure rate it is likely that we'll lose a couple more before 600 hours/500K cycles. Interim results were reported verbally to John Pelkey earlier this week, and did not seem to cause undue concern.

TSL has completed analysis of the returned truck device (77PSL2-1). They found that the "crud" was copper oxide from the spring arm. Small amounts of silver, zinc oxide, iron oxide, and aluminum were also found. No evidence of other elements (such as kalis) were found, leading to the conclusion that the device was destroyed by plain water. We also reported this verbally to Pelkey. A report is to follow next week.

**MISCELLANEOUS:**

The test of rubber diaphragms has been abandoned temporarily. The EP rubber material we used to stamp out the disc-shaped diaphragms has been shown to take significant compression set and shrinkage, rendering its effectiveness as a seal rather useless. This idea still has merit, however, and should be continued with a more robust rubber material. Unfortunately, the cycler running these parts has experienced a failure of its Moog servovalve. These are rebuildable, but this valve has seen many many millions of cycles and should probably be replaced at some point. Unanticipated cycler failures have significant impact on the group's overcrowded cycling schedule.

-MSG # 573680 FR=SBO1 TO=PCME BENT=07/17/92 01:15 PM  
R#434 ST=C DIV=0050 CC=00101 BY=SBO1 AT=07/17/92 01:15 PM

TD:	Tad Ballard	ETB	Paul Katch	PRK1
	Tom Burke	MFPC	Steve Major	BNFH
	Rick Conlin	RAC1	Danny O'Driscoll	DDG
	Jeff DiDomenico	DIDG	Dale Sogge	FFUN
	Charlie Douglas	CMP1	Matt Sellers	PCME
	Nora Freda	WHLZ	Rusty Struble	RCS2
	Dick Gariepy	MFPC	Jim Watt	PCQA

CC: Tom Charboneau (delivered separately)  
Dave Czarn

FR: Steve Offiler SBO1

BJ: BiWeekly Highlights

\*\*\*\*\*  
**VALIDATION ISSUES:**

The writeup of 57PSL2-2 was completed. Only an impulse test was performed; the rest of the report claims similarity to 57PSL11-3. This could have gotten awkward, with the failures experienced in L11-3; however this was avoided by asserting that L11-3 was actually tested to the L2-2 spec. This is generally true since the now, as-yet unfinished L11-3 spec is based largely on the L2-2 spec. Areas where the two specs diverge were explained in the L2-2 report.

We have had the necessary conversations with engineers at Ford, and have obtained verbal agreement on the finalized Power Steering spec which will ultimately cover all Ford PB devices. They have added a leak check at 100% frequency, which is fine since this is presently done on the automatic testing equipment. We ironed out all issues with vibration parameters, and worked away from the time-consuming additional thermal soaks Ford had proposed for the Thermal Cycle test. For drift after impulse, they do not want to place additional post-test parameters onto the print; rather, they've proposed a blanket allowance of 10% additional tolerance on the low end. We'd like to see a bilateral 10% based on Stan's observations of upward drift; but this will certainly require re-opening of the negotiations and additional time which I do not think we can afford.

The next priority after the spec details are cleaned up and typed up is to produce the validation writeup for 87PSL2-2. Creep actuation issues experienced in the original testing have disappeared with the impulse retest. We still need to use this opportunity to analyze what happened to the original parts, which may help produce a more robust design.

We must submit validation testing to Australia for Capri 77PSL6-1 by the end of September. This is complicated by the need to obtain a colored EPDM O-ring (to avoid production-line confusion). We may need to validate with APT black EPDM O-rings, then go back and retest later with the colored production-intent parts.

TI-NHTSA 006301

**LIGHT TRUCK ISSUES:**

The 600 hour test has experienced four failures to date (301K, 342K, 379K, and 416K cycles) which are classified as "normal" diaphragm life problems. One other failure occurred at 49K which was a misplaced gasket. Without further failures, the projected completion is noon on 920721. However, based on the failure rate it is likely that we'll lose a couple more before 600 hours/500K cycles. Interim results were reported verbally to John Palkey earlier this week, and did not seem to cause undue concern.

TSL has completed analysis of the returned truck device (77PSL2-1). They found that the "crud" was copper oxide from the spring arm. Small amounts of silver, zinc oxide, iron oxide, and aluminum were also found. No evidence

of other elements (such as salts) were found, leading to the conclusion that the device was destroyed by plain water. We also reported this verbally to Pelkey. A report is to follow next week.

**MISCELLANEOUS:**

The test of rubber diaphragms has been abandoned temporarily. The EP rubber material we used to stamp out the disc-shaped diaphragms has been shown to take significant compression set and shrinkage, rendering its effectiveness as a seal rather useless. This idea still has merit, however, and should be continued with a more robust rubber material. Unfortunately, the cycler running these parts has experienced a failure of its Moog servovalve. It is rebuildable, but this valve has seen many many millions of cycles and should probably be replaced at some point. Unanticipated cycler failures have significant impact on the group's overcrowded cycling schedule.

Regards,  
Steve O.

161-01-30

SAMPLE ORDER

ORDER NO: CD91-73  
REQUEST DATE: 07/17/91  
CREDIT ACCOUNT: 5902  
COST CENTER: 101  
PRODUCT CODE: 060

CUSTOMER: FORD MOTOR COMPANY  
CUSTOMER P.O. NO: U-62975  
TI PART NO: 77PSL2-1  
CUSTOMER PART NO: ~~U77PSL2-1~~ FLVC-9F924-AB  
QUANTITY: 30  
PRICE: \$12.00 EACH

DELIVERY PROMISED: 9 - 6/28/91 (ALREADY DELIVERED)  
18.24 - 7/19/91 (QTY THIS BUILD)  
3 - 7/17/91 (57PSL5-3 SHIPPED WOD 7/17)

SPECIAL INSTRUCTIONS:

BILL TO:  
FORD MOTOR COMPANY  
P.O. BOX 1704  
DEARBORN, MI 48121

SHIP TO:  
FORD MOTOR COMPANY  
20000 ROTUNDA DRIVE  
RM 3001 - BLDG #5  
DEARBORN, MI 48121  
ATT'N: TIM ANDRESEN

XX PRODUCTION SAMPLES  
ENGINEERING DEVELOPMENT SAMPLES

CC: ENGINEERING: STEVE OFFILER  
PRODUCTION CONTROL: MARIE CROSSLAND  
SALES ENGINEER: JOE SCHUCK

TI-NHTSA 006303

HOW TO MEASURE A TEXAS INSTRUMENTS, INC. PRESSURE SWITCH SOUND PULSE.  
77PSL3-1 CRUISE CONTROL SWITCH

- 1) View the trace at full scale on the oscilloscope (no expansion).
- 2) You will see two lines.
  - A sloped line which is the pressure at the switch (solid line ).  
This line may be straight and smooth or it may have a ripple. The ripple is the sound pulse
  - A horizontal and vertical line, (dashed).  
This line measures the voltage across the switch. When the switch opens the line jumps vertically from the bottom of the page to the top of the page.
- 3) With the trace still on the scope zoom into the ripple in the curve.
- 4) Move the cursor to the visual peak prior to the first valley. For switches with no ripple estimate the point of major slope change to a nearly level line.
- 5) Reset the voltage to zero at that level.
- 6) Move the cursor to the bottom of the first valley and read the voltage.  
If the switch is quite use 6A instead.
  - 6A) Move the cursor to the next major slope change, usually at the end of a short flat section. This is a visual estimate and as such is subject to interpretation.
- 7) Multiply the voltage by 50psi/volt (ref transducer scale factor) to obtain the magnitude of the ripple in psi.

HOW TO MEASURE A TEXAS INSTRUMENTS, INC. PRESSURE SWITCH SOUND PULSE.  
FOR 77PSL3-1 CRUISE CONTROL SWITCH

The same technique works on a plotted curve.

- A) zoom into the ripple.
- B) Plot the curve. Figure 1.

The scales for these lines are indicated in the boxes on the left. The right side of the box is drawn with the same line type as the actual curve (solid, dashed, etc)

V/D = Volts per division

V<sub>y</sub> = voltage at tick mark next to V<sub>y</sub> on left side of page

There are 2cm per division on the y axis

T/D = Time per division

TL = time at left edge of page

There are 2.5 cm per division on the x axis

- C) Using a ruler measure the distance from peak to valley in centimeters.
- D) Multiply that figure by the v/d value to obtain the height in volts.
- E) Multiply by 50psi/volt to get the pressure reading.

TC: [unclear] Szam Circulation needed.

FR: Dale Sogge

SJ: Ford Silent switch test results

Attached are copies of all the pertinent documents pertaining to the silent switch.

The first document is the results from Ford's Test on parts with a range of sound levels as tested by R.H. Walker. Ford says the only acceptable parts are #64, 01, 16, 74.

The second document describes the details for all of the parts sent to Ford.

#64 was used for the original repeatability study so it has been tested several times and it has seen at least one months exposure to brake fluid without any increase in sound level. It uses a disc from the first lot of production switches.

#01 was also used for the repeatability study. It also uses a disc from one of the first four lots of quite production.

#16 uses a disc that I had judged to be slightly noisy based on the disc differential, at the beginning of the project. Apparently it's ok.

#74 is high differential fallout from the production line. This device exceeded the 45psi differential test limit on the final tester. Actual value on the final tester was unknown. The differential in the lab was 61.5psi which is probably 50-55psi on the line. The fact that this was quite allowed me to open the differential spec from 45 to 50psi which has increased our yields. We may want to open it to 55psi. One problem though is we don't know why the differential should ever be that high.

Also attached are the sound curves for these devices. The smoothness of these curves vs others correlates well to Ford's testing. The only fallback in the test was that it might not have been a blind test at Ford.

The next attachment is the final specification sent to Ford. Ford will make this part of the engineering specification. I selected a sound level of -1.5psi based on the Ford test results. One difficulty with this level for the spec is that we probably won't be 1.33CPK capable due to the device variation and the large R&R (25%). Fortunately we do not need to demonstrate CPK, we must only pass an audit on 12 pieces every 6 months.

The final document is a description of how to interpret the sound curves. Ford requested this for their information.

#### Actions

- 1) We need to modify the envelope drawings for quite switches to call out the sound test as specified. We may have to wait until the ES spec is issued. - Charlie, Steve
- 2) Retest the returned switches and then forward to other groups. - Dale

Regards, Dale

TI-NHTSA 006306

drs92-39, 7-28-92

*Dale*  
*I think we need to see the*  
*specification for the disc piece*  
*to determine if we*

TO: B. J. Meeroff

cc: R. H. Walker

Subject: Evaluation of alternate source for 1993 SHO dump switch.

Eleven cruise control dump switches from Texas Instruments were tested on a 1993 SHO to see at which sound level and above could the switches be seen as a viable alternative to the parts currently in use.

Eleven switches with serial numbers listed below were tested. Each was prefilled with brake fluid and the right front brake was bled after installation. A light indicator wired to the switch was used to verify switch actuation. Pedal feel was subjectively evaluated with and without vacuum in the booster. All evaluations were static.

Listed below are the various readings for pedal feel and sound level:

<u>SERIAL NUMBER</u>	<u>FEEL</u>	<u>SOUND LEVEL(dBsig)</u>
64	9	+1.5
01	9	+0.5
16	9	0.0
74	8	0.0
39	6	-2.5
23	5	-4.25
36	4	-6.6
53	5	-9.5
10	4	-26.2
59	3	-41.4
06	3	-81.0

Reason: The ...  
have an acceptable rating for all pedal ... issues.

*Sandra Postell*

Sandra L. Postell  
845-3303

-MSG M#- 222666 FR=VAGB TO=COPY SENT=07/28/92 07:08 AM  
BT=C DIV=0050 CC=00134 BY=VAGB AT=07/28/92 07:08 AM

TO: ANDRE CHARPENTIER ACHR  
CC: 77PS SMWT MFPC  
CLAIRE BALTHAZAR PCME  
FR: ~~MATT SELLERS~~ PCME

SJ: 77PS FUNCTION TESTER UPDATES  
\*\*\*\*\*

ANDRE,

THERE ARE A FEW UPDATES NEEDED ON THE DEFAULT SETTINGS FOR THE FOLLOWING DEVICES. ADDITIONALLY I WOULD LIKE TO SET UP ANOTHER DEFAULT FOR A NEW DEVICE - 77PSL6-1.

CHANGE # 1  
\*\*\*\*\*

77PSL3-1  
77PSL5-2  
77PSL3-2  
77PSL4-1

ON EACH DEVICE LISTED ABOVE PLEASE CHANGE:

- 1.) MINIMUM ACTUATION FROM 110 PSIG TO 105 PSIG.
- 2.) MAXIMUM DIFFERENTIAL FROM 45 PSIG TO 50 PSIG.

NEW DEVICE  
\*\*\*\*\*

77PSL6-1

PLEASE ADD THE DEVICE LISTED ABOVE TO THE DEFAULT SELECTION SCREEN. SET-UP PARAMETERS ARE SAME AS THE UPDATED 77PSL3-1 SPECIFICATION.

REGARDS . . . MATT  
X1245

TI-NHT8A 008309



77PS Pressure Tester

7/27/92 portfolio : 77PSL2-1 PG SNAP  
L4-1 Falcon Quiet  
L2-3 LT SNAP  
L5-2 Taurus Quiet  
L3-1 ENS3 Quiet NON ABS  
L3-2 LINNAB Quiet  
L3-3 F-SER/BROOK Quiet  
87PSL2-2 Ford PWR STR SNAP

-MSG #= 349687 FR=8801 TO=PCME SENT=07/31/92 12:50 PM  
R#-522 ST=C DIV=0050 CC=00101 BY=8801 AT=07/31/92 12:50 PM

TO: Ted Ballard	ETB	Paul Katch	PRK1
Tom Burke	MFPC	Steve Major	SMFH
Rick Conlin	RAC1	Danny O'Driscoll	DOD
Jeff DiDonomica	DIDO	Dale Sogge	FFUN
Charlie Douglas	CMP1	<del>Matt Stevens</del>	PCME
Nora Freda	WHLZ	Rusty Struble	RCB2
Dick Gariepy	MFPC	Jim Watt	PCGA

CC: Tom Charboneau (delivered separately)  
Dave Czarn

FR: Steve Offiler 8801

SJ: BiWeekly Highlights

The new, consolidated engineering specification for all power steering pressure switches has been typed up in its final form, and faxed to Nora for presentation to Ford engineers today. A clean paper copy is being overnited to him as well, to be duplicated on Ford ES title block paper and signed off for release into the Ford system.

The 600-hour thermal ramp and impulse test for Ford Light Truck has completed the full 600 hours. A total of seven devices failed in the normal diaphragm rupture mode, as well as the early failure at 49K for misplaced diaphragm. These results were verbally communicated to John Palkey, who did not indicate any undue concern over the failures. He has not had an opportunity to discuss this issue with Neru Modi as yet. We are working on a test report to be submitted to Ford.

Completion of the 600-hour test has allowed us to begin the battery of impulse and thermal cycle tests for 77P8L3-1 and L5-2. If all goes well, the L3-1 impulse will be complete mid-day Monday 08/03, the L5-2 impulse will complete mid-day Friday 08/07, and thermal cycles on both will commence. It will be necessary to work over the weekend of 08/08 and 08/09 to complete the TC test in time for final characterizations and writeup for 08/14. Samples of these parts were pre-characterized for noise, and will be post-characterized as well to determine if there are noise changes over life.

Jeff has received the refurbished servovalve back from Moog, and is working to get cyciler "B" up and running again with PAG oil.

We received metric hexports for Falcon from the model shop (B20 CNC lathes), but discovered a thread chamfer was neglected, so they were sent back to be reworked. We should have them back, and through plating, within a couple of weeks.

We continue to share information with Andy McKenna in Japan on diaphragm life in brake fluid applications. We are sending Andy samples of some materials (Tezel, and Kapton with enhanced properties) so he may begin testing immediately. We are working with J-B-L to produce samples of lathe-cut rubber diaphragms; an EX print is being generated. We'll share these with Andy as well.

Regards,  
Steve G.

TI-NHTSA 006311

**HIGHLIGHTS**  
Stephen B. Offiler  
Week Ending 92-07-31

*Norm*  
920731



The new, consolidated engineering specification for all power steering pressure switches has been typed up in its final form, and faxed to Norm for presentation to Ford engineers today. A clean paper copy is being overnighted to him as well, to be duplicated on Ford ES title block paper and signed off for release into the Ford system.

The 600-hour thermal ramp and impulse test for Ford Light Truck has completed the full 600 hours. A total of seven devices failed in the normal diaphragm rupture mode, as well as the early failure at 49K for misplaced diaphragm. These results were verbally communicated to John Pelkey, who did not indicate any undue concern over the failures. He has not had an opportunity to discuss this issue with Noru Modi as yet. We are working on a test report to be submitted to Ford.

Completion of the 600-hour test has allowed us to begin the battery of Impulse and Thermal Cycle tests for 77P5L3-1 and L3-2. If all goes well, the L3-1 Impulse will be complete mid-day Monday 08/03, the L3-2 Impulse will complete mid-day Friday 08/07, and Thermal Cycles on both will commence. It will be necessary to work over the weekend of 08/08 and 08/09 to complete the TC test in time for final characterizations and writeup for 08/14. Samples of these parts were pre-characterized for noise, and will be post-characterized as well to determine if there are noise changes over life.

Jeff has received the refurbished servovalve back from Moog, and is working to get cyclus "B" up and running again with PAG oil.

We received metric hexports from the model shop (B20 CNC lathe), but discovered a thread chamfer was neglected, so they were sent back to be reworked. We should have them back, and through plating, within a couple of weeks.

We continue to share information with Andy McKenna in Japan on diaphragm life in brake fluid applications. We are sending Andy samples of some materials (Telzel, and Kapton with enhanced properties) so he may begin testing immediately. We are working with J-B-L to produce samples of lathe-cut rubber diaphragms; an EX print is being generated. We'll share these with Andy as well.

PRESSURE SWITCH DATA

Form 21605

TEST NO.

250-12-56

DEVICE <b>FPS</b>	DATE REQUESTED <b>8/3/92</b>	REQUESTED BY <b>DAL SO99E</b>	REQUESTED COMPL. DATE
PERFORMED BY <b>DAVID O TOOLE</b>	DATE STARTED <b>8/5/92</b>	DATE COMPLETED	APPROVED BY

PROJECT TITLE:

CUSTOMER:

PURPOSE OF TEST:

To test noise level set act.  
AFCA TESTING BY FORD ON SHO THURUS

All readings on Disk #10 8/8/92

PROCEDURE:

		X50 =	PEI	
250-12-4	0.014	*		} Recorded on 8/8/92 Disk #10
250-12-56	-1.466 MV		-58.3	
250-12-10	-1.127 MV		-71.0	
250-12-16	0.015		0	
250-12-15	-1.551 MV		-7.75	
39	-75 MV		-3.75	
53	-2.15 MV		-10.75	
62	-7.65 MV *		-37.25	
69	-9.70 MV		-49.5	
79	-0.1 MV		-0.5	

JEFF

1) PLEASE RUN & R&R (REPEATABILITY & REPRODUCIBILITY) TEST ON A NOISY PASSENGER CAR SWITCHES FROM THE PRODUCTION LINE. A SECOND & THIRD PERSON WILL BE REQUIRED TO INSTALL THE SWITCH, BLEND IT & GET A RESULT FOR THE REPRODUCIBILITY PART. SEE STATISTICAL QUALITY CONTROL MANUAL FOR METHOD. 10 UNITS

PLOTS ARE NOT REQUIRED JUST THE PEAK TO PEAK VOLTAGE VALUE. SHARE PLOT DATA ON DISC.

2) MEASURE THE PEAK TO PEAK VOLTAGE OF THE FOLLOWING SWITCH TYPES. MEASURE FIVE PIECES OF EACH TYPE & RECORD THE AVERAGE & SIGMA. (NOTE: FOR QUIET SWITCHES YOU MAY NOT BE ABLE TO DETECT A RIPPLE, JUST RECORD AS ZERO) RECORD RESULTS ON ALLIANCE BEFORE STARTING.

ALL WITH NO SNUBBERS

77PSL3-1	QUIET PASS CAR
77PSL	NOISY TRUCK
-	QUIET TRUCK - BUILT WITH LOT 'AA' DISCS, <sup>IN BNS</sup> GOT FROM GENTLE
-	LOT "N" SLIGHTLY NOISY PASS CAR
-	LOT "L" " " "
QUIET PASS CAR 6.5 p.p.m.	LOT "F"
QUIET TRUCK 10.5 "	LOT "T" SLIGHTLY NOISY TRUCK
-	LOT "U" QUIET TRUCK - NEW FROM STOCK
-	LOT "B" IF YOU CAN FIND IT - I THINK YOU HAVE IT. (QUIET TRUCK FROM 1990)
-	LOT "D" YOU HAVE
-	LOT "E"

TI-NHTSA 006314

SAVE ALL PARTS SO I CAN DESCRIBE &  
PRESSURE SENSOR CURVE & THICK DEGRIP &  
MEASURE DISC CURVE

TI-NHTSA 006315

GM GAGE STUDY FOR REPEATABILITY AND REPRODUCIBILITY (LONG METHOD)  
~~02-Jan-80~~ MAY 12, 1982  
 NOISY SWITCH PULSE LEVEL

NUMBER OF OPERATORS	2	MIN SPEC	-1500
NUMBER OF PARTS	10	MAX SPEC	2000
NUMBER OF TRIALS	2	TOLERANCE	3500

DATA SUMMARY

OPERATOR	AVERAGE	RANGE
JEFF	814.9	494.8
HOWARD	1110.55	87.7
3	NA	NA
4	NA	NA
5	NA	NA
6	NA	NA
7	NA	NA
8	NA	NA
9	NA	NA
10	NA	NA
AVERAGE	962.725	291.25

MIN XBAR 814.9  
 MAX XBAR 1110.55  
 XBARDIFF 295.65

	MEASUREMENT UNIT ANALYSIS	%TOLERANCE
REPEATABILITY:	1329.731	37.99%
REPRODUCIBILITY:	1030.113	29.66%
RPT & REPR (R&R):	1686.969	48.20%

NOTE: ALL CALCULATIONS BASED ON 5.15 SIGMA (99%)

$$Cpk = \frac{USL - \bar{x}}{3\sigma_x}$$

$$\begin{aligned}
 USL &= \bar{x} + 3\sigma_x Cpk \\
 &= 962.75 + 3(101)(1.33) \\
 &= 1605
 \end{aligned}$$

TI-NHTSA 006316

DATA FOR OPERATOR HOWARD

PART	TRIAL					AVG	RANGE
	1	2	3	4	5		
1	938	1085				1011.5	147
2	1130	994				1062	136
3	960	1000				980	40
4	1310	1350				1330	40
5	1280	1290				1285	10
6	960	1040				1000	80
7	825	1123				974	298
8	1220	1280				1250	60
9	1150	1140				1145	10
10	1040	1096				1068	56
11	$\bar{x} = 1081.3$	$\bar{x} = 1131.8$				NA	0
12						NA	0
13	$\sigma_{n-1} = 161.25$	$\sigma_{n-1} = 125.7$				NA	0
14						NA	0
15						NA	0
16						NA	0
17						NA	0
18						NA	0
19						NA	0
20						NA	0
21						NA	0
22						NA	0
23						NA	0
24						NA	0
25						NA	0

GRND AVG: 1110.55      AVG RNGE: 67.7  
 UCL FOR INDIVIDUAL RANGES 951.5137

ENTER STUDY TITLES IN CELLS A8,A9,A10, MIN/MAX SPEC IN B12, B13  
 NOISE SWITCH PULSE LEVEL

MIN SPEC  
 MAX SPEC  
 TOLERANCE 0

DATA FOR OPERATOR JEFF

PART	TRIAL					AVG	RANGE
	1	2	3	4	5		
1	671	1000				835.5	329
2	694	1091				892.5	397
3	657	1005				831	348
4	177	1321				749	1144
5	775	1102				938.5	327
6	179	1090				631.5	917
7	729	1117				920	394
8	707	1256				981.5	549
9	665	383				524	282
10	715	976				845.5	261
11						NA	0
12						NA	0
13						NA	0
14						NA	0
15						NA	0
16						NA	0
17						NA	0
18						NA	0
19						NA	0
20						NA	0
21						NA	0
22						NA	0
23						NA	0
24						NA	0
25						NA	0

GRND AVG: 814.9      AVG RANGE: 494.8  
 UCL FOR INDIVIDUAL RANGES 951.5137

GM GAGE STUDY FOR REPEATABILITY AND REPRODUCIBILITY (LONG METHOD)  
~~92-011-55~~ MAY 12, 1992  
 SOUND PULSE SILENT SWITCHES

NUMBER OF OPERATORS	2	MIN SPEC	-200
NUMBER OF PARTS	10	MAX SPEC	500
NUMBER OF TRIALS	2	TOLERANCE	700

DATA SUMMARY

OPERATOR	AVERAGE	RANGE
JEFF	38.95	16.5
HOWARD	44.9	27.8
3	NA	NA
4	NA	NA
5	NA	NA
6	NA	NA
7	NA	NA
8	NA	NA
9	NA	NA
10	NA	NA
-----		
AVERAGE	41.925	22.15

MIN XBAR	38.95
MAX XBAR	44.9
XBARDIFF	5.95

	MEASUREMENT UNIT ANALYSIS	%TOLERANCE
-----		
REPEATABILITY:	101.1281	14.45%
REPRODUCIBILITY:	0	0.00%
RPT & REPR (R&R):	101.1281	14.45%

NOTE: ALL CALCULATIONS BASED ON 5.15 SIGMA (99%)

TI-NHTSA 006319

ENTER STUDY TITLES IN CELLS A8,A9,A10, MIN/MAX SPEC IN B12. B13  
 SOUND PULSE SILENT SWITCHES

MIN SPEC  
 MAX SPEC  
 TOLERANCE 0

DATA FOR OPERATOR JEFF

PART	TRIAL					AVG	RANGE
	1	2	3	4	5		
1	37	52				44.5	15
2	-12	-7				-9.5	5
3	33	0				16.5	33
4	-22	-13				-17.5	9
5	39	10				24.5	29
6	208	223				214	18
7	-13	-4				-8.5	9
8	0	30				15	30
9	59	53				56	6
10	49	60				54.5	11
11	37.5	90A				NA	0
12						NA	0
13						NA	0
14						NA	0
15						NA	0
16						NA	0
17						NA	0
18						NA	0
19						NA	0
20						NA	0
21						NA	0
22						NA	0
23						NA	0
24						NA	0
25						NA	0

$\sigma = 25.5$        $\sigma_{n-1} = 69.7$   
 14

GRND AVG: 38.95      AVG RANGE: 16.5  
 UCL FOR INDIVIDUAL RANGES 72.36405

$$UCL_{\bar{x}} = \bar{\bar{x}} + A_2 \bar{R}$$

$$= 41.925 + .308(22.15)$$

$$= 48.74$$

$$6\sigma_{\bar{x}} = \sqrt{n} \cdot 2A_2 \bar{R}$$

$$= \sqrt{10} \cdot 2(.308)(22.15)$$

$$= 43.14$$

$$C_{pk} = \frac{(USL - \bar{x})}{3\sigma_{\bar{x}}}$$

$$USL = \bar{x} + 3\sigma_{\bar{x}} C_{pk}$$

$$= 41.9 + 3(69)(1.33)$$

$$= 317.21$$

$$LSL = -233.41$$

TI-NHTSA 006320

DATA FOR OPERATOR HOWARD


PART	1	2	TRIAL 3	4	5	AVG	RANGE
1	40	68				54	28
2	40	26				33	14
3	20	53				36.5	33
4	23	-19				2	42
5	17	9				13	8
6	181	155				168	26
7	-8	22				7	30
8	0	33				16.5	33
9	70	19				44.5	51
10	81	68				74.5	13
11						NA	0
12						NA	0
13						NA	0
14						NA	0
15						NA	0
16						NA	0
17						NA	0
18						NA	0
19						NA	0
20						NA	0
21						NA	0
22						NA	0
23						NA	0
24						NA	0
25						NA	0

GRND AVG: 44.9      AVG RANGE: 27.8  
 UCL FOR INDIVIDUAL RANGES 72.36405

SOUND TEST (HYDRAULIC PULSE) ON LOT T, MEASURED WITH KISTLER,  
 ASSEMBLED USING PARTS FROM TEST D; D-DIMENSIONS, RATHER THAN PROJECTION LINE

2.505JC  
 5-1-92

TI-NHTSA 006322



EFFICIENCY LINE = 23-200

	JEFF				HOWARD				NAME OF AVE	
	1 RUN 1	2 RUN 2	3 AVG	4 DELTA	5 RUN 1	6 RUN 2	7 AVG	8 REPEAT DELTA	9 REPEAT DELTA	
1	171	1000	836	+229	938	1065	1012	+147	+12	
2	194	1091	897	+197	1170	994	1062	-136	-29	
3	657	1015	831	+148	960	1000	980	+48	-25	
4	177	1321	759	+1144	1710	1550	1570	+40	+9	
5	775	1102	939	+337	1280	1290	1285	+10	+188	
6	173	1098	672	+917	960	1040	1000	+80	-90	
7	723	1119	826	+395	825	1123	974	+298*	-143	
8	787	1256	782	+505	1224	1280	1250	+60	-6	
9	665	383*	529	-282	1150	1140	1145	-10	N/A	
10	715	976	846	+261	1040	1096	1068	+56	+92	
11										
12		1034/254				1110/134	58.8/111		83/95	
13		1061/116					36.9/77			
14	THESE									
15	TAKEN									
16	ON A									
17	DIFF.									
18	DAY									
19	N/G									
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
31										
32										
33										
34										
35										
36										
37										
38										
39										
40										
41										
42										
43										
44										
45										
46										
47										
48										
49										
50										

THESE TAKEN ON A DIFF. DAY N/G

1034/254 ← w/ 2nd MEAS.  
1061/116

1110/134

GR AVG  
1108

15 ± 30%  
263

$\frac{263}{10} = 23.7\%$

$\frac{385}{1108} = 25.8\%$

REPEATABILITY → BASED ON HOWARD'S MEAS. w/ FLYER  
RETURNED (#7) IS 23.7%


REPRODUCIBILITY → JEFF'S SINGLE SBT VS. HOWARD'S AVG (ID #7 RETURNED)  
IS 25.8%

AD 920515

#1 Shipped.


#1


TI-NHTSA 006324



#6+10 Skipped.

TI-NHTBA 006326






TI-0801406

TI-NHTSA 006326

#16 Shipped.

#4

RANGES:	2.250V	10.00V	3.750V
OFFSETS:	0.0V	0.0V	0.0V
TOTAL TIME:	1.00S		
POST-TRIG:	0.05		
TRIGGER:	MAN		
	15.53.42	08 JUL 92	




TI-NHTSA 006327

#25 Shipped. Black #22 #23 Purple #5


RANGES:	2.250V	10.00V	3.750V
OFFSETS:	0.0V	0.0V	0.0V
TOTAL TIME:	1.00S		
POST-TRIG:	0.0S		
TRIGGER:	MAN		
15:54:19 06 JUL 92			

TI-NHTSA 008326




#

RANGES:	2.250V	10.00V	3.750V
OFFSETS:	0.0V	0.0V	0.0V
TOTAL TIME:	1.00S		
POST-TRIG:	0.0S		
TRIGGER:	MAN		
15:54:57 08 JUL 92			




TI-NHTSA 008329



TI-NHTSA 006330

# 39 shipped.


# 8




TI-NHTSA 006331

RANGES:	2.250V	10.00V	3.750V
OFFSETS:	0.0V	0.0V	0.0V
TOTAL TIME:	1.00S		
POST-TRIG:	0.0S		
TRIGGER:	MAN		
	15, 56, 29	05 JUL 92	


TI-NHTSA 006332





RANGES:	2.250V	10.00V	3.750V
OFFSETS:	0.0V	0.0V	0.0V
TOTAL TIME:	1.00S		
POST-TRIG:	0.0S		
TRIGGER:	MAN		
15:57:01	00 JUL 92		

TI-NHTBA 008333




RANGES:	2.250V	10.00V	3.750V
OFFSETS:	0.0V	0.0V	0.0V
TOTAL TIME:	1.00S		
POST-TRIG:	0.0S		
TRIGGER:	MAN		
	13:57:24	00 JUL 92	

TI-NHTSA 006334

50159 Shipped.


TI-NHTSA 008335

#1



of Shipp.

#13




RANGES:	2.250V	10.00V	3.750V
OFFSETS:	0.0V	0.0V	0.0V
TOTAL TIME:	1.00S		
POST-TRIG:	0.0S		
TRIGGER:	MAN		
16.08.41 05 JUL 92			

TI-NHTSA 006936


RANGES:	2.250V	10.00V	3.750V
OFFSETS:	0.0V	0.0V	0.0V
TOTAL TIME:	1.00S		
POST-TRIG:	0.0S		
TRIGGER:	MAN		
DE:	33:04	07 JUL 92	

TI-NHTSA 006337



#74 Skipped

#15



TI-NHTSA 006338

CREEP ACTUATION AFTER <sup>2-2-67</sup> CREEP TEST 251 JAD 920513

DEVICE #	TEST	BASE DIM.	CUP-PIN	PRE-LOAD	CONDITION	
223-15-01	IMPULSE	89	96	7	OK	
223-15-02		89	96	7	OK	
223-15-03		89	96	7	CREEP	
223-15-04		90	96	6	CREEP	
223-15-05		92	96	4	CREEP	
223-15-06		91	95	4	CREEP	
223-15-07		90	96	6	OK	
223-15-08		99	96	7	CREEP	PRELOAD $\bar{X}$
223-15-09		91	95	4	CREEP	5.33
223-15-10		90	96	6	CREEP	
223-15-11		91	96	5	CREEP	
223-15-12		91	96	5	CREEP	
223-15-13		90	96	6	OK	
223-15-14		90	96	6	CREEP	
223-15-15		90	96	6	CREEP	
223-15-16		91	96	5	CREEP	
223-15-17		93	96	3	CREEP	
223-15-18		91	96	5	CREEP	
223-15-19	V	92	96	4	CREEP	
223-15-37	TERM.	87	96	9	OK	
223-15-38	STRENGTH	86	96	10	OK	
223-15-39		87	96	9	OK	
223-15-40		87	96	9	OK	
223-15-41		90	96	6	OK	
223-15-42		88	96	8	OK	PRELOAD $\bar{X}$
223-15-43		87	96	9	OK	9.08
223-15-44		86	96	10	OK	
223-15-45		86	97	11	OK	
223-15-46		87	96	9	OK	
223-15-47		86	96	10	OK	
223-15-48	V	88	97	9	OK	
223-15-49	T-CYCLE	87	95	8	OK	
223-15-50		88	96	8	OK	
223-15-51		88	96	8	OK	PRELOAD $\bar{X}$
223-15-52		91	96	5	OK	7.33
223-15-53		89	96	7	OK	
223-15-54	V	88	96	8	OK	

-MSG M# 02147611 FR=FFUN TO=8801 SENT=07/31/92 01:47 PM  
R#083 ST=C DIV=0050 CC=00101 BY=FFUN AT=07/31/92 01:47 PM  
dra92-43

TO: Dave Szarn  
Matt Sellers  
Steve Offiler

FR: Dale Rogge

SU: Tolerance on 6.5mil preload target.

Question: When rework is sent back through the line how close must the bases be to the target preload of 6.5mils. The line currently assumes it must be within +/-0.1mils.

Answer: Rework can take place if the target for the run is within -0.0 to +0.5 mils. ie 6.5 to 7.0.

All production can also be built to this spec.

Justification: At 6.5 mils the conservatively assumed high temp shift of -4 produces actuations as low as 85psi at 150C. At low temps the assumed shift produces actuation at 175psi. This indicates that there is some room to move the target towards 7.0 mils which would produce 190psi actuation which is just below the spec of 200psi.

At high temps we are well below the spec of 90psi. If we assume a more realistic number of 3 mils for high temp shift then we get 90psi at 150C, just meeting the spec. This indicates that we cannot target anything below 6.5mils.

These calculations work so long as the sensor assembly switches in the 130-140psi range. If the disc drops it down to 120psi we would fall below the 90psi spec again. Then the preload target should shift upwards to match the changing disc. Tying the target and the act and rel specs to the disc at this point is not recommended because of the complexity it adds. It may need to be considered in the future so that production is not always running in and asking for a spec modification because of a change in the lots.

Note: We recently have a lot running low. For this lot we reduced the lower spec limit on act. from 110 to 105psi, without making any change in the target preload. These parts maybe a problem at high temps.

Regards,  
Dale

TI-NHTSA 006340

## QUIET SWITCH STUDIES ALTERNATIVE CONFIGURATIONS

### PURPOSE

There is a need for a quiet cruise control pressure switch to prevent noises from being transmitted into the passenger compartment. A silent switch was developed by using a low differential disc. This quiet switch is assigned part number 77psi3-1. During the development of this switch a number of alternative configurations were investigated in the hope of finding a simpler solution to control sound. This report describes the results of tests on the alternative configurations.

### CONFIGURATIONS

Seven configurations were tested. Six with a noisy wide differential disc (standard production disc).

A) A sheet of 0.003" thick silicone rubber was placed between the converter and the cup (figure 1). The theory was that the converter maybe hitting the cup when the disc snaps and the impact generates a noise.

B) A sheet of 0.003" thick silicone rubber was placed between the disc and the converter (figure 1). The theory was to see if the sound generated by the disc could be blocked from transmitting to the converter.

C) A sheet of 0.0003" thick silicone rubber was placed between the converter and the washer (figure 1). The theory was that when the converter impacts the washer on switch release that it generates a sound.

D) A metal labyrinth was installed inside the hexport, just below the diaphragm. The theory was that by proper acoustical tuning the passage could be made to absorb the sound wave as it tried to travel down the passage. The labyrinth consisted of two brass pieces with horizontal slots cut in them. The pieces were stacked so as to create a "Z" channel (figure 2).

E) A rubber labyrinth with four holes was installed inside the hexport, just below the diaphragm (figure 3). This was an advancement on the theory behind #4, in that the rubber would provide more absorption. The rubber piece also tried to take advantage of the sloped walls of the hexport to reflect the sound wave. The rubber piece design was selected to have a manufacturable shape.

F) Same as 5 except for 2 holes.

TI-NHTSA 006341

TEST LOT NO.	TEST	DEVICE
TESTED BY <i>Mike J...</i>	SPENCER PRODUCTS - METALS & CONTROLS DIVISION TELME INSTRUMENTS INCORPORATED ATLANTON, MASSACHUSETTS	DOC.
APPROVED BY		PAGE <i>10 of 13</i>
DATE <i>8/3/78</i>		

G) A hex shaped metal insert to create a snubber (figure 4). The theory is that the hydraulic fluid cannot fill the void left by the instantaneous disc snap as quickly, thus slowing down the hydraulic turbulence that creates sound. This was tested with a quiet disc to see if it could be made more quiet.

#### EVALUATION METHOD

Each piece was tested by ramping air from 0-400psi at a fixed rate till the switch actuated. There was a microphone located in the tubing just below the switch to listen for the sound. The microphone was attached to a B&K spectrum analyzer. for some of the tests there was also an accelerometer attached to the top of the cup to measure the acceleration generated by the snap. The spectrum analyzer was used to measure the intensity of the sound and to look for resonances.

Later a test was devised to measure the sound in a hydraulic system using a high frequency pressure transducer. Some of the pieces were evaluated with this method. In all cases the sound level was compared to a know noisy switch to evaluate the effect of the change. On the hydraulic system the sound level is defined by the magnitude of the negative pressure pulse generated when the fluid tries to rush in and fill the void left by the disc snap. A noisy switch is typically -40psi. A quiet switch is 0.0psi.

#### RESULTS

The intensity plots for a standard noisy switch are shown in figure 5. The top scale shows the magnitude of the acceleration. The bottom scale shows the magnitude of the sound. The setup was not calibrated so the scales are for relative comparison only. From the plot it is clear that sound is generated in the 700 to 2k frequency range.

Figure 6 shows the same plot for a quiet switch using a low differential disc. The magnitude of the acceleration and sound has decreased by 2/3rd's. This is called a moderately quiet switch. During later testing with the hydraulic system it was determined that even this sound level was to loud. An even lower differential disc was developed. The lower differential disc was not measured with air because the sound could not be detected.

Case A) The rubber between the convertor and the cup did not show a noticeable decrease in the sound level. No plot is available because the plotter malfunctioned.

TI-NHTSA 006342

TEST LOT NO.	TEST	DEVICE
TESTED BY		
APPROVED BY		DOC.
DATE		PAGE 2 of 13

PR 5288

SPENCER PRODUCTS - METALS & CONTROLS DIVISION  
TEXAS INSTRUMENTS INCORPORATED  
ATYLBROW, MASSACHUSETTS

Case B) The rubber between the disc and converter did reduce the sound level as seen in figure 7. The level is approximately the same as the moderate quiet switch. Figure 8 shows the same switch plotted as intensity vs time. This shows that a sound pulse is still being generated.

Case C) The rubber between the converter and the washer is shown in figures 9 & 10. Again the sound is reduced, in this case slightly more than even the previous case.

Case D) The metal labyrinth did not reduce the level (figure 10). A slight increase in the sound level was noted.

Case E) The rubber 4 hole plug was tested hydraulically because no sound could be detected with air. It had a -38.8psi pulse, just as noisy as the standard noisy part. This piece was also tested by FORD on a SHO taurus and deemed to be noisy.

Case F) The 2 hole rubber part had a pulse of -27.6psi. Quieter than the 4 hole but still noisy.

Case G) The metal hex snubber insert a no sound, pulse level was 0.0psi. This part was tested by FORD on a SHO taurus, and deemed quiet. Note this had a quiet disc.

#### DISCUSSION

During the development of the quiet switch it was determined that any noisy detected on an air system is too much. This means that cases A-D will not work.

Case E & F were rejected because the vehicle test showed they were noisy.

Case G was not expected to be noisy because it had a quiet disc. If the quiet disc without a snubber is at zero sound then it cannot be reduced by additional snubbing. This piece shows that a snubber really offers no benefit.


Based on these results the decision was made to convert to a quiet disc without any other changes. It was chosen because it was the only solution that FORD brake engineers felt was quiet enough and had a low enough feet.

#### CONCLUSION

A wide selection of creative solutions to control switch sound were tested. The only solution that was quiet was a low differential disc. This solution was implemented at the start of production in June of 1992.

TI-NHTSA 006343

TEST LOT NO.	TEST	DEVICE
TESTED BY		
APPROVED BY		SPENCER FREQUENT - METALS & CONTROLS DIVISION TEXAS INSTRUMENTS INCORPORATED ATLANTA, GEORGIA
DATE		DOC. PAGE 3 of 13




CONFIDENTIAL

TI-NHTSA 008344

TEST LOT NO.	TEST	FIGURE 1	DEVICE
TESTED BY	SPENCER PRODUCTS - METALS & CONTROLS DIVISION TEXAS INSTRUMENTS INCORPORATED ATLANTA, MASSACHUSETTS		DOO.
APPROVED BY			PAGE 4 of 13
DATE			

FR 1288




CONFIDENTIAL

TI-NHT8A 006345


CASE D  
FIGURE 2

TEST LOT NO.	SPENCER PRODUCTS - METALS & CONTROLS DIVISION TEXAS INSTRUMENTS INCORPORATED APL, EDSON, MASSACHUSETTS	DEVICE
TESTED BY		DOD.
APPROVED BY		PAGE 2 of 13
DATE		

PR 5286



80 DURO RUBBER




TI-NHTSA 006346

TEST LOT NO.	TEST CASE E	SERVICE
TESTED BY	FIGURE 3	
APPROVED BY	BRINCA PRODUCTS - WEYALE & COMPANY'S DIVISION TEXAS INSTRUMENTS INCORPORATED ATLANTA, GEORGIA, MASSACHUSETTS	DOC.
DATE		PAGE 6 of 13

PR 588

0



CONFIDENTIAL

TI-NHTSA 006347

CASE 6

TEST LOT NO.	TEST PIONE 4	DEVICE
TESTED BY	SPENCER PRODUCTS - METALS & CHEMICALS DIVISION TESTING INSTRUMENTS DEPARTMENT ATLANTA, GEORGIA	DOC.
APPROVED BY		PAGE 10/13
DATE		

TEST LOG NO. \_\_\_\_\_  
 TESTED BY \_\_\_\_\_  
 APPROVED BY \_\_\_\_\_  
 DATE \_\_\_\_\_

TEST

PRINCIPAL PRODUCTS - MICROPHONIC  
 TESTS PERFORMED BY S. J. JONES  
 ATTY. GENERAL, MANASSASVILLE

Q100  
 PAGE 88115

Q100



Brüel & Kjær

Type 2034

Page No. 30

Sign.:



Meas. Object:

*DE RETURN  
 JMW RAMP  
 ACV = 134psi  
 REL = 58  
 AIR*

Comments:

*A = MICROPHONE  
 B = ACCELEROMETER  
 (unlabeled)  
 noisy swirl*

W1 INST SPEC CH. B MAG INPUT MAIN Y: 19.4mU  
 Y: 50.0mU RMS LIN X: 1784Hz  
 X: 64Hz TO 8.4kHz LOG  
 SETUP W1



W1 INST SPEC CH. A MAG INPUT MAIN Y: 189mU  
 Y: 10.0U RMS LIN X: 1784Hz  
 X: 64Hz TO 8.4kHz LOG  
 SETUP W1

TI-NHTSA 006348

PM 1584

TEST LOT NO. B  
 TESTED BY [Signature]  
 APPROVED BY [Signature]  
 DATE



  
 (U) & K Jar  
 Type 2034  
 Page No. 45  
 Sign. i  
 Desc. Object: Q2 QUIET SWIRT  
 FREQUENCY  
 SCAN RANGE AIR  
 TRUCK DRG?  
 Comments: QUIET SWIRT

SPRINGER PRODUCTS - SERIAL & PART NO. DIVISION  
 TEST INSTRUMENTS INFORMATION  
 ATTENTION, CALIBRATION

DOO.  
 PAGE 2/13

W1 INST SPEC CH. B MAG  
 Y: 50.0mU RMS LIN  
 X: 120Hz TO 12.0kHz LOC  
 SETUP W1

MAIN Y: 88.5mU  
 X: 1138Hz



INST SPEC CH. A MAG INPUT MAIN Y: 1.98U  
 Y: 10.0U RMS LIN X: 1138Hz  
 X: 120Hz TO 12.0kHz LOC  
 SETUP W2 OVERLOAD

TL-NHT8A 00349

PM 5285

TEST LOT NO. \_\_\_\_\_  
 TESTED BY \_\_\_\_\_  
 APPROVED BY \_\_\_\_\_  
 DATE \_\_\_\_\_

TEST

SHOWN PRODUCTS - TESTED & APPROVED  
 TEST INSTRUMENTS INSPECTION  
 ATTENTION, MANAGEMENT

DOC. \_\_\_\_\_  
 PAGE 10/215

DEVICE \_\_\_\_\_



Type 2034

Page No. 47

Sign.:



Make, Object:

82-ALU-8/1  
MILIC COMPANY  
RETENTION  
ALU

Comments:

RUBBER BETWEEN  
DISC & COMBARS

W1 INST SPEC CH. B MAG INPUT MAIN Y1 5.86mU  
 Y1 50.0mU RMS LIN X1 1824Hz  
 X1 128Hz TO 12.8kHz LOG  
 SETUP W1 OVERLOAD



W1 INST SPEC CH. A MAG MAIN Y1 1.24U  
 Y1 10.0U RMS LIN X1 1824Hz  
 X1 128Hz TO 12.8kHz LOG  
 SETUP W1 OVERLOAD

TI-NHTSA 006360

CASE B  
FIGURE 7

PN 5288

TEST LOT NO. \_\_\_\_\_  
 TESTED BY \_\_\_\_\_  
 APPROVED BY \_\_\_\_\_  
 DATE \_\_\_\_\_

TEST

Page No. 87

Sign. \_\_\_\_\_

Neas. Object:

RZ ARIATION  
PA  
RUBBER DRIVE  
CONVERTER

Comments:

10mV/g  
3/12/92  
RUBBER DRIVE  
DISC & CONVERTER

DOOR

PAGE 11/875



Brüel & Kjær

Type 2034

Page No. 87

Sign. \_\_\_\_\_



Neas. Object:

RZ ARIATION  
PA  
RUBBER DRIVE  
CONVERTER

Comments:

10mV/g  
3/12/92  
RUBBER DRIVE  
DISC & CONVERTER

W1 TIME CH. A REAL INPUT MAIN Y<sub>1</sub> -8.55mV  
 Y<sub>1</sub> 15.00  
 X<sub>1</sub> 99.978ms + 31.3ms  
 SETUP W1 OVERLOAD



W1 TIME CH. B REAL MAIN Y<sub>1</sub> -1.110  
 Y<sub>1</sub> 30.00  
 X<sub>1</sub> 99.978ms + 31.3ms  
 SETUP W1 OVERLOAD

CASE B

TI-NHTSA 008351

TEST LOT NO.  
 TESTED BY  
 APPROVED BY  
 DATE

TEST

MEASUREMENTS - INTERNAL & EXTERNAL DIMENSIONS  
 TOLERANCES UNLESS OTHERWISE SPECIFIED  
 ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED

DEVICES

DATE 12/27/73



Brüel & Kjær

Type 2034

Page No.  
40

Sign.:

Meas. Object:

R3 DETENTION  
 PIA  
 NEW PUMP  
 RUBBER BETWEEN  
 PLS 1. DETENTION



Comments:

RUBBER BETWEEN  
 CONCRETE &  
 WATERS

INST SPEC CH. B MAG  
 Y: 50.0mV RMS LIN  
 X: 64Hz TO 6.4kHz  
 SETUP W1 OVERLOAD

INPUT

MAIN Y: 10.0mV  
 X: 1818Hz



W1 INST SPEC CH. A MAG  
 Y: 10.0uV RMS LIN  
 X: 64Hz TO 6.4kHz  
 SETUP W1 OVERLOAD

LOC

MAIN Y: 20.0mV  
 X: 1818Hz

TI-NHTSA 006362

CASE C  
 FIGURE 9

PM 588

TEST LOT NO.  
TESTED BY  
APPROVED BY  
DATE



Brüel & Kjaer

Type 2034

TEST  
BRÜEL & KJÆR PRODUCTS - SERIAL & GENERAL SERVICE  
FIELD INVESTIGATIVE INSTRUMENTS  
ATTACHMENT, IMPROVEMENTS

Page No.  
B4

Sign.:

Head.  
Object:

R3 ACQUISITION  
FR  
rubber hammer  
use & conversion



Comments:

spec/1 MS  
RUBBER HAMMER  
CONVERSION &  
WALLET

SERVICE  
PAGE 13 OF 13

W1 TIME CH. A REAL  
Y: 2.50U  
X: 0.00ms + 500ms  
SETUP W1 OVERLOAD

MAIN Y: 9.32E-9U  
X: 0.00ms



W1 TIME CH. B REAL INPUT  
Y: 15.0U  
X: 0.00ms + 500ms  
SETUP W1 OVERLOAD

MAIN Y: -2.27U  
X: 0.00ms

TI:HTSA 006363

CASE C

QUIET SWITCH FINAL ASSEMBLY  
 PRE-LOAD TARGET = .0066 TO .007  
 VALID FINAL ASSEMBLY MATRIX'S

SENSOR LOT X-BAR x .001"		SENSOR LOT CODE	BASE CHECK SELECTION TABLE BY PIN SIZE BASE CHECK TOLERANCE IS +/- .001"							
FROM	TO		140	141	142	143	144	145	146	
42.5	43	A	89.5	91.5	92.5	93.5	94.5	95.5	96.5	
43.5	44	B	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
44.5	45	C	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
45.5	46	D	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
46.5	47	E	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
47.5	48	F	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
48.5	49	G	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
49.5	50	H	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
PRE-LOAD ".007"	PRE-LOAD ".0066"	I	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
		J	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
		K	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
		L	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
		M	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
		N	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
		O	89.5	90.5	91.5	92.5	93.5	94.5	95.5	
			STANDARD LOW GAGE		STANDARD HIGH GAGE					

TI-NHTSA 006354

MJS QUIET PRE-LOAD.XLS

REVISION A  
8/3/92



PROCESS POTENTIAL AND QUALITY INDEXES SUMMARY DATA SHEET

PART #: F2AC-9F924-AA  
SUPPLIER: TEXAS Fasteners  
CODE: T0258  
ADDRESS: 34 FOREST ST.  
ATTLEBORO MA  
VEHICLE BUILD: EP VP FB OTHER

SUPPLIER CONTACT: Jim Watt  
CONTACT PHONE: (508) 698-1119  
PART DESCRIPTION: Next Generation  
Speed Control Deactivation Safety Switch  
SQA CODE:  
VEHICLE PROGRAM: PASS CAR

CHARACTERISTIC TYPE

▽ = FORD CRITICAL CHARACTERISTICS

S.C. = FORD OR SUPPLIER SIGNIFICANT CHARACTERISTICS

NUMBER OF CRITICAL AND SIGNIFICANT CHARACTERISTICS:

1:	<u>Actuation Pressure</u>	TYPE: <u>SC</u>	Cp = <u>**</u>	Cpk = <u>**</u>
2:	<u>Release Pressure</u>	TYPE: <u>SC</u>	Cp = <u>**</u>	Cpk = <u>**</u>
3:	<u>3/8-24 UNE-2A THL.</u>	TYPE: <u>SC</u>	Cp = <u>A*</u>	Cpk = <u>A*</u>
4:		TYPE:	Cp =	Cpk =
5:		TYPE:	Cp =	Cpk =
6:		TYPE:	Cp =	Cpk =
7:		TYPE:	Cp =	Cpk =
8:		TYPE:	Cp =	Cpk =
9:		TYPE:	Cp =	Cpk =
10:		TYPE:	Cp =	Cpk =
11:		TYPE:	Cp =	Cpk =
12:		TYPE:	Cp =	Cpk =
13:		TYPE:	Cp =	Cpk =
14:		TYPE:	Cp =	Cpk =
15:		TYPE:	Cp =	Cpk =

PIST =  $\frac{1833}{1833} \times 100 = 100\%$

PIPC<sub>Cp</sub> = \_\_\_\_\_ x 100 = \_\_\_\_\_ %    PIPC<sub>Cpk</sub> = \_\_\_\_\_ x 100 = \_\_\_\_\_ %

COMMENTS:

\*\* Calibration check is done 100%. Parts tested 300; defective 0. percent of defect 0.  
A\* Threads are checked on a Go/NoGo Gage

PREPARED BY: ELAINE ROSE

DATE: 8-7-92

**DRAWINGS AVAILABLE UPON  
REQUEST**

CRIMP TEST

1  
2  
3  
4  
5

6  
7  
8  
9  
10

CRIMP H.T.

- ① 536
- ② 537
- ③ 538
- ④ 537
- ⑤ 537

- ⑥ 536
- ⑦ 537
- ⑧ 540
- ⑨ 538
- ⑩ 541

120° STILL CON.

150° STILL CON.

TORQUE 2

- ⑥ 11
- ⑦ 13
- ⑧ 11
- ⑨ 13
- ⑩ 15

needed adj. wrench  
to take out of spec

needed adj. wrench  
to take out of spec

CRIMP HT 2

- ① 536
- ② 537
- ③ 540
- ④ 538
- ⑩ 540

All devices  
can be  
turned w/ hand.

538  
537  
537  
538  
537

100  
100  
100  
100

100  
100  
100  
100

100  
100  
100

NOT EXCEED POINTS FOR WEIGHT ON FILLING 0

RECYCLE COUNTY	2
PRESTON PRESS	6000 PSI
MAX THER TIME	1500 PSI
NET THER TIME	2500 PSI
MAX MILLWALL	2000 PSI
DIFFERENTIAL	0.0 TO 300.0 PSI
REVERSE	0.50 TO 140.0 PSI
MAXIMUM	2000 PSI
LIMIT (INT.)	0.0
WIND MEAN W/T	0.0 MEAN FILL
WINDS (2) LB	0.00
HEAT DATA	

LOT 111104  
LOT 111104  
LOT 111104

775 PRESSURE TESTER LOT REPORT

100  
100  
100  
100

100  
100  
100  
100

10 Devices

- Serial Rec
  - Torque TEST
  - And
  - Crimp Height
- 1 → 10  
Rig

→ Hi temp TEST

→ 120°C 1/2 hour CONT.

→ 150°C 1/2 hour CONT

→ Torque TEST  
Crimp height:

- 1 SER 1; PIX 1; LE 000000; SINGLES; WIND=45.4; WRFD=45.7; LEAK RATE= 1.4  
 WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4; WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4
- 2 SER 2; PIX 2; LE 000000; SINGLES; WIND=45.4; WRFD=45.7; LEAK RATE= 1.4  
 WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4; WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4
- 3 SER 3; PIX 3; LE 000000; SINGLES; WIND=45.4; WRFD=45.7; LEAK RATE= 1.4  
 WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4; WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4
- 4 SER 4; PIX 4; LE 000000; SINGLES; WIND=45.4; WRFD=45.7; LEAK RATE= 1.4  
 WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4; WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4
- 5 SER 5; PIX 5; LE 000000; SINGLES; WIND=45.4; WRFD=45.7; LEAK RATE= 1.4  
 WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4; WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4
- 6 ~~SER 6; PIX 6; LE 000000; SINGLES; WIND=45.4; WRFD=45.7; LEAK RATE= 1.4~~  
~~WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4; WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4~~
- 7 SER 7; PIX 7; LE 000000; SINGLES; WIND=45.4; WRFD=45.7; LEAK RATE= 1.4  
 WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4; WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4
- 8 SER 8; PIX 8; LE 000000; SINGLES; WIND=45.4; WRFD=45.7; LEAK RATE= 1.4  
 WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4; WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.4
- 9 SER 9; PIX 9; LE 000000; SINGLES; WIND=45.4; WRFD=45.7; LEAK RATE= 1.7  
 WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.7; WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.7
- 10 SER 10; PIX 10; LE 000000; SINGLES; WIND=45.4; WRFD=45.7; LEAK RATE= 1.7  
 WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.7; WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.7
- 11 SER 11; PIX 11; LE 000000; SINGLES; WIND=45.4; WRFD=45.7; LEAK RATE= 1.7  
 WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.7; WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.7
- 12 SER 12; PIX 12; LE 000000; SINGLES; WIND=45.4; WRFD=45.7; LEAK RATE= 1.7  
 WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.7; WIND: 45.4; WRFD: 45.7; LEAK RATE: 1.7

8/5/92



From Lot #112 7785L3-1 8/1/92  
 Lot 112 had 1 Hi temp failure

- ① 10 devices each box (2) perform Torque test.
- ② Same 10 devices From each box dis-Assemble and measure Calculated Spring pre-load.

	Torque	PIN	BASE	SENSOR	Preload
1.	16	142	88	474	.0066
2.	17	142	89	473	.0057
3.	18	142	88	470	.0070
4.	15	142	89	471	.0059
5.	16	143	89	469	.0071
6.	13	143	89	470	.0069
7.	12	142	89	467	.0063
8.	16	142	89	470	.0066
9.	14	142	89	470	.0066
10.	13	142	89	470	.0066
11.	13	143	88	470	.0080
12.	15	142	88	465	.0075
13.	16	142	89	469	.0061
14.	15	143	89	473	.0067
15.	15	142	89	467	.0063
16.	15	142	89	464	.0066
17.	14	142	89	462	.0066
18.	12	142	89	469	.0059

**TEXAS  
INSTRUMENTS**



**ISIR SUBMISSION**

**TO DANA CORPORATION  
FOR PART NUMBER F2AC-9F824-AA  
NEXT GENERATION  
SPEED CONTROL DEACTIVATION SAFETY SWITCH**

**AUGUST 4, 1982**

# TEXAS INSTRUMENTS



August 20, 1992

Dana Corporation  
Weatherhead Division  
109 Increment Street  
St. Thomas, Ontario  
Canada M5P3G6

Attn: Mr. Jerry Garber  
Quality Manager


Subj: Part Number F2AC-9F924-AA (Pressure Switch)  
TI Part Number 77PSL3-1

Dear Jerry,

Enclosed, please find the ISIR for the F2AC-9F924-AA pressure switch. An identical ISIR package has also been forwarded to the Dana Angola, Indiana facility.

Please let me know if you have any questions or if I may be of any further assistance.

Regards,

  
Jim Matt  
QRA Engineer  
Precision Controls Department  
Control Products Division

cc: Dave Czarn, MS 12-29; Steve Offiler, MS 12-29  
Rick Conlin, MS 12-33; Gary Snyder, MS 12-33  
Andy McGuire, MS 12-27  
Grant Simons, Dana Purchasing Dept., Ontario, Canada  
Norm Frada, TI Farmington Hills, Michigan

enc: ISIR submission F2AC-9F924-AA

# TEXAS INSTRUMENTS



August 20, 1992

Dana Corporation  
Weatherhead Division  
203 Weatherhead Street  
Angola, Indiana 46703

Attn: Mr. Lynn Johnson  
Quality Manager

Subj: Part Number F2AC-9F924-AA (Pressure Switch)  
TI Part Number 77PSL3-1

Dear Lynn,

Enclosed, please find a copy of the ISIR for the F2AC-9F924-AA pressure switch. The original ISIR package has been forwarded to Dana Ontario, Canada facility.

Please let me know if you have any questions or if I may be of any further assistance.

Regards,

  
Jim Watt  
QRA Engineer  
Precision Controls Department  
Control Products Division

cc: Dave Czern, MS 12-29; Steve Offilar, MS 12-29  
Rick Conlin, MS 12-33; Gary Snyder, MS 12-33  
Andy McGuirk, MS 12-27  
Mike Rogers, Dana Purchasing Dept., Angola, Indiana  
Norm Frede, TI Farmington Hills, Michigan

encl: ISIR submission F2AC-9F924-AA

REPORT OF IFR TESTING  
 FORD PASSENGER CAR  
 ELECTRONIC SPEED CONTROL  
 DEACTIVATION PRESSURE SWITCH  
 75/92/82

TEXAS INSTRUMENTS INCORPORATED  
 CONTROL PRODUCTS DIVISION  
 PRECISION CONTROLS DEPARTMENT  
 34 FOREST STREET  
 ATTLEBORO, MA 02703

TEST LOT NO.	TEST	DEVICE
TESTED BY	 <b>TEXAS INSTRUMENTS</b>	DOC.
APPROVED BY <i>[Signature]</i> DATE 02-08-82		MATERIALS & CONTROLS GROUP ATTLEBORO, MA 02703 PAGE 1

FORM 5290

TABLE OF CONTENTS

1.0	GENERAL .....	3
2.0	OBJECTIVE .....	4
3.0	TEST PROCEDURES AND RESULTS .....	4
3.1	CALIBRATION .....	4
3.2	VOLTAGE DROP .....	5
3.3	CURRENT LEAKAGE .....	6
3.4	PROOF .....	7
3.5	IMPULSE .....	7
3.6	BURST .....	8
3.7	HUMIDITY .....	9
3.8	SALT SPRAY .....	9
3.9	VIBRATION .....	9
3.10	TERMINAL STRENGTH .....	10
3.11	VACUUM .....	10
3.12	TEMPERATURE CYCLE .....	11
3.13	FLUID RESISTANCE .....	11
3.14	NOISE .....	12
4.0	APPENDICES	
4.1	Ford Engineering Specification (inv delta) ES-F2VC-9F924-AA .....	14
4.2	Data .....	33
4.3	Noise Pressure Trace .....	39

TEST LOT NO.	TEST	DEVICE
TESTED BY	 <b>TEXAS INSTRUMENTS</b>	DOC.
APPROVED BY		MATERIALS & CONTROLS GROUP ATTLEBORO, MA 01703
DATE	11-21-77	PAGE 2

FORM 8225

1.0 GENERAL

1.1 Customer: Ford Motor Company P.L.A. from Dana-Weatherhead

1.2 Part Numbers:

1.2.1 Ford P/N: F2AC-9F924-AA

1.2.2 Dana P/N: 120-55046

1.2.3 TI P/N: 7798L3-1

1.3 Engineering Specification: (inv delta) ES-F2VC-9F924-AA

1.4 Date of Completion: 920811

1.5 Quantity of Units Tested: 72

1.6 Disposition of Tested Units: All devices are presently retained under quarantine, completely separate from any production devices, to be destroyed per the ES at a later date after full ISR approval is obtained.

1.7 TI test series number: 245-15-129

1.8 TI Pressure Switch test report number: PS/92/82

TEST LOT NO.	TEST	DEVICE
TESTED BY	<b>TEXAS INSTRUMENTS</b> 	DOC.
APPROVED BY		MATERIALS & CONTROL GROUP
DATE 92-08-11		ATTLEBORO, MA 01701
		PAGE 1

FORM 228

## 2.0 OBJECTIVE

This testing was performed to demonstrate the ability of 77P8L3-1 to conform to customer specifications given in (inv delta) ES-F2VC-9F924-AA, in fulfillment of the requirements of the Initial Sample Report. Units tested were built using fully qualified production components and production assembly equipment.

## 3.0 TEST PROCEDURES AND RESULTS

All switches were tested per Ford Engineering Specification (inv. delta) ES-F2VC-9F924-AA. A copy of this ES is included in Appendix 4.1. Procedural details are therefore omitted from the presentation of results in most cases. In those instances where the ES procedure methodology requires elaboration, a complete explanation of the procedure is presented. For all tests, raw data is included in Appendix 4.2.

### 3.1 CALIBRATION

3.1.1 Devices tested: 245-15-01 thru 72

3.1.2 Procedure: Calibration is checked at room temperature using ambient air as the pressure medium. Calibration settings, as specified on the part drawing, are actuation (electrical contacts opening) at 90 - 160 psig, and release (contacts reclosing) at 20 psig minimum. For the purpose of stabilization, actuation values are recorded on the sixth cycle, after subjecting the switch to two (2) pressure cycles to 800 psig minimum and back to zero, followed by three (3) cycles to approx. 10% above actuation pressure and back to approx. 10% below release pressure. The change in continuity is measured while conducting 750 +/- 50 milliamps at 13.0 +/- 1.0 volts DC.

TEST LOT NO.	TEST	DEVICE
TESTED BY	<b>TEXAS INSTRUMENTS</b>  MATERIALS & CONTROLS GROUP ATTLERBORO, MA 01708	DOC.
APPROVED BY		PAGE
DATE 81-08-17		

FORM 8298

3.1.3 Equipment: Custom TI designed and built pressure check station, using Heise Model CM96365 pressure gage calibrated on a regular quarterly schedule. Continuity change measured on custom TI designed and built equipment meeting the above electrical parameters.

3.1.4 Initial Results: Prior to proof testing, the average actuation was found to be 126 psi with a sigma of 6.2; after proof the average actuation was 131 psi with a sigma of 4.9. The average shift is 4%. Prior to proof testing, the average release was found to be 113 psi with a sigma of 6.5; after proof the average release was 119 psi with a sigma of 5.7. The average shift is 5%.

3.1.5 Final Results: Prior to proof testing, the average actuation was found to be 130 psi with a sigma of 5.4; after proof the average actuation was 129 psi with a sigma of 5.3. The average shift is -0.8%. Prior to proof testing, the average release was found to be 108 psi with a sigma of 7.7; after proof the average release was 108 psi with a sigma of 6.6. The average shift is 0.

### 3.2 VOLTAGE DROP

3.2.1 Devices tested: 245-15-01 thru 72

3.2.2 Procedure: Voltage drop is checked simultaneously with Calibration (see 3.1.2). The measurement is taken at room temperature using ambient air as the pressure medium. For the purpose of stabilization, data is recorded on the sixth cycle, after subjecting the switch to two (2) pressure cycles to 800 psig minimum and back to zero, followed by three (3) cycles to approx. 10% above actuation pressure and back to approx. 10% below release pressure. The voltage drop is measured while conducting 750 +/- 50 milliamps at 13.0 +/- 1.0 volts DC.

TEST LOT NO.	TEST	DEVICE
TESTED BY	TEXAS INSTRUMENTS 	DOC.
APPROVED BY		MATERIALS & CONTROLS GROUP ATLLEBORO, MA 02740
DATE 02-08-11		PAGE

FORM 5200

- 3.2.3 Equipment: Fluke Model 8020B Digital Multimeter, calibrated quarterly, used in conjunction with the continuity equipment in 3.1.3.
- 3.2.4 Initial results: Values for all devices fell below the specification of 200 millivolts maximum by close to two orders of magnitude; no specific statistics calculated for this reason.
- 3.2.5 Final results: With the exception of parts undergoing Impulse testing (devices 245-15-01 thru 12 and -37 thru 49), all final results were comparable with initial results. The Impulse parts experience an increase in the voltage drop reading due to the specified 25,000 cycles run at full electrical load, which causes a certain amount of normal erosion of the contact surfaces. All 24 Impulse devices still fell significantly below 200 mV maximum, and statistics show a Cpk of 2.53.

### 3.3 CURRENT LEAKAGE

- 3.3.1 Devices tested: 245-15-01 thru 72
- 3.3.2 Procedure: Per the ES section III. C. This test is conducted as a pass/fail.
- 3.3.3 Equipment: Associated Research HyPot test unit used as power source for 500 VAC, 60 Hz test circuit. Fluke Model 8020B Digital Multimeter, calibrated quarterly, used to measure voltage drop across a series resistance of one megohm (+/- 5%).
- 3.3.4 Initial results: All devices passed.
- 3.3.5 Final results: All devices passed.

TEST LOT NO.	TEST	DEVICE
TESTED BY	 <b>TEXAS INSTRUMENTS</b>	DOC.
APPROVED BY		PAGE
DATE 12-08-17		MATERIALS & CONTROLS GROUP ATTLEBORO, MA 01703

FORM 8200

### 3.4 PROOF

- 3.4.1 Devices tested: 245-15-01 thru 72
- 3.4.2 Procedure: Per the ES section III. D. This test is conducted as a pass/fail. The test pressure specified on the part drawing is 3000 psi.
- 3.4.3 Equipment: Enerpak model P-392 hydraulic hand pump using Enerpak hydraulic fluid as the pressure medium. Hydraulic fluid is removed from the devices using a combination of vacuum and residue-free solvent Sprayon(TM) Hi-Tech 02002 TF Electrical Contact Cleaner. US Gauge #33714 reading to 5000 psig with 100 psi increments, resolvable to 50 psi., calibrated quarterly. Custom TI designed and built safety enclosure.
- 3.4.4 Initial Results: All devices passed.
- 3.4.5 Final Results: All devices passed.

### 3.5 IMPULSE

- 3.5.1 Devices tested: 245-15-01 thru 12 and -37 thru 48
- 3.5.2 Procedure: Per the ES section III. E.
- 3.5.3 Equipment: Thermotron model S-4 Mini-Max environmental chamber capable of -55 C to +200 C, humidity uncontrolled. Custom TI designed and built cycler, utilizing Enerpak integrated hydraulic pressure source, TI315 Programmable Logic Controller, Moog servovalve and controller, Simpson signal generator, and opposing-piston fluid isolators, to produce a hydraulic-fluid flow-type primary with a brake-fluid dead-end-type secondary terminated with a 24-station manifold equipped with internal heaters. Capability to 5 Hz at 0-1450 psig cycle. Custom TI designed and built 24 station Switch

TEST LOT NO.	TEST	DEVICE
TESTER BY		
APPROVED BY	<b>TEXAS INSTRUMENTS</b> 	DOC.
DATE 22-02-17		ATLAPORD, MA 02108

FORM 5296

Monitor Circuit which automatically stops the cycler in the event of abnormal switch action, defined as continuity change which does not track the signal from the signal generator. Thermocouple readouts calibrated quarterly. 12-station inductive load bank, per the schematic found in the ES (figure 4) used in the last 25K cycles.

3.5.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

**3.6 BURST**

3.6.1 Devices tested: 245-15-67 thru 72.

3.6.2 Procedure: Per the ES section III. F. After holding 7000 psi for 30 seconds as specified, the devices were inadvertently pressurized to approx. 7600 psi.

3.6.3. Equipment: Same as 3.4.3, with the addition of Enerpak gauge reading to 10,000 psig with 100 psi increments, resolvable to 50 psi., calibrated quarterly.

3.6.4. Results: All six devices passed 30 seconds at 7000 psig without evidence of fluid leakage or seepage from the switch or threads.

At 7600 psi, one device (-70) displayed evidence of fluid seepage.

TEST LOT NO.	TEST	DEVICE
TESTED BY	 <b>TEXAS INSTRUMENTS</b>	DOC.
APPROVED BY		PAGE
DATE	MATERIALS & CONTROL GROUP ATTLEBORO, MA 01760	

FORM 8200

### 3.7 HUMIDITY

3.7.1 Devices tested: 245-15-25 thru -30.

3.7.2 Procedure: Per the ES section III. G. Please note that performing a full characterization per the ES consists of measurement of actuation, release, voltage drop, current leakage, and proof. This battery of tests when performed on six (6) devices takes approximately 2 hours to complete. Therefore "Within 15 minutes..." called out in the ES (section III. G. 2. a.) is an acceptance requirement that is physically impossible to meet. Every effort is made to complete final characterization within the two hour period stated above.

3.7.3 Equipment: Humidity chamber RK model 58.

3.7.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

### 3.8 SALT SPRAY

3.8.1 Devices tested: 245-15-31 thru -36.

3.8.2 Procedure: Per the ES section III. H.

3.8.3 Equipment: Marshaw salt spray chamber.

3.8.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

### 3.9 VIBRATION

3.9.1 Devices tested: 156-15-61 thru 66.

3.9.2 Procedure: Per the ES section III. I.

TEST LOT NO.	TEST	DEVICE
TESTED BY		
APPROVED BY	<b>TEXAS INSTRUMENTS</b>	DOC.
DATE 02-04-17		MATERIALS & CONTROLS GROUP ATTLEBORO, MA 02703

FORM 229a

TI-NHTSA 006375

3.9.3 Equipment: Vibration table, Ling, model A395 with Hewlett-Packard model 5427 controls. Air tank with 350 psig minimum pressurized Nitrogen used to actuate devices with at least 1.1 times maximum actuation specification on part drawing; 160 psig \* 1.1 = 176 psi minimum.

3.9.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

### 3.10 TERMINAL STRENGTH

3.10.1 Devices tested: 245-15-13 thru -24.

3.10.2 Procedure: Per the ES section III. J.

3.10.3 Equipment: Custom TI designed and built fixtures for gaging terminal movement after force application and for application of impact via a pendulum. This equipment is regularly used on the 57PS/77PS assembly lines in testing to TI Quality Assurance Specifications.

3.10.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

### 3.11 VACUUM

3.11.1 Devices tested: 245-15- 55 thru 60.

3.11.2 Procedure: Per the ES section III. K.

3.11.3 Equipment: Kinney vacuum pump. Sensotec pressure transducer range 0-25 psia calibrated quarterly, with Fluke model 8020B Digital Multimeter/readout, calibrated quarterly.

3.11.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

TEST LOT NO.	TEST	DEVICE
TESTED BY		
APPROVED BY	<b>TEXAS INSTRUMENTS</b>  MATERIALS & CONTROL GROUP ATTLEBORO, MA, 01704	DOC.
DATE 12-08-17		PAGE 16

FORM 8298

### 3.12 TEMPERATURE CYCLE

- 3.12.1 Devices tested: 245-15-49 thru 54
- 3.12.2 Procedure: Per the ES section III. L.
- 3.12.3 Equipment: Same as 3.5.3.
- 3.12.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

### 3.13 FLUID RESISTANCE

- 3.13.1 Devices tested: 245-15-01 thru -36.
- 3.13.2 Procedure: Per the ES section III. M.
- 3.13.3 Equipment: Fluids as called out in ES table in III. M. 1. c. plus appropriate beakers and storage apparatus; vented hood.
- 3.13.4 Results: The 36 devices were divided into groups as follows for subsequent testing. Results of these tests are reported in the section indicated.
- 3.13.4.1 Impulse (3.5), -01 thru -12
- 3.13.4.2 Terminal Strength (3.10), -13 thru -24.
- 3.13.4.3 Humidity (3.7), -25 thru -30.
- 3.13.4.4 Salt Spray (3.8), -31 thru -36.

TEST LOT NO.	TEST	DEVICE
TESTED BY		
APPROVED BY	<b>TEXAS INSTRUMENTS</b> 	DOC.
DATE 82-12-31		PAGE 11

FORM 8996

TI-NHTSA 008377

### 3.14 NOISE

In certain vehicle applications, the brake pressure switch action has been shown to be transmitted to the passenger compartment as audible noise and corresponding tactile feel in the brake pedal. A "silent" device has been developed by Texas Instruments in order to address this concern. At the same time, a means of quantifying the noise/feel was explored. The hypothesis was that a sudden motion of pressure-sensing components within the switch caused a pressure wave to propagate from the switch. Characterization of this effect using high-speed pressure transducers showed that "noisy" devices produce a large negative pressure spike at the point of switch activation, and supported the hypothesis. The "silent" devices produce little or no spike. See Appendix 4.3 for a pressure trace of a typical silent device.

Ultimately (inv delta) ES-F2VC-9F924-AA will be updated to include a section on noise testing, to be applicable only to devices designated as silent. For this validation, in lieu of an officially finalized noise specification, a total of 12 devices (6 from this test and 6 similar devices) were initially characterized for noise, then run through Impulse or Thermal Cycle testing, then recharacterized for noise at the end.

#### 3.14.1 Devices tested:

77PSL3-1 Impulse:	245-15-37, 38, 39
77PSL3-1 Thermal Cycle:	245-15-49, 50, 51
77PSL5-2 Impulse:	245-15-81, 82, 83
77PSL5-2 Thermal Cycle	245-15-105, 106, 107

3.14.2 Procedure: The device under test is installed on the test manifold. Air is evacuated via a vacuum pump. The manifold is filled with the test fluid. Pressure to 300 psi is applied and the signal from the high-speed transducer is captured on a digital oscilloscope.

TEST LOT NO.	TEST	DEVICE
TESTED BY		
APPROVED BY	<b>TEXAS INSTRUMENTS</b> 	DOC.
DATE 12-08-17		NATERIALS & CONTROLS GROUP ATLANTA, GA 30301

FORM 8988

3.14.3 Equipment: Custom TI designed and built equipment, utilizing a single-port test manifold within a protective enclosure. The manifold is evacuated by a Flab H-125 pneumatic vacuum pump. DOT 3 Brake Fluid is introduced via a fluid reservoir. Pressure is applied via pressurized air which is introduced to an air-over-oil chamber which connects to the test manifold. The dynamic pressure signal during switch actuation is measured with a Kistler High-Frequency Dynamic Pressure Transducer model 606A (SN C46154) with a Kistler 5004 Charge Amplifier whose output connects to channel A of a dual-channel Nicolet 4094A Digital Oscilloscope. The electrical switching action of the device under test is recorded simultaneously on channel B using a 5-volt source and a 1K ohm load resistor.

3.14.4 Initial results: All twelve test devices produced zero pressure spike.

3.15.5 Final results: All twelve test devices produced zero pressure spike.

TEST LOT NO.	TEST	SERVICE
TESTED BY		
APPROVED BY		DOC.
DATE 02-28-11	 MATERIALS & CONTROLS GROUP ATTLEBORO, MA 02703	PAGE 11

FORM 8295

TI-NHTSA 006379

**Appendix 4.1**  
**Ford Engineering Specification**  
**(inv delta) ES-F2VC-9F924-AA**

<b>TEST LOT NO.</b>	<b>TEST</b>	<b>DEVICE</b>
<b>TESTED BY</b>		
<b>APPROVED BY</b>	 <b>TEXAS INSTRUMENTS</b>	<b>DOC.</b>
<b>DATE</b> 02-08-17		<b>PAGE</b> 14

FORM 0281

# Engineering Specification

PART NAME SWITCH ASSEMBLY - SPEED CONTROL DEACTIVATE				PART NUMBER ▽ 28-7270-97924-11			
LET							
FR							
LEV							
PR							
DATE	LET	FR	REVISION	EN	OK	REFERENCE	
			ADDED DATA TO COMPLETE SPEC. & RETYPED			PREPARED/APPROVED BY R.S. DeLoach 9009 10	
10/13/52			NC00510079779002			DRAWN BY	
						DESIGNED BY	
						CONDUCTED/APPROVAL SIGNATURE	
						DESIGN ENGINEER SUPERVISOR R. DeLoach 9009 10	
						DESIGN ENGINEERING UNIT	
						MANUFACTURING ENGINEER	
						QUALITY CONTROL R. DeLoach 9009 10	
						QUALITY ASSISTANCE R. DeLoach 9009 10	
						PRODUCTION DIVISION R. DeLoach 9009 10	

▽ CONTROL ITEM -- THE ▽ SYMBOL ALSO DENOTES PROJECT INSURANCE DESIGNATED CRITICAL CHANGING POINTS, TESTS AND AUXILIARY CHECKS. CHECKS MUST BE CONTROLLED BY PROJECT ENGINEER. MUST APPEAR ON THE O-971 CONTROL PLAN WHICH REQUIRES PRODUCT INSURANCE APPROVAL.

## Engineering Specification

### SWITCH ASSEMBLY - SPEED CONTROL DEACTIVATE

#### I. General

This specification covers the test requirements for the speed control deactivate switch -9792A- used in the electronic speed control system. Design changes on the switch assembly or its components shall not be made without compliance to Section V of this specification and written approval from the releasing Production Engineering Office.

This engineering specification is a supplement to the released drawing on the above part, and all requirements herein must be met in addition to all other requirements of the part drawing. Minimum measures necessary for demonstrating compliance to these requirements are given in each section.

The engineering tests, sample sizes, and test frequencies contained within this engineering specification reflect the minimum requirements established to provide a regular evaluation of conformance to design intent. The engineering test program is intended as a supplement to normal material inspections, dimensional checking and in-process controls, and should in no way adversely influence other inspection operations.

QI suppliers may implement different test sample sizes and frequencies providing these changes have been included in an alternate Control Plan approved by the design responsible Product Engineering Office and concurred in by SQE.

#### II. PRODUCTION VALIDATION AND IN-PROCESS TESTS

- Production Validation (PV) Tests must be completed satisfactorily with parts from production tooling (and processes where possible) before IPR approval and authorization for shipment of production parts can be effected. Parts must be revalidated completely, or per Section V whenever any change is made which could possibly affect part function or performance.
- In-Process Test Phase 1 (IP-1) - IP-1 tests are used to demonstrate process capability and must be completed using initial production parts from production tooling and processes prior to first production shipment approval. IP-1 tests are to continue in effect until process capability is demonstrated.
- In-Process Test Phase 2 (IP-2) - IP-2 test program may be implemented only after process capability has been established. Tests must be completed with production parts on a continuing basis. Samples for these tests must be selected on a random basis to represent the entire production population as much as possible. In the event that any of the requirements in these tests is not met, the reaction plan specified in Ford QID Sect. 3.5, "Engineering Specifications (ES) Test Performance Requirements" shall be invoked.

2  
18

**SECTION III. TABLE OF TESTS**


Engineering Specifications

Item	Test Name Functional Tests	PRODUCTION VALIDATION		IN-PROCESS IP-1		IN-PROCESS IP-2	
		Minimum Sample Size	Statistical Test Acceptance Criteria	Minimum Sample Size	Statistical Test Acceptance Criteria	Minimum Sample Size	Statistical Test Acceptance Criteria
<b>III.</b>							
△ A	Calibration	72	F90-.96	100%	All Must Pass	100%	All Must Pass
B	Voltage Drop	72	F90-.96	12/No.	F90-.84	4/Lot	" " "
C	Current Leakage	72	F90-.96	3/No.	F90-.96	4/Lot	" " "
D	Frost Test	72	F90-.96	12/No.	F90-.84	4/Lot	" " "
F	Burst	6	F90-.72	3/No.	F90-.96	4/Lot	" " "
I	Vibration	6	F90-.72	3/No.	F90-.96	6/6 No.	F90-.72
J	Torsional Strength	12	F90-.84	6/No.	F90-.72	4/Lot	All Must Pass
K	Vacuum	6	F90-.72	3/No.	F90-.96	6/6 No.	F90-.72
L	Temperature Cycle	6	F90-.72	3/No.	F90-.96	6/6 No.	F90-.72
M	Fluid Resistance	36	F90-.94	16/12No.	F90-.94	16/12No.	F90-.94
<b>Survivability Tests</b>							
<b>III.</b>							
K	Impact	24	F90-.90	12/No.	F90-.84	3/1 No.	F90-.96
G	Humidity	6	F90-.72	3/No.	F90-.96	6/6 No.	F90-.72
H	Salt Spray	6	F90-.72	3/No.	F90-.96	6/6 No.	F90-.72

△ In-Process-IP-1

**Engineering Specification**

**PRODUCTION VALIDATION FLOW CHART**



ALL MEET PASS

ALL MEET PASS

16

VEN-3710-9904-AA

## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS

#### ▽ A. Calibration

##### 1. Test Requirements

- a. Switch calibration is to be checked at room temperature ( $15^{\circ}\text{C}$ - $35^{\circ}\text{C}$ ) using ambient air or equivalent.
- b. Calibration settings shall be specified on the part drawing with the settings checked after 2 or more pressure cycles with ambient air, or equivalent. Pressure cycle range is to be determined by the manufacturer to insure switch calibration stability. The cut-in and differential set points are to be measured while conducting  $750 \pm 50$  milliamperes while  $13.0 \pm 1.0$  volts D.C. is applied. The cut-in point is to be checked with increasing pressure.
- c. The cut-out point is to be checked with decreasing pressure, and the differential set point is to be calculated using the cut-in pressure minus the cut-out pressure.

##### 2. Acceptance Requirements

- a. Nonconformance is defined as any switch point which falls outside the tolerance band specified on the part drawing.

#### B. Voltage Drop

##### 1. Test Requirements

- a. Voltage drop is to be measured after 2 or more cycles with ambient air or equivalent, from 0 to  $10,000 \pm 173$  KPa ( $1450 \pm 25$  PSI) while conducting  $750 \pm 50$  milliamperes and  $13.0 \pm 1.0$  volts D.C. is applied to the switch. Under these conditions with the switch closed the voltage drop is to be measured. Millivolt connection interface at terminals to be less than 10 millivolts.

##### 2. Acceptance Requirements

- a. Nonconformance is defined as a voltage drop in excess of 200 millivolts.

5

18

▽ ES-FJVC-97924-AA

TI-NHTSA 006385

## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS (cont'd)

#### C. Current Leakage

##### 1. Test Requirements

- a. Current leakage is to be checked with 500 volts, 60 Hz alternating current.
- b. Current leakage is to be checked:
  - (1) Between the switch leads with the contacts open.
  - (2) Between the lead and the switch housing with contacts closed.
  - (3) Between either lead and switch housing with the contacts open.

##### 2. Acceptance Requirements

- a. Nonperformance is defined as any leakage current in excess of one hundred (100) microampere.

#### D. Proof Test

##### 1. Test Requirements

- a. Subject sample switches to Section A to establish their initial switching pressures.
- b. Proof test is to be conducted using brake fluid or equivalent as the pressure medium. Test pressure shall be as specified on the part drawing. Test pressure shall be isolated from pressure source and held for not less than 30 seconds.
- c. Recheck the switches to Section A.

##### 2. Acceptance Requirements

- a. No evidence of fluid leakage, seepage, or drop in test pressure greater than 430 KPa. (62 PSI) is permitted.
- b. A change in cut-in and cut-out pressures greater than  $\pm 5\%$  from the initial value is not permitted.
- c. The test samples must be destroyed after testing.

## Engineering Specification

### III. TEST PROCEDURE AND REQUIREMENTS (cont'd)

#### E. Impulse

##### 1. Test Requirements

- a. Test the switch for a total of 500,000 cycles. Cycle pressure between (low) 0-275 KPa (0-40 psi) and (high)  $10,000 \pm 345$  KPa ( $1450 \pm 50$  psi).
  - 1) 0 - 475,000 cycles:  $13 \pm 1$  volts, brake current to monitor function.
  - 2) 475,001 - 500,000 cycles:  $13 \pm 1$  volts D.C., 750  $\pm$  50 ma., per figure 4.
- b. Brake fluid temperature to be  $135 \pm 14^{\circ}\text{C}$  and ambient temperature to be  $187^{\circ}\text{C}$  min.
- c. Cycle rate is to be 110-130 cycles per minute.
- d. Switch must open and close each cycle.

##### 2. Acceptance Requirements

- a. After impulse test check to sections A, B, C, & D using the procedure established in each section.
- b. Nonconformance is defined as any switch not meeting the criteria in sections A, B, C, & D.
- c. Samples used for this test must be destroyed after all testing is completed.

#### F. Burst

##### 1. Test Requirements

- a. Burst strength is to be checked using brake fluid or equivalent as the pressure medium.
- b. Pressurize the switch to 48.3 MPa (7000 PSI) minimum and hold for 30 seconds minimum.

##### 2. Acceptance Requirements

- a. Nonconformance is defined as any evidence of fluid leakage or seepage from the switch or threads. Samples used for this test must be destroyed after testing is completed.

## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS (cont.)

#### G. Humidity

##### 1. Test Requirements

- a. Mount the switch in the test port in a humidity chamber. Currently released mating electrical connector must be installed before start of test.
- b. Subject the switch to ten (10) continuous humidity cycles as follows:
  - (1) Raise temperature to  $65 \pm 10/-2$  °C over 2.5 hours; at 90-98% relative humidity.
  - (2) Hold 3 hours at  $65 \pm 10/-2$  °C at 90-98% relative humidity.
  - (3) Lower temperature to  $25 \pm 10/-2$  °C over 2.5 hours; at 90-98% relative humidity.

##### 2. Acceptance Requirements

- a. Within 15 minutes after completion of the tenth humidity cycle check the switch to sections A, B, C, D, using the procedure established in each section.
- b. Nonconformance is defined as any switch not meeting the criteria in sections A, B, C, or D.

#### H. Salt Spray

##### 1. Test Requirements

- a. Mount the switch in the test port in a salt spray chamber. The currently released mating electrical connector and wiring must be installed prior to start of test.
- b. Expose the switch assembly to 72 hours of salt spray per ASTM B-117.

##### 2. Acceptance Requirements

- a. After exposure, check the switch to sections A, B, C, D, using the procedure established in each section.
- b. Nonconformance is defined as any switch not meeting the criteria in sections A, B, C, or D. Samples used for this test must be destroyed after all marking is completed.

8

18

▽ ES-FYVC-57924-AA

## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS (cont'd)

#### I. Vibration

##### 1. Test Requirements

- a. Mount the switch in the test port and attach the currently released mating electrical connector before start of test.
- b. Switches are to be vibrated in all 3 planes with electrical continuity being monitored during the entire test. See Figure 1 for switch orientation in the 3 planes. Vibration tests are to be conducted at room temperature using brake fluid, ambient air, or equivalent as the pressure medium.
- c. Internal pressure shall be maintained at 0 KPa G, when the switch is in the closed position and 1.1 times test actuation pressure shown on print when the switch is in the open position.
- d. Vibrate the switch at 1.5 mm displacement (peak-to-peak) while varying the frequency uniformly from 5 to 30 to 5 Hz over a 5 minute period.
- e. Vibrate the switch in alternate one-hour periods in the open and closed positions for a total of 8 hours in each plane. (Total test time is 24 hours).

##### 2. Acceptance Requirements

- a. After the entire vibration sequence check the switches to sections A, B, C, or D using the procedure established in each section.
- b. Nonconformance is defined as any evidence of leakage or any change in electrical continuity/discontinuity during the vibration cycles, or any switch not meeting the criteria in sections A, B, C, or D. Samples used for this test must be destroyed after all testing is completed.

## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS (cont'd)

#### J. Terminal Strength

##### 1. Test Requirements

a. Mount the switch in the test port.

(1) Apply a  $59 \pm 5$  N axial force to each terminal.

(2) With a pendulum apply a  $45 \pm 5$  N impact force to the switch housing at the connector end, perpendicular to the centerline axis of the switch. See Figure 1 for force application point and direction.

##### 2. Acceptance Requirements

a. Check the switch to sections A, B, C, and D using the procedures established in each section.

b. Nonconformance is defined as any terminal or housing fracture, or any switch not meeting the criteria in sections A, B, C, or D.

#### K. Vacuum

##### 1. Test Requirements

a. Mount the switch in the test port. Vacuum tests are to be conducted at room temperature using ambient air as the pressure medium.

b. Subject the switch to 5 cycles of vacuum from atmospheric pressure (760 mm Hg) to an absolute pressure of 3-4 mm Hg. Maintain the vacuum for a minimum of 60 seconds.

##### 2. Acceptance Requirements

a. Check the switch to sections A, B, C, and D using the procedures established in each section.

b. Nonconformance is defined as any switch not meeting the criteria in sections A, B, C, and D.

10

18

▽ ES-F29C-57924-AA

## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS (cont'd)

#### L. Temperature Tests

##### 1. Test Requirements

- a. Mount switches in test parts; test to be run using currently released brake fluid.
- b. Repeat the following procedure 15 times.
  - (1) Lower the switch and fluid temperature to at least  $-40^{\circ}\text{C}$ .
  - (2) Cycle the switches ten times at 10 seconds/cycle. One cycle consists of a pressure variation from 0 - 276 KPa.G (0-40 psi) to  $10,000 \pm 345$  KPa.G ( $1450 \pm 50$  PSI).  
Note: Switch must open and close each cycle.
  - (3) Raise switch and fluid temperature to  $38^{\circ}\text{C}$  minimum.
  - (4) Repeat Step 2.
- c. At completion of Step b, check switches per sections A, B, C, and D.

##### 2. Acceptance Requirements

- a. Nonconformance is defined as any evidence of switch fluid leakage, seepage, or not meeting the criteria of sections A, B, C, and D.

#### M. Fluid Resistance

##### 1. Test Requirements

- a. Mount the switch in the test part and orient as installed in the vehicle.
- b. Install the currently released wiring electrical connector (with wire leads) to the switch.
- c. Sequentially, immerse the switch into each of the specified fluids, at a temperature of  $23 \pm 2^{\circ}\text{C}$ , for  $5 \pm 1$  second. Remove the switch and drain and store the switch for the specified time at room temperature, prior to immersing into the next fluid.

## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS (cont'd)

<u>Fluid</u>	<u>Drain Time</u>	<u>Storage Time</u>
Reference Fuel C ASTM D471	60 ± 5 min.	none
10W40 Engine Oil	24 ± 1 hour	14 days
Ethylene Glycol/ Water 50/50 by Volume	24 ± 1 hour	24 ± 1 hour
Brake Fluid DOT 3	24 ± 1 hour	48 ± 1 hour
Automatic Transmission/ Power Steering Fluid (same) ESP-H20118-G1	24 ± 1 hour	14 days
Isopropyl Alcohol/ Water 50/50 by Volume	24 ± 1 hour	none
Reference Fuel C, ASTM D471 with Methyl Alcohol 85/15 by Volume	24 ± 1 hour	none

4. For the Flow Chart, subject the prescribed number of immersed switches to the post immersion tests specified below:

- III. K. Impulse
- III. G. Humidity
- III. H. Salt Spray
- III. J. Terminal Strength

#### Acceptance Requirements

- a. Switches must fully meet the requirements of the specified post immersion test.
- b. Nonconformance is defined as any switch not meeting the criteria in sections A, B, G, or D. Samples used for this test must be destroyed after all testing is completed.

## Engineering Specification

### IV. STATISTICAL ANALYSIS METHODS

- A. For IV, IV-1 and IV-2 tests, all samples tested must pass. Having all the required sample size pass will provide data to support the conclusion that the switch has a minimum reliability  $R$ , at a given confidence of  $C$ . The notation  $Pn-R$  is interpreted as minimum reliability equal to  $R$ , at a confidence  $C$ ; thus P9D-.90 means a minimum reliability of 90% at 90% confidence.
- B. All samples must pass in the statistical test acceptance criteria stated for tests with 100% frequency; or samples from lots, which could have a variable size.

### V. REVALIDATION REQUIREMENTS

- A. No change in design, material, process or component supplier shall be made without prior approval from the releasing Product Engineering Office. As part of approving a change, the releasing Product Engineering Office will establish the portion of the Product Validation tests required to be run to revalidate the switch. The following table is to be used as a guide in determining the type of tests required for revalidation requirements.

#### DESIGN CHANGE REVALIDATION

Component	Process or Material Change or New Supplier
1. Terminals, Contacts, or Connector	III, B, C, E, G, H, I, J, L, M.
2. Case or Housing	All Tests
3. Disc or Diaphragm	III, A, D, E, F, I, K, L.
4. Fitting or Fluid Connection	III, D, E, F, H, I, M.
5. Annual revalidation is not required on carryover switches.	

### VI. LOT DEFINITION

A lot is defined as no more than eight (8) hours of production up to 4,000 pieces. If shifts extend beyond eight (8) hours, or more than 4,000 pieces are produced in a shift, the product must be separated into at least two lots.

## Engineering Specification

### VII. RECORD RETENTION

- A. Recording and record retention shall conform with Ford Q-101.
- B. Production Validation test results and analysis are to be forwarded to the releasing Product Engineering Office before approval for shipment of production parts can be granted.
- C. In-Process test results shall be available at the supplier's manufacturing facility for the releasing Product Engineering Office and Ford SCA or its representatives to review on request.

### VIII. INSTRUCTIONS AND NOTES

All switches are to be identified with the Ford part number, supplier identification, and a date code indicating final assembly.

All test equipment and test procedures for testing to this specification must be approved by the releasing Product Engineering Office and no change in equipment or procedure may be made without their written concurrence.

Test port configuration is shown in Figure 1.

O-rings, if used in the design, shall be free from cuts, nicks, abrasions or any other damage which would result in a fluid leak.

All switches must have a shipping cap installed over the port threads to prevent contamination. All shipping caps must be approved by the releasing Product Engineering Office prior to production interpretation.

All switches that do not pass the calibration test are to either be readjusted and rechecked, or scrapped. (Salvage of component parts permitted with 100% reinspection).

If product nonconformance occurs for test sections III. B, C, D, E, F, and J, production shall be stopped and the problems corrected. All production lots shall be sorted 100% prior to shipment. Suspected nonconformances of any shipped parts shall be reported immediately to the releasing Product Engineering Office.

If nonconformance of the statistical acceptance criteria occurs for test sections III. G, H, I, K, L and M, a cause to recall the subject weeks production and to stop production may result.

## Engineering Specification

### IX. COMPILATION OF REFERENCE DOCUMENTS

ASTM B-117, Salt Spray Testing

Ford Q-101, Quality System Standard - 1990 Edition

ES-FUEE-14464-AA, Specification - SLV Assy - Wire Connector

ES-FZVF-9C735-AA, Specification - Harve Assembly Speed Control


15

18

▽ ES-FZVF-9C734-AA


TI-NHTSA 006395

**Engineering Specification**



**VIBRATION TEST - SWITCH ORIENTATION**


**FIGURE 1.**



**TERMINAL STRENGTH - LOAD ORIENTATION**

**FIGURE 2.**

Engineering Specification




Reference  
SAE J512 OCT 80  
Figure 5A

TEST FIXTURE PORT CONFIGURATION

FIGURE 3

17	18		$\nabla$ 28-2270-28924-1A
FRAME	OF	REVISED	NUMBER

Engineering Specification



DEACTIVATE SWITCH  
TEST SET UP

FIGURE 4

18

18

▽ 25-7270-97504-11

Appendix 4.2  
Data

TEST LOT NO.	TEST	DEVICE
TESTED BY		
APPROVED BY	<b>TEXAS INSTRUMENTS</b> 	DOC.
DATE 12-01-17		MATERIALS & CONTROLS GROUP ATTLEBORO, MA 01703

FORM 5298

PRESSURE SWITCH DATA

Form 21605

TEST NO. 245-15-129

DEVICE 77PSL 3-1, 77PSL 5-2	DATE REQUESTED 9/04/13	REQUESTED BY Steve Offley	REQUESTED COMPL. DATE
PERFORMED BY Jeffie D. Gonzalez	DATE STARTED 9/04/13	DATE COMPLETED	APPROVED BY
PROJECT TITLE: Speed Control			

CUSTOMER:

PURPOSE OF TEST: Production Validation

PROCEDURE: DCS-F106-9F924-AR: Full ESR

Natural Nylon Pipes

ultra-low diff. disc.

Act 90-160

Rel 20 min

77PSL 3-1

INITIAL Characterization

Device	Act	Rel	No. Drop	Leak	Proof	Act	Rel	Test	Complete	Test	Complete
245-15-01187	107	107	4.1	✓	✓	148	102	Fluid Disc	✓	Impulse	✓
-03	127	67	3.1	✓	✓	120	113		✓		✓
-07	138	11	3.8	✓	✓	120	115		✓		✓
-09	131	115	5.7	✓	✓	121	117		✓		✓
-05	159	117	6.1	✓	✓	126	115		✓		✓
-06	124	103	4.7	✓	✓	122	119		✓		✓
-07	05	117	4.5	✓	✓	121	119		✓		✓
-08	123	107	4.8	✓	✓	119	113		✓		✓
-09	124	107	4.5	✓	✓	122	119		✓		✓
-10	131	115	3.3	✓	✓	125	116		✓		✓
-11	125	114	4.9	✓	✓	125	118		✓		✓
-12	126	117	4.2	✓	✓	125	124		✓		✓
-13	126	116	3.5	✓	✓	123	122		✓	Iron Shredd	✓
-14	107	92	4.8	✓	✓	128	119		✓		✓
-15	129	112	3.4	✓	✓	125	125		✓		✓
-16	129	111	4.1	✓	✓	124	111		✓		✓
-17	125	108	3.9	✓	✓	122	121		✓		✓
-18	126	116	3.7	✓	✓	122	116		✓		✓
-19	128	116	5.3	✓	✓	122	112		✓		✓
-20	122	11	3.1	✓	✓	127	109		✓		✓
-21	134	121	3.9	✓	✓	129	128		✓		✓
-22	121	105	3.2	✓	✓	122	115		✓		✓
-23	126	10	2.7	✓	✓	122	120		✓		✓
-24	119	98	3.6	✓	✓	123	117		✓		✓
-25	124	110	3.1	✓	✓	127	112		✓	Security	✓
-16	119	108	3	✓	✓	125	117		✓		✓
-01	131	117	3	✓	✓	127	122		✓		✓
-01	131	120	3.2	✓	✓	130	119		✓		✓

Device #	Act	Ref	My. Deep	Correct 100 H.	Temp. per Point	Act	Ref	Test	Complete	Test	Complete
215-16-29	129	114	3.3	✓	✓	129	110	Fluid test	✓	Humidity	✓
- 30	114	126	3.3	✓	✓	126	110		✓		✓
- 31	129	114	3.9	✓	✓	129	119		✓	Soft Spay	✓
- 32	123	115	2.6	✓	✓	123	120		✓		✓
- 33	116	102	2.8	✓	✓	115	105		✓		✓
- 34	126	119	2.3	✓	✓	128	122		✓		✓
- 35	118	109	2.9	✓	✓	125	113		✓		✓
- 36	122	117	2.9	✓	✓	127	115		✓		✓
- 37	131	119	3.1	✓	✓	122	118	Temperature	✓	Humidity	✓
- 38	132	118	2.6	✓	✓	130	125		✓		✓
- 39	134	125	2.6	✓	✓	135	126		✓		✓
- 40	134	112	2.7	✓	✓	129	125		✓		✓
- 41	135	112	2.8	✓	✓	127	118		✓		✓
- 42	116	106	2.7	✓	✓	130	118		✓		✓
- 43	117	106	2.7	✓	✓	127	117		✓		✓
- 44	120	101	2.7	✓	✓	131	125		✓		✓
- 45	124	126	3.7	✓	✓	142	131		✓		✓
- 46	122	114	3.4	✓	✓	130	120		✓		✓
- 47	127	117	2.7	✓	✓	133	118		✓		✓
- 48	116	107	2.7	✓	✓	127	120		✓		✓
- 49	124	112	2.7	✓	✓	137	115	7-Cycle	✓	Humidity	✓
- 50	132	121	2.9	✓	✓	135	124		✓		✓
- 51	112	101	3.0	✓	✓	130	124		✓		✓
- 52	117	121	3.2	✓	✓	126	128		✓		✓
- 53	127	121	2.0	✓	✓	124	122		✓		✓
- 54	121	122	3.8	✓	✓	125	119		✓		✓
- 55	128	115	3.0	✓	✓	127	119	Vacuum	✓		✓
- 56	126	114	2.9	✓	✓	128	118		✓		✓
- 57	127	118	2.7	✓	✓	130	119		✓		✓
- 58	122	111	3.2	✓	✓	130	126		✓		✓
- 59	123	112	3.1	✓	✓	125	119		✓		✓
- 60	131	117	2.4	✓	✓	123	121		✓		✓
- 61	127	119	2.2	✓	✓	124	120	Vibration	✓		✓
- 62	127	117	2.7	✓	✓	121	124		✓		✓
- 63	129	118	2.6	✓	✓	122	125		✓		✓
- 64	128	117	3.5	✓	✓	136	125		✓		✓
- 65	121	112	2.8	✓	✓	126	118		✓		✓
- 66	118	107	2.1	✓	✓	127	115		✓		✓
- 67	132	123	2.9	✓	✓	134	123	Acid	Pass		✓
- 68	126	117	2.9	✓	✓	121	122		Pass		✓
- 69	123	128	2.7	✓	✓	120	124		Pass		✓
- 70	119	129	2.7	✓	✓	129	121		Pass	Humidity	✓
- 71	121	120	2.7	✓	✓	122	124		Pass		✓
- 72	125	129	2.8	✓	✓	126	126		Pass		✓
- 73	125	120	2.8	✓	✓	137	129	Not used			✓
- 74	124	118	2.4	✓	✓	128	120				✓
- 75	119	112	3.4	✓	✓	126	117				✓
- 76	118	127	2.4	✓	✓	121	117				✓
- 77	120	109	2.1	✓	✓	126	118				✓
- 78	111	101	2.4	✓	✓	125	113				✓
- 79	112	105	2.5	✓	✓	127	117				✓
- 80	121	124	2.7	✓	✓	126	122				✓

**PRESSURE SWITCH DATA**

Form 21605

TEST NO. \_\_\_\_\_

DEVICE	DATE REQUESTED	REQUESTED BY	REQUESTED COMPL. DATE
PERFORMED BY	DATE STARTED	DATE COMPLETED	APPROVED BY

PROJECT TITLE: \_\_\_\_\_

CUSTOMER: \_\_\_\_\_

PURPOSE OF TEST: \_\_\_\_\_

PROCEDURE: \_\_\_\_\_

771563-1

Final Characterizations

Device #	Set P. (psi)	Act. P. (psi)	Flow Rate (lb/hr)	100°F	700°F	Test No.
101	131	104	38.6	✓	✓	122-100
102	128	97	39.4	✓	✓	122-105
103	130	102	39.6	✓	✓	122-108
104	128	101	39.0	✓	-	122-109
105	135	108	35.2	✓	✓	122-110
106	127	95	32.1	✓	✓	117-97
107	130	103	35.6	✓	✓	122-105
108	124	99	35.2	✓	✓	122-103
109	124	96	34.3	✓	✓	122-105
110	122	100	36.5	✓	✓	120-101
111	127	97	35.9	✓	✓	122-105
112	125	101	36.8	✓	✓	122-105
113	128	109	4.3	✓	✓	122-115
114	124	92	2.7	✓	-	119-95
115	125	102	2.8	✓	✓	122-115
116	126	111	2.7	-	✓	122-120
117	124	102	2.6	✓	✓	122-116
118	131	97	2.2	-	-	122-105
119	133	99	2.7	-	✓	122-115
120	122	97	2.3	-	✓	120-111
121	122	10	2.7	✓	✓	122-122
122	122	104	5.1	✓	✓	122-112
123	123	101	2.0	✓	✓	125-102
124	125	103	2.5	✓	✓	122-114
125	121	105	2.1	✓	✓	125-120
126	124	112	5.0	✓	✓	125-109
127	128	112	3.1	✓	✓	127-114
128	123	112	3.4	✓	✓	123-101

Row #	Ref	Rel	M. App	2001	2002	2003	Rel
1	121	101	2.7	✓	✓	121	101
2	122	99	3.4	✓	✓	122	100
3	123	114	2.9	✓	✓	120	112
4	124	109	2.3	✓	✓	125	106
5	125	99	6.6	✓	✓	120	97
6	126	118	3.9	✓	✓	127	118
7	127	126	2.8	✓	✓	125	125
8	128	101	3.1	✓	✓	128	101
9	128-112		8.6	✓	✓	123-109	
10	128-114		6.8	✓	✓	127-106	
11	126-112		8.7	✓	✓	126-107	
12	131-113		8.0	✓	✓	122-110	
13	125-111		7.2	✓	✓	122-106	
14	124-112		5.6	✓	✓	126-107	
15	127-112		5.7	✓	✓	124-108	
16	125-111		5.5	✓	✓	122-107	
17	128-113		7.7	✓	✓	128-113	
18	129-116		7.0	✓	✓	122-108	
19	131-117		8.0	✓	✓	127-105	
20	126-112		4.5	✓	✓	122-105	
21	127-98		2	✓	✓	127-98	
22	129-100		5.6	✓	✓	127-100	
23	126-108		2.6	✓	✓	127-98	
24	130-105		1.7	✓	✓	120-101	
25	130-102		2.9	✓	✓	128-101	
26	125-103		1.1	✓	✓	125-97	
27	129-117		1.3	✓	✓	128-109	
28	122-120		1.2	✓	✓	120-115	
29	126-123		1.2	✓	✓	124-108	
30	125-121		1.7	✓	✓	121-113	
31	130-118		2.7	✓	✓	127-114	
32	128-125		1.7	✓	✓	126-120	
33	124-117		1.5	✓	✓	124-120	
34	128-124		2.2	✓	✓	120-114	
35	127-115		2.6	✓	✓	128-109	
36	128-109		2.6	✓	✓	128-113	
37	127-127		2.8	✓	✓	120-124	
38	128-105		3.1	✓	✓	128-110	

Appendix 4.3  
Noise Pressure Trace

TEST LOT NO.	TEST	DEVICE
TESTED BY	<b>TEXAS INSTRUMENTS</b> 	DOC.
APPROVED BY		PAGE 16
DATE 02-06-17	MATERIALS & CONTROLS GROUP ATTLEBORO, MA 02100	

FORM 8208

TI-NHTSA 006404

77PSL3-1

E2AC-9F924-AA

"QUIET"




FIGURE 3

TI-NHTSA 006405

1974

1975

1976

1977

1978

1979

1980

1981

1982

1983

1984

1985

1986

1987

1988

1989

1990

1991

1992

1993

1994

1995

1996

1997

1998

1999

2000

2001

2002

2003

2004

2005

2006

2007

2008

2009

2010

2011

2012

2013

2014

2015

2016

2017

2018

2019

2020

2021

2022

2023

2024

2025

2026

2027

2028

2029

2030

2031

2032

2033

2034

2035

2036

2037

2038

2039

2040

2041

2042

2043

2044

2045

2046

2047

2048

2049

2050

2051

2052

2053

2054

2055

2056

2057

2058

2059

2060

2061

2062

2063

2064

2065

2066

2067

2068

2069

2070

2071

2072

2073

2074

2075

2076

2077

2078

2079

2080

2081

2082

2083

2084

2085

2086

2087

2088

2089

2090

2091

2092

2093

2094

2095

2096

2097

2098

2099

2100

2101

2102

2103

2104

2105

2106

2107

2108

2109

2110

2111

2112

2113

2114

2115

2116

2117

2118

2119

2120

2121

2122

2123

2124

2125

2126

2127

2128

2129

2130

2131

2132

2133

2134

2135

2136

2137

2138

2139

2140

2141

2142

2143

2144

2145

2146

2147

2148

2149

2150

2151

2152

2153

2154

2155

2156

2157

2158

2159

2160

2161

2162

2163

2164

2165

2166

2167

2168

2169

2170

2171

2172

2173

2174

2175

2176

2177

2178

2179

2180

2181

2182

2183

2184

2185

2186

2187

2188

2189

2190

2191

2192

2193

2194

2195

2196

2197

2198

2199

2200

2201

2202

2203

2204

2205

2206

2207

2208

2209

2210

2211

2212

2213

2214

2215

2216

2217

2218

2219

2220

2221

2222

2223

2224

2225

2226

2227

2228

2229

2230

2231

2232

2233

2234

2235

2236

2237

2238

2239

2240

2241

2242

2243

2244

2245

2246

2247

2248

2249

2250

2251

2252

2253

2254

2255

2256

2257

2258

2259

2260

2261

2262

2263

2264

2265

2266

2267

2268

2269

2270

2271

2272

2273

2274

2275

2276

2277

2278

2279

2280

2281

2282

2283

2284

2285

2286

2287

2288

2289

2290

2291

2292

2293

2294

2295

2296

2297

2298

2299

2300

2301

2302

2303

2304

2305

2306

2307

2308

2309

2310

2311

2312

2313

2314

2315

2316

2317

2318

2319

2320

2321

2322

2323

2324

2325

2326

2327

2328

2329

2330

2331

2332

2333

2334

2335

2336

2337

2338

2339

2340

2341

2342

2343

2344

2345

2346

2347

2348

2349

2350

2351

2352

2353

2354

2355

2356

2357

2358

2359

2360

2361

2362

2363

2364

2365

2366

2367

2368

2369

2370

2371

2372

2373

2374

2375

2376

2377

2378

2379

2380

2381

2382

2383

2384

2385

2386

2387

2388

2389

2390

2391

2392

2393

2394

2395

2396

2397

2398

2399

2400

2401

2402

2403

2404

2405

2406

2407

2408

2409

2410

2411

2412

2413

2414

2415

2416

2417

2418

2419

2420

2421

2422

2423

2424

2425

2426

2427

2428

2429

2430

2431

2432

2433

2434

2435

2436

2437

2438

2439

2440

2441

2442

2443

2444

2445

2446

2447

2448

2449

2450

2451

2452

2453

2454

2455

2456

2457

2458

2459

2460

2461

2462

2463

2464

2465

2466

2467

2468

2469

2470

2471

2472

2473

2474

2475

2476

2477

2478

2479

2480

2481

2482

2483

2484

2485

2486

2487

2488

2489

2490

2491

2492

2493

2494

2495

2496

2497

2498

2499

2500

2501

2502

2503

2504

2505

2506

2507

2508

2509

2510

2511

2512

2513

2514

2515

2516

2517

2518

2519

2520

2521

2522

2523

2524

2525

2526

2527

2528

2529

2530

2531

2532

2533

2534

2535

2536

2537

2538

2539

2540

2541

2542

2543

2544

2545

2546

2547

2548

2549

2550

2551

2552

2553

2554

2555

2556

2557

2558

2559

2560

2561

2562

2563

2564

2565

2566

2567

2568

2569

2570

2571

2572

2573

2574

2575

2576

2577

2578

2579

2580

2581

2582

2583

2584

2585

2586

2587

2588

2589

2590

2591

2592

2593

2594

2595

2596

2597

2598

2599

2600

2601

2602

2603

2604

2605

2606

2607

2608

2609

2610

2611

2612

2613

2614

2615

2616

2617

2618

2619

2620

2621

2622

2623

2624

2625

2626

2627

2628

2629

2630

2631

2632

2633

2634

2635

2636

2637

2638

2639

2640

2641

2642

2643

2644

2645

2646

2647

2648

2649

2650

2651

2652

2653

2654

2655

2656

2657

2658

2659

2660

2661

2662

2663

2664

2665

2666

2667

2668

2669

2670

2671

2672

2673

2674

2675

2676

2677

2678

2679

2680

2681

2682

2683

2684

2685

2686

2687

2688

2689

2690

2691

2692

2693

2694

2695

2696

2697

2698

2699

2700

2701

2702

2703

2704

2705

2706

2707

2708

2709

2710

2711

2712

2713

2714

2715

2716

2717

2718

2719

2720

2721

2722

2723

2724

2725

2726

2727

2728

2729

2730

2731

2732

2733

2734

2735

2736

2737

2738

2739

2740

2741

2742

2743

2744

2745

2746

2747

2748

2749

2750

2751

2752

2753

2754

2755

2756

2757

2758

2759

2760

2761

2762

2763

2764

2765

2766

2767

2768

2769

2770

2771

2772

2773

2774

2775

2776

2777

2778

2779

2780

2781

2782

2783

2784

2785

2786

2787

2788

2789

2790

2791

2792

2793

2794

2795

2796

2797

2798

2799

2800

2801

2802

2803

2804

2805

2806

2807

2808

2809

2810

2811

2812

2813

2814

2815

2816

2817

2818

2819

2820

2821

2822

2823

2824

2825

2826

2827

2828

2829

2830

2831

2832

2833

2834

2835

2836

2837

2838

2839

2840

2841

2842

2843

2844

2845

2846

2847

2848

2849

2850

2851

2852

2853

2854

2855

2856

2857

2858

2859

2860

2861

2862

2863

2864

2865

2866

2867

2868

2869

2870

2871

2872

2873

2874

2875

2876

2877

2878

2879

2880

2881

2882

2883

2884

2885

2886

2887

2888

2889

2890

2891

2892

2893

2894

2895

2896

2897

2898

2899

2900

2901

2902

2903

2904

2905

2906

2907

2908

2909

2910

2911

2912

2913

2914

2915

2916

2917

2918

2919

2920

2921

2922

2923

2924

2925

2926

2927

2928

2929

2930

2931

2932

2933

2934

2935

2936

2937

2938

2939

2940

2941

2942

2943

2944

2945

2946

2947

2948

2949

2950

2951

2952

2953

2954

2955

2956

2957

2958

2959

2960

2961

2962

2963

2964

2965

2966

2967

2968

2969

2970

2971

2972

2973

2974

2975

2976

2977

2978

2979

2980

2981

2982

2983

2984

2985

2986

2987

2988

2989

2990

2991

2992

2993

2994

2995

2996

2997

2998

2999

3000

[The main body of the document is extremely faint and illegible due to heavy noise and low contrast. It appears to contain several paragraphs of text, but the content cannot be discerned.]

**TEXAS INSTRUMENTS**

INCORPORATED

MATERIALS AND CONTROLS GROUP

- ATTLEBORO, MA 01915   
  VERMILION, KY 40380  
 CENTRAL LAKE, MI 48822

**Shipping Order**

DATE: 8/19/92 S.O. # 271328

REF. # \_\_\_\_\_ DATE SHIPPED: / /

SHIPPED VIA: **OVERNIGHT**

SHIP TO: **DANA CORPORATION**  
**WEATHERHEAD DIVISION**  
**203 WEATHERHEAD STREET**  
**ANGOLA, INDIANA 46703**

USE (CHECK ONE)

- SCRAP SALES  
 SALE OF ASSETS  
 OUTSIDE PROCESSING  
 TRANSFERS BETWEEN TI LOCATIONS  
 OTHER, EXPLAIN IN COMMENTS DATA

CHARGE TO:

QUANTITY	DESCRIPTION/PART #/P.C.	UNIT PRICE	TOTAL
6	77PBL3-1 SAMPLES	n/c	
1	181R PKG.	n/a	

GROSS WEIGHT	NO. OF CONTAINERS	ORIGINATOR'S NAME (TYPED) ELAINE ROSE ep 12-27	ORIGINATOR'S SIGNATURE
--------------	-------------------	---	------------------------

**TEXAS INSTRUMENTS**

**Shipping Order**

INCORPORATED  
MATERIALS AND CONTROLS GROUP

DATE: 8 / 19 / 92 S.O. # 271329

- ATYL BORO, MA 02269
- VERMILION, KY 40381
- CENTRAL LAKE, MI 49628

REF. # \_\_\_\_\_ DATE SHIPPED 1 / 1

SHIPPED VIA: OVERNIGHT

SHIP TO:

DANA CORPORATION  
WEATHERHEAD DIVISION  
109 INCREMENT STREET  
ST. THOMAS, ONTARIO  
CANADA M5P3C8

USE (CHECK ONE)

- SCRAP SALES
- SALE OF ASSETS
- OUTSIDE PROCESSING
- TRANSFERS BETWEEN TI LOCATIONS
- EXPENSE MATERIAL
- OTHER, EXPLAIN: CUSTOMER DATA

CHARGE TO:

DIV/ACCT. # \_\_\_\_\_ CO. \_\_\_\_\_

QUANTITY	DESCRIPTION/PART #/PO	UNIT PRICE	TOTAL
6	77PBL3-2 SAMPLES 83.97 ea.	n/c	
1	ISLR PKG.	n/c	
<b>GROSS WEIGHT</b>	<b>NO. OF CONTAINERS</b>	<b>ORIGINATOR'S NAME (TYPED)</b> FLAINE ROSE MR 12-27	<b>ORIGINATOR'S SIGNATURE</b>

6000 - Canada  
Indiana

Customer Information

Checklist of Required Actions

Part Number: 77RCL3-1

Customer Requested Date: 8/14/92


Action 70 - DANA Corp  
Ontario, Canada

Available/Completed Status

- | Action  | Available/Completed | Status |
|---|---------------------|--------|
| 1. Manufacturing feasibility  | ✓                   |        |
| 2. Design FMEA  | ✓                   |        |
| 3. Process Flow Diagram<br><i>Process FMEA</i>  | ✓                   |        |
| 4. Designated characteristics (kpa)<br>(Significant characteristics)  | —                   |        |
| 5. Control Plan   | ✓                   |        |
| 6. Gage R & R Studies   | ✓                   |        |
| 7. Process Capability Studies (Cpk)   | —                   |        |
| 8. ES testing   | ✓                   |        |
| 9. Material Analysis (Date)   | ✓                   |        |
| 10. PIPC (Process potential Cp and<br>process capability Cpk on a<br>minimum of 300 switches once<br>the process is stable for<br>significant characteristics.) | ✓                   |        |
| 11. PIST (Includes dimensional<br>requirements on the print<br>and also all engineering<br>specification (ES) test results.                                     | ✓                   |        |
| 12. Available product to<br>accomplish testing/measurement  | ✓                   |        |

13. Comments/negotiations: Need duplicate ESSE copy  
to Dana Corp -  
Angola, Ind.

(Rev 0. 06/25/92. J. Watt)



PROCESS POTENTIAL AND QUALITY INDEXES SUMMARY DATA SHEET

PART #: F2AC-9F924-AA  
SUPPLIER: TEXAS Instruments  
CODE: T025R  
ADDRESS: 34 Forest St.  
Attleboro MA  
VEHICLE BULD: EP VP FB OTHER

SUPPLIER CONTACT: Jim Watt  
CONTACT PHONE: (508) 699-1719  
PART DESCRIPTION: Next Generation  
Special Control Deactivation Solenoid  
SDA CODE:  
VEHICLE PROGRAM: Pass Car

*Switch*

CHARACTERISTIC TYPE

▽ = FORD CRITICAL CHARACTERISTICS

S.C. = FORD OR SUPPLIER SIGNIFICANT CHARACTERISTICS

NUMBER OF CRITICAL AND SIGNIFICANT CHARACTERISTICS:

1:	<u>Activation Pressure</u>	TYPE: <u>SC</u>	Cp = <u>**</u>	Cpk = <u>**</u>
2:	<u>Release Pressure</u>	TYPE: <u>SC</u>	Cp = <u>**</u>	Cpk = <u>**</u>
3:	<u>3/8-24UNF-2A TH.</u>	TYPE: <u>SC</u>	Cp = <u>A*</u>	Cpk = <u>A*</u>
4:		TYPE: _____	Cp = _____	Cpk = _____
5:		TYPE: _____	Cp = _____	Cpk = _____
6:		TYPE: _____	Cp = _____	Cpk = _____
7:		TYPE: _____	Cp = _____	Cpk = _____
8:		TYPE: _____	Cp = _____	Cpk = _____
9:		TYPE: _____	Cp = _____	Cpk = _____
10:		TYPE: _____	Cp = _____	Cpk = _____
11:		TYPE: _____	Cp = _____	Cpk = _____
12:		TYPE: _____	Cp = _____	Cpk = _____
13:		TYPE: _____	Cp = _____	Cpk = _____
14:		TYPE: _____	Cp = _____	Cpk = _____
15:		TYPE: _____	Cp = _____	Cpk = _____

PIST =  $\frac{18.33}{18.33} \times 100 = 100\%$

PIPC<sub>Cp</sub> = \_\_\_\_\_ x 100 = \_\_\_\_\_ %    PIPC<sub>Cpk</sub> = \_\_\_\_\_ x 100 = \_\_\_\_\_ %

COMMENTS:

\*\* Calibration check is done 100%, Parts tested 300, defective 0, percent of defect 0.

A\* Threads are checked on a Go/NoGo Gage

PREPARED BY:

ELAINE ROSE

DATE: 8-4-92

**TEXAS INSTRUMENTS, INC. ISIR SUBMISSION  
TO DANA CORPORATION  
FOR PART NUMBER F2AC-9F924-AA (77PSL3-1)**

SAMPLE REPORT

REASON FOR REPORT	VENDOR	P.O.	PART NO.	REV.
NEW PART			77RS63-1	A
REPLACEMENT TOOL.	REPORT REQ BY	DATE	INSPECTED BY	DATE
CORRECTED TOOL.	Elaine Rose	4/14/92	Sandy Gilbert	4/20/92
REPAIRED TOOL.	THE DIMENSIONS INDICATED BELOW REPRESENT TEXAS INSTRUMENTS' FINDINGS REGARDING THE ACTUAL VALUES FOR ALL CHARACTERISCS MEASURED. IN CASES WHERE ACTUAL VALUES DEVIATE FROM THE SPECIFIED DIMENSIONS, THE DISPOSITION MUST INDICATE THE REQUIRED ACTION FOR EACH NON-CONFORMANCE IN THE APPROPRIATE COLUMN.			
REVIEW				
OTHER <u>Dim analysis</u> X				

Dimension	(CIRCLE ALL OUT OF TOLERANCE DIMENSIONS)						DISPOSITION	
	1	2	3	4	5	6	Method of Correction	
1 1.85-2.06	1.933	1.933	1.942	1.956	1.980	1.927	Trim	
2 $\phi$ 19.05 max	18.687	18.692	18.583	18.755	18.783	18.655	"	
3 .25-.75	0.519	0.561	0.552	0.522	0.552	0.585	"	REWORK
4 2.79-3.10 2 pks	0.748	0.804	0.762	0.805	0.884	0.887	Cal	
	2.90	2.90	2.91	2.92	2.91	2.91	"	
	2.91	2.92	2.93	2.94	2.92	2.94	"	
5 19.45-19.81	19.65	19.70	19.71	19.73	19.75	19.73	"	
6 11.40-11.90	11.794	11.797	11.792	11.790	11.784	11.783	Trim	
7 16.56-16.76	16.623	16.652	16.636	16.654	16.626	16.621	"	
8 2.84-3.05	2.936	2.948	2.927	2.924	2.910	2.919	"	
$\phi$ 0.1 $\phi$ A	0.035	0.017	0.018	0.006	0.043	0.050	"	
9 1.24-1.45	1.241	1.242	1.249	1.260	1.270	1.258	"	
10 11.60-11.92	11.864	11.719	11.725	11.681	11.682	11.726	"	
11 1.24-1.55	1.384	1.397	1.393	1.397	1.425	1.388	"	
12 57.15 MAX	55.64	55.65	55.69	55.75	55.75	55.71	Cal	
13 12.59-13.11	12.824	12.862	12.914	12.933	12.850	12.86	NO	
14 11.65-12.17	12.023	12.025	12.146	12.126	12.068	0.88	"	
	11.963	11.923	12.056	12.081	12.011	12.053	"	
15 6.60-6.81	6.702	6.696	6.690	6.680	6.708	6.712	Trim	
16 No flash or burrs on this surface	OK	OK	OK	OK	OK	OK	Visual	
17 2.79-3.41	3.053	3.164	3.162	3.205	3.187	3.25	Comp	
18 0.68-1.30	1.137	1.066	1.153	1.165	1.071	1.117	"	
19 Stamp Date code & Ford PN.	OK	OK	OK	OK	OK	OK	Visual	

REMARKS AND/OR INSTRUCTIONS:

DISPOSITION: TOOL APPROVED FOR PROD.	RESUBMISSION REQ'D
MFG. ENG.:	QRA ENG.:
	PURCH. AGENT:

## SAMPLE REPORT

REASON FOR REPORT	VENDOR	P.O.	PART NO.	KEY
NEW PART			77P563-1	A
REPLACEMENT TOOL	REPORT REQ. BY	DATE	INSPECTED BY	DATE
CORRECTED TOOL	Elaine Rose	4/14/92	Sandy Gilbert	4/20/92
REPAIRED TOOL	THE DIMENSIONS INDICATED BELOW REPRESENT TEXAS INSTRUMENTS' FINDINGS REGARDING THE ACTUAL VALUES FOR ALL CHARACTERISTICS MEASURED. IN CASES WHERE ACTUAL VALUES DIFFER FROM THE SPECIFIED DIMENSIONS, THE DISPOSITION MUST INDICATE THE REQUIRED ACTION FOR EACH NON-CONFORMANCE IN THE APPROPRIATE COLUMN.			
REVIEW				
OTHER	Dim analysis X			

Dimension	(CIRCLE ALL OUT OF TOLERANCE DIMENSIONS)						DISPOSITION	
	1	2	3	4	5	6	Key	Disposition
1 1.85 - 2.06	1.933	1.933	1.942	1.956	1.900	1.927	Time	
2 19.05 max	18.804	18.811	18.784	18.799	18.784	18.811		
3 .25 - .25	0.518	0.561	0.552	0.522	0.558	0.546		REWORK
4 2.79 - 3.10 2 pts	2.90	2.90	2.91	2.92	2.91	2.91	OK	
5 19.45 - 19.81	19.65	19.70	19.71	19.73	19.75	19.73		
6 11.40 - 11.90	11.794	11.797	11.791	11.790	11.784	11.78	Time	
7 16.56 - 16.76	16.623	16.652	16.636	16.654	16.626	16.628		
8 2.84 - 3.05	2.936	2.948	2.922	2.924	2.910	2.919		
9 0.15 A	0.035	0.017	0.018	0.026	0.015	0.020		
10 1.24 - 1.45	1.241	1.242	1.249	1.260	1.270	1.252		
11 11.60 - 11.92	11.864	11.719	11.725	11.681	11.682	11.726		
12 1.24 - 1.55	1.384	1.397	1.393	1.397	1.425	1.38		
13 57.15 max	55.64	55.05	55.01	56.75	55.75	55.71	OK	
14 12.51 - 13.11	12.824	12.862	12.914	12.933	12.850	12.86	NO	
15 11.65 - 12.17	12.023	12.025	12.146	12.126	12.068	12.01		
16 6.00 - 6.81	6.702	6.686	6.670	6.670	6.708	6.70	Time	
17 1.05 - 1.30	OK	OK	OK	OK	OK	OK	OK	
18 2.79 - 3.41	3.053	3.164	3.162	3.205	3.187	3.25	COMA	
19 0.68 - 1.30	1.137	1.016	1.103	1.165	1.071	1.117		
20 Stamp date code	OK	OK	OK	OK	OK	OK	OK	
21 Fold PAN								

REMARKS AND/OR INSTRUCTIONS:

DISPOSITION: TOOL APPROVED FOR PRODUCTION	1ER 105 RESUBMISSION OF 105
MFG. ENG.:	QRA ENG.:
	PURCH. AGENT:



SAMPLE REPORT

F 3 20 7134 40

REASON FOR REPORT	VENDOR	P.O.	PART NO.	REV.
NEW PART			77PSL3-1	A
REPLACEMENT TOOL.	REPORT REQ. BY	DATE	INSPECTED BY	DATE
CORRECTED TOOL.	Elaine Rose	4/14/92	Sandy Gilbert	4/20/92
REPAIRED TOOL.	THE DIMENSIONS INDICATED BELOW REPRESENT TEXAS INSTRUMENTS FINDINGS REGARDING THE ACTUAL VALUES FOR ALL CRITICAL DIMENSIONS MEASURED IN THIS WORK ORDER. DEVIATIONS FROM THE SPECIFIED DIMENSIONS. THE DISPOSITION MUST INDICATE THE REQUIRED ACTION FOR EACH NON-CONFORMANCE IN THE APPROPRIATE COLUMN.			
REVIEW				
OTHER	Dim analysis X			

Dimension	(CIRCLE ALL OUT OF TOLERANCE DIMENSIONS)						DISPOSITION
	1	2	3	4	5	6	
39 Cont	24° 21'	23° 31'	23° 42'	23° 47'	24° 28'	23° 26'	OK
40 Housing to be	OK	OK	OK	OK	OK	OK	OK
Wet/KH: in color							
41 (71.5°) 2 pks	71° 49'	71° 25'	72° 21'	71° 45'	71° 43'	71° 44'	OK
	72° 27'	72° 21'	72° 14'	72° 30'	72° 5'	72° 34'	

REMARKS AND/OR INSTRUCTIONS:

DISPOSITION: TOOL APPROVED FOR PRODUCTION	RESUBMISSION REQ'D
MFG. ENG.:	QRA ENG.:
	PURCH. AGENT:

SAMPLE REPORT

F2AC-9F924-AA

REASON FOR REPORT	VENDOR	P.O.	PART NO.	REV.
NEW PART			77PSL3-1	A
REPLACEMENT TOOL	REPORT REQ BY	DATE	INSPECTED BY	DATE
CORRECTED TOOL	Elaine Rose	4/14/92	Sandy Gilbert	4/10/92
REPAIRED TOOL	THE DIMENSIONS INDICATED BELOW REPRESENT TEXAS INSTRUMENTS' FINDINGS REGARDING THE ACTUAL VALUES FOR ALL CHARACTERISTICS MEASURED. IN CASES WHERE ACTUAL VALUES DEVIATE FROM THE SPECIFIED DIMENSIONS, THE DISPOSITION MUST INDICATE THE REQUIRED ACTION FOR EACH NON-CONFORMANCE IN THE APPROPRIATE COLUMN.			
REVIEW				
OTHER <i>Dim analysis</i> X				

DIMENSION	(CIRCLE ALL OUT OF TOLERANCE DIMENSIONS)						DISPOSITION	
	1	2	3	4	5	6	METHOD OF INSPECTION	
20 3/8-24 UNF 2A	OK	OK	OK	OK	OK	OK	OK	PS
3667-.3739 <i>Dimension</i>	3715	3725	3710	3715	3705	3710		Cal
21 1.10-1.40	1.224			section				Time
22 <i>4.5</i>	OK	<i>1.5</i>		section				Auto Meter
23 <i>0.16 Dim by same</i>								
24 41°-43°	42°10'			section				Time
25 40°-50° Chamfer	44°24'	44°7'	41°57'	46°6'	45°53'	46°9'		Comp
26 7.82-8.03	7.940	8.001	7.932	7.919	7.950	7.910		"
27 1.52-2.04	1.836	1.897	1.783	1.821	1.823	1.783		"
28 9.39-9.66	9.433	9.442	9.462	9.504	9.507	9.442		2ND
29 8.12 min	8.913	9.104	8.945	8.900	8.950	8.884		"
30 14.23 max	13.64	13.58	13.50	13.53	13.50	13.56		Cal
31 32.51 max	31.40	31.63	31.61	31.58	31.66	31.75		"
32 5.58-5.85	5.702	5.667	5.697	5.687	5.679	5.679		Time
33 7.23-7.37	7.296	7.263	7.323	7.282	7.311	7.286		"
34 3.30-3.60	3.439	3.466	3.438	3.418	3.429	3.438		"
35 11.02-11.53 Hex	11.13	11.34	11.24	11.13	11.14	11.14		Cal
36 0.58-0.68 2 pks	0.626	0.620	0.623	0.625	0.624	0.627		Time
	0.664	0.665	0.653	0.670	0.664	0.665		"
37 2.59-2.80 2 pks	2.699	2.682	2.721	2.703	2.674	2.668		"
	2.625	2.621	2.677	2.625	2.630	2.638		"
⊕ 0.25 (D) AB	0.013	0.019	0.041	0.004	0.033	0.014		"
	0.047	0.072	0.062	0.112	0.143	0.112		"
38 8.20-8.72 2 pks	8.321	8.312	8.488	8.376	8.346	8.318		Comp
	8.430	8.475	8.445	8.524	8.369	8.328		"
39 25°±4° 2 pks	23°52'	24°24'	24°1'	24°54'	23°36'	25°4'		"

REMARKS AND/OR INSTRUCTIONS:

DISPOSITION: TOOL APPROVED FOR PROD.	RESUBMISSION REQ'D
MFG. ENG.:	QRA ENG.:
	PURCH. AGENT:

# TEXAS INSTRUMENTS

ADDRESS: 4400 W. LAMAR BLVD. DALLAS, TEXAS 75242



PAGE 2 OF 3

## SAMPLE REPORT

F2AL-9F924-AA

REASON FOR REPORT	VENDOR	P.O.	PART NO.	REV.
NEW PART			77PSL3-1	A
REPLACEMENT TOOL	REPORT REQ. BY	DATE	INSPECTED BY	DATE
CORRECTED TOOL	Elaine Rose	4/14/82	Sandy Gilbert	4/20/82
REPAIRED TOOL	THE DIMENSIONS INDICATED BELOW REPRESENT TEXAS INSTRUMENTS FINDINGS REGARDING THE ACTUAL VALUES FOR ALL CHARACTERISTICS MEASURED. IN CASES WHERE ACTUAL VALUES DEVIATE FROM THE SPECIFIED DIMENSIONS, THE DISPOSITION MUST INDICATE THE REQUIREMENT FOR EACH NON-CONFORMANCE IN THE APPROPRIATE COLUMN.			
REVIEW	F2AL-117			
OTHER <u>Dim analysis</u> X				

Dimension	(CIRCLE ALL OUT OF TOLERANCE DIMENSIONS)						DISPOSITION
	1	2	3	4	5	6	
20 3/2-24 UNF 2A	OK	OK	OK	OK	OK	OK	OK
3667-3739	3715	3725	3710	3715	3705	3710	OK
21 1.10-1.40	1.224			section			OK
22 1.00-1.25	1.05	.95		section			OK
23 0.76-0.90 chamfer				section			OK
24 41°-43°	42°10'			section			OK
25 40°-50° chamfer	44°24'	44°7'	41°57'	46°6'	45°53'	44°4'	COMP
26 7.82-8.03	7.940	8.001	7.932	7.919	7.950	7.910	"
27 1.52-2.04	1.836	1.897	1.783	1.821	1.823	1.713	"
28 9.39-9.66	9.433	9.442	9.462	9.504	9.507	9.400	2ND
29 8.12 min	8.913	9.104	8.948	8.900	8.960	8.881	"
30 14.23 max	13.64	13.58	13.50	13.53	13.50	13.56	OK
31 32.51 max	31.40	31.63	31.61	31.58	31.66	31.48	"
32 5.58-5.85	5.72	5.87	5.81	5.71	5.89	5.80	OK
33 7.23-7.37	7.30	7.36	7.35	7.33	7.31	7.30	"
34 3.30-3.60	3.45	3.46	3.48	3.49	3.47	3.46	"
35 14.02-14.53 Max	14.32	14.34	14.31	14.13	14.14	14.16	OK
36 0.58-0.68 2PKS	0.626	0.620	0.623	0.625	0.624	0.620	OK
37 2.59-2.80 2 pks	2.671	2.682	2.721	2.703	2.674	2.681	"
38 0.25 (D) A B	0.073	0.079	0.071	0.074	0.073	0.074	"
39 8.30-8.72 2 pks	8.321	8.318	8.481	8.376	8.346	8.343	OK
39 25° 4' 2 pks	23° 52'	24° 24'	24° 1'	24° 54'	23° 36'	25° 4'	"

REMARKS AND/OR INSTRUCTIONS:

DISPOSITION: TOOL APPROVED FOR PROG. <u>1</u>	RESUBMISSION REQ'D
MFG. ENG.:	QRA ENG.:
	PURCH. AGENT:

FORM NO. 2078A

**DRAWINGS AVAILABLE UPON  
REQUEST**

TEXAS INSTRUMENTS INCORPORATED  
 CONTROL PRODUCTS DIVISION  
 ATTLEBORO, MASSACHUSETTS 02703

QUALITY ASSURANCE WORK ORDER

\* INDICATE TYPE OF SERVICE REQUESTED:  FIRST ARTICLE INSPECTION  
 PARTIAL "FAI"  
 TOOLPROOF  
 DIMENSIONAL ANALYSIS  
 MACHINE CAPABILITY  
 PROCESS CAPABILITY

NOTICE: TWO COPIES OF THE DRAWING MUST BE INCLUDED WITH YOUR REQUEST.  
 REPORTING SUPPLIER F.A.I. INCLUDED WITH THIS REQUEST: YES/NO

\* INDICATE ONE OF THE FOLLOWING REASONS:  NEW PART / NEW TOOL / MOLD  
 CORRECTED TOOL / MOLD  
 OTHER \_\_\_\_\_

(V F2AC-9F924-AA)

\* PART NUMBER: 77PSL3-1 DRAWING REVISION: A  
 NUMBER OF CAVITIES / STATIONS 6 TOOL ID: \_\_\_\_\_  
 TYPE OF MATERIAL: NORYL PART DESCRIPTION: PRESSURE SWITCH  
 SUPPLIER: \_\_\_\_\_ SAMPLE / MOLD DATE: \_\_\_\_\_

\* DATE SUBMITTED: 4-14-92 DATE RECEIVED: 4/24/92  
 REQUESTED BY: ELAINE ROSE N/S: 15-27  
 COST CENTER: 149 PRODUCT CODE: 88 EXT: 1907  
 PRIORITY ( INDICATE ONE ):  URGENT \*  AS DATED

\*\* "URGENT" PRIORITY REQUIRES MANAGER'S APPROVAL

APPROVED BY ( IF REQUIRED ): M. DeWalt

ENGINEERING SPECIAL INSTRUCTIONS

NOTES

- 1.) A "FIRST ARTICLE INSPECTION", "PARTIAL F.A.I.", OR A "TOOLPROOF", ALL REQUIRE A "DISPOSITION" FROM THE MATERIALS REVIEW BOARD, INCLUDING ALL APPROPRIATE COMMENTS. ALSO, THE DISPOSITIONED COPY MUST BE RETURNED TO RECEIVING INSPECTION CCI146 FOR PROPER RECORDING.
- 2.) RECORDS: A) COPIES OF ALL "FIRST ARTICLE INSPECTIONS" ( INCLUDING PARTIALS ) WILL BE RETAINED BY RECEIVING INSPECTION FOR SEVEN YEARS.  
 B) RECORDS OF ALL OTHER ANALYSIS WILL NOT BE RETAINED BY RECEIVING INSPECTION.
- 3.) "DIMENSIONAL ANALYSIS": ANY REQUEST FOR A DIMENSIONAL ANALYSIS THAT INCLUDES ALL DIMENSIONS, OR ALL "CRITICAL" & "TOLERANCE" DIMENSIONS, WILL BE CONSIDERED A "FIRST ARTICLE INSPECTION" OR A "TOOLPROOF", AND WILL REQUIRE DISPOSITION BY THE MATERIALS REVIEW BOARD. THE APPROVED COPY MUST BE RETURNED TO RECEIVING INSPECTION CCI146.

QUALITY ASSURANCE

DATE REC.: \_\_\_\_\_  
 EST. HRS.: \_\_\_\_\_  
 COMPLETED: \_\_\_\_\_  
 BY: \_\_\_\_\_

RECEIVING INSPECTION

77PSL3-1

Act. 90-160psi

6-29-92

Data obtained Apr. 16, 92

pg. 143

1	129.5	125.9	131.4	* 172.0	127.6	141.4
2	139.4	127.2	132.6	139.8		140.5
3	129.7	123.3	133.2	129.4		130.8
4	134.0	131.2	125.9	131.6		138.7
5	140.5	122.5	140.4	132.5		133.4
6	134.7	123.5	133.2	136.1		137.9
7	130.7	138.9	132.4	130.4		134.6
8	123.3	132.0	139.1	136.1		129.9
9	130.4	120.2	127.6	125.0		128.4
10	124.9	122.5	137.5	130.4		126.5
11	132.4	122.1	131.3	133.2		125.9
12	129.8	125.3	129.0	131.0		126.0
13	123.6	127.1	125.3	127.2		129.2
14	129.1	125.2	133.2	132.2		132.2
15	131.7	130.9	130.4	127.2		126.7
16	127.3	129.3	124.3	129.2		127.2
17	121.0	140.5	132.4	126.7		132.4
18	126.2	125.5	129.1	125.3		125.0
19	136.2	121.3	119.2	122.3		139.7
20	133.3	122.2	132.4	126.2		125.2
21	129.0	134.0	135.2	127.6		124.7
22	122.2	127.4	120.6	123.6		127.5
23	121.6	130.4	122.2	134.0		126.6
24	141.3	122.0	* 127.2	143.6	142.2	122.2
25	120.7	122.7	122.5	135.9		122.5
26	123.6	125.9	123.4	134.5		128.7
27	131.7	127.0	125.4	132.2		123.5
28	127.5	126.0	131.2	122.0		126.6
29	122.1	122.3	124.4	121.2		126.9
30	122.3	122.6	121.2	122.2		122.2
31	121.9	127.2	125.5	121.2		122.2
32	127.6	121.7	122.2	122.5		122.2
33	134.5	129.2	122.2	122.1		122.2
34	130.5	121.6	122.7	121.7		122.2
35	122.2	121.6	122.1	122.2		122.2
36	120.7	122.2	122.2	122.2		122.2
37	125.6	122.2	122.1	122.2		122.2
38	121.7	122.2	122.2	122.2		122.2
39	122.6	122.0	122.1	122.2		122.2
40	122.5	122.2	122.2	122.2		122.2
41	121.9	122.1	122.2	122.2		122.2
42	122.4	122.1	122.2	122.2		122.2
43	125.9	122.5	122.4	122.0		122.5
44	121.9	122.3	122.7	122.3		122.2
45	122.7	122.2	122.2	122.6		122.2
46	126.3	125.6	122.6	122.1		122.4
47	122.2	122.4	122.5	122.4		122.4
48	122.0	122.9	122.0	122.2		122.2
49	121.2	122.6	122.2	122.1		122.2
50	123.2	122.6	121.0	122.7		122.5

77PSL3-1

Oct.

6-29-92

Data obtained Apr. 16 1992

A. 272

1	131.7								
2	128.2								
3	131.7								
4	134.4								
5	137.1								
6	120.5								
7	130.3								
8	133.4								
9	124.2								
10	133.9								
11	133.7								
12	130.6								
13	128.1								
14	128.9								
15	130.8								
16	133.3								
17	127.2								
18	130.8								
19	129.5								
20	130.3								
21	129.8								
22	126.1								
23	127.1								
24	130.7								
25	134.7								
26	127.6								
27	127.2								
28	123.1								
29	122.9								
30	125.2								
31	130.5								
32	123.6								
33	121.3								
34	124.2								
35	131.5								
36	127.6								
37	125.6								
38	128.1								
39	133.1								
40	126.6								
41	129.4								
42	127.5								
43	129.9								
44	125.2								
45	124.0								
46	122.9								
47	131.0								
48	123.8								
49	123.8								
50	126.9								

1	100.0	97.1	95.9	140.7	89.5	111.0
2	104.0	95.2	90.2	97.1		116.0
3	88.1	93.4	103.8	95.8		106.3
4	95.6	93.5	91.4	90.9		104.0
5	111.6	85.6	113.1	99.9		98.3
6	102.0	98.4	100.6	102.3		102.2
7	98.1	103.9	94.4	96.6		102.2
8	84.2	107.9	105.9	97.8		100.9
9	105.3	87.1	100.8	91.8		97.6
10	90.2	88.1	104.7	96.6		95.1
11	97.1	94.5	100.8	88.4		96.3
12	99.8	101.8	97.0	97.6		94.2
13	100.0	104.8	92.2	93.3		97.4
14	98.6	102.3	102.1	95.7		97.4
15	106.4	104.6	98.2	102.3		104.6
16	105.3	90.9	93.6	99.3		93.7
17	95.9	104.6	104.7	93.2		102.5
18	106.1	104.6	89.9	86.7		92.7
19	109.7	93.6	88.7	98.1		108.2
20	96.2	94.3	98.5	90.9		92.3
21	108.9	102.1	107.8	94.4		103.5
22	98.4	92.4	93.8	96.7		94.6
23	93.6	100.1	* 96.0	100.3	112.8	94.6
24	106.5	94.1	92.6	112.3		101.1
25	85.3	89.4	96.1	105.2		92.0
26	98.1	89.4	89.6	100.3	7.6	90.3
27	97.0	91.8	94.1	101.0	7.2	105.4
28	97.0	91.8	94.1	98.4	7.1	89.3
29	98.6	100.7	101.6	97.2		92.8
30	100.9	107.5	100.8	93.2		98.5
31	97.0	93.3	97.1	97.7		89.0
32	95.8	88.2	94.6	96.4		97.1
33	103.7	96.5	106.1	106.5		82.4
34	99.5	98.6	96.9	101.1		95.0
35	98.5	88.7	99.5	90.4		95.0
36	88.6	88.0	91.8	104.0		88.3
37	104.5	99.4	100.5	97.6		91.8
38	98.1	90.8	97.5	102.6		97.7
39	105.9	92.4	103.5	106.3		97.9
40	101.9	97.9	93.5	90.4		92.6
41	94.9	98.8	96.6	98.2		91.8
42	103.4	93.6	87.2	100.0		99.3
43	93.4	97.4	88.5	102.9		83.9
44	100.9	94.9	104.6	98.8		103.0
45	87.2	103.8	108.9	100.4		104.2
46	83.8	90.8	95.8	90.6		100.2
47	96.3	96.9	97.3	102.9		96.4
48	100.1	102.2	92.4	95.5		108.1
49	101.4	97.2	102.1	104.1		92.3
50	98.8	89.7	98.3	101.6		107.8

77PSL3-1

6-21-92

Data obtained Apr. 16-92

Cal.

pg. 2 of 2

1	102.4								
2	92.3								
3	100.8								
4	99.5								
5	100.8								
6	87.5								
7	95.2								
8	100.1								
9	98.8								
10	101.2								
11	101.4								
12	102.8								
13	92.7								
14	101.4								
15	95.9								
16	101.0								
17	92.5								
18	95.9								
19	95.7								
20	98.5								
21	107.8								
22	94.9								
23	91.1								
24	97.2								
25	104.8								
26	97.2								
27	93.6								
28	89.0								
29	86.1								
30	88.0								
31	100.6								
32	81.2								
33	96.8								
34	100.6								
35	97.6								
36	103.6								
37	88.8								
38	88.6								
39	98.5								
40	101.0								
41	98.6								
42	103.6								
43	95.5								
44	93.0								
45	104.4								
46	87.3								
47	90.1								
48	90.6								
49	97.5								
50	91.8								

17-APR-1992 09:43:52.38 OPER DOOR DID NOT CLOSE 1

17-APR-1992 09:44:12.33 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 09:44:29.38 TOOL CYCLE TIMEOUT 1

7798 PRESSURE TESTER LOT REPORT

RATONB177P6L2-1  
LOT ID: MASTERG  
LOT STARTED: 17-APR-1992 09:43:29.56  
LOT FINISHED: 17-APR-1992 10:11:04.07

SETUP DATA:

DISC LOT ID: 0.00  
DISC MEAN (ACT) 23.4 MEAN REL: 12.7  
LIMIT (MC)  
ACTUATION: 90.0 TO 160.0 PSI  
RELEASE: 20.0 TO 120.0 PSI  
DIFFERENTIAL: 0.0 TO 160.0 PSI  
MAX MILLIVOLT: 500.0 PSI  
ACT CREEP TIME: 25.0 PSI  
REL CREEP TIME: 130.0 PSI  
PRECYCLE PRESS: 800.0 PSI  
PRECYCLE COUNT: 2

NOT ENOUGH PARTS FOR REPORT ON FIXTURE 0

SER 1; FIX 1; C= 000000; BIN=GOOD; NPSU=43.7; NPSD=47.4; LEAK RATE= 2.0  
ACT= 129.2; REL= 100.0; DIF= 29.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 2; FIX 2; C= 000000; BIN=GOOD; NPSU=43.7; NPSD=47.4; LEAK RATE= 2.0  
ACT= 139.4; REL= 104.0; DIF= 35.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 3; FIX 3; C= 000000; BIN=GOOD; NPSU=43.7; NPSD=47.4; LEAK RATE= 2.0  
ACT= 129.7; REL= 88.1; DIF= 41.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 4; FIX 4; C= 000000; BIN=GOOD; NPSU=43.7; NPSD=47.4; LEAK RATE= 2.0  
ACT= 134.0; REL= 98.6; DIF= 35.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:11:26.79 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:11:46.79 OPER DOOR STILL DID NOT CLOSE 1

SER 5; FIX 1; C= 000000; BIN=GOOD; NPSU=44.1; NPSD=48.2; LEAK RATE= 2.0  
ACT= 140.5; REL= 111.6; DIF= 28.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 6; FIX 2; C= 000000; BIN=GOOD; NPSU=44.1; NPSD=48.2; LEAK RATE= 2.0  
ACT= 134.7; REL= 102.0; DIF= 32.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 7; FIX 3; C= 000000; BIN=GOOD; NPSU=44.1; NPSD=48.2; LEAK RATE= 2.0  
ACT= 130.7; REL= 98.1; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 8; FIX 4; C= 000000; BIN=GOOD; NPSU=44.1; NPSD=48.2; LEAK RATE= 2.0  
ACT= 123.0; REL= 84.2; DIF= 39.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:12:34.38 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:12:54.38 OPER DOOR STILL DID NOT CLOSE 1

SER 9; FIX 1; C= 000000; BIN=GOOD; NPSU=44.1; NPSD=48.1; LEAK RATE= 2.0  
ACT= 139.4; REL= 105.3; DIF= 34.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 10; FIX 2; C= 000000; BIN=GOOD; NPSU=44.1; NPSD=48.1; LEAK RATE= 2.0  
ACT= 124.9; REL= 90.2; DIF= 34.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 11; FIX 3; C= 000000; BIN=GOOD; NPSU=44.1; NPSD=48.1; LEAK RATE= 2.0  
ACT= 132.4; REL= 97.1; DIF= 35.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:22:26.46 OPER DOOR DID NOT CLOSE 1

BER 13; FIX 1; C= 0000000; BIN=8008; NFRU=44.1; NFRD=47.3; LEAK RATE= 1.9  
ACT= 133.6; REL= 100.0; DIF= 33.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

BER 14; FIX 2; C= 0000000; BIN=8008; NFRU=44.1; NFRD=47.3; LEAK RATE= 1.9  
ACT= 129.1; REL= 92.6; DIF= 36.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

BER 15; FIX 3; C= 0000000; BIN=8008; NFRU=44.1; NFRD=47.3; LEAK RATE= 1.9  
ACT= 134.7; REL= 106.4; DIF= 28.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

BER 16; FIX 4; C= 0000000; BIN=8008; NFRU=44.1; NFRD=47.3; LEAK RATE= 1.9  
ACT= 137.3; REL= 105.3; DIF= 32.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:23:09.05 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:23:29.05 OPER DOOR STILL DID NOT CLOSE 1

BER 17; FIX 1; C= 0000000; BIN=8008; NFRU=43.7; NFRD=48.1; LEAK RATE= 1.7  
ACT= 131.0; REL= 93.9; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

BER 18; FIX 2; C= 0000000; BIN=8008; NFRU=43.7; NFRD=48.1; LEAK RATE= 1.7  
ACT= 136.8; REL= 106.1; DIF= 30.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

BER 19; FIX 3; C= 0000000; BIN=8008; NFRU=43.7; NFRD=48.1; LEAK RATE= 1.7  
ACT= 136.8; REL= 107.7; DIF= 29.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

20 BER 20; FIX 4; C= 0000000; BIN=8008; NFRU=43.7; NFRD=48.1; LEAK RATE= 1.7  
ACT= 133.3; REL= 98.2; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

BER 21; FIX 1; C= 0000000; BIN=8008; NFRU=44.1; NFRD=47.2; LEAK RATE= 1.9  
ACT= 139.0; REL= 108.9; DIF= 30.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

BER 22; FIX 2; C= 0000000; BIN=8008; NFRU=44.1; NFRD=47.2; LEAK RATE= 1.9  
ACT= 128.8; REL= 98.4; DIF= 30.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

BER 23; FIX 3; C= 0000000; BIN=8008; NFRU=44.1; NFRD=47.2; LEAK RATE= 1.9  
ACT= 131.6; REL= 73.6; DIF= 58.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 24; FIX 4; C= 000000; BIN=GOOD; NFRU=44.1; NFRD=47.2; LEAK RATE= 1.9  
ACT= 141.3; REL= 106.5; DIF= 34.8 PSI; ACTDR= 200.0ms; RELCR= 200.0

SER 25; FIX 1; C= 000000; BIN=GOOD; NFRU=44.4; NFRD=48.5; LEAK RATE= 2.2  
ACT= 129.7; REL= 85.3; DIF= 35.4 PSI; ACTDR= 200.0ms; RELCR= 200.0

SER 26; FIX 2; C= 000000; BIN=GOOD; NFRU=44.4; NFRD=48.5; LEAK RATE= 2.2  
ACT= 123.6; REL= 98.1; DIF= 35.4 PSI; ACTDR= 200.0ms; RELCR= 200.0

SER 27; FIX 3; C= 000000; BIN=GOOD; NFRU=44.4; NFRD=48.5; LEAK RATE= 2.2  
ACT= 131.7; REL= 97.0; DIF= 34.6 PSI; ACTDR= 200.0ms; RELCR= 200.0

SER 28; FIX 4; C= 000000; BIN=GOOD; NFRU=44.4; NFRD=48.5; LEAK RATE= 2.2  
ACT= 127.5; REL= 97.0; DIF= 30.5 PSI; ACTDR= 200.0ms; RELCR= 200.0

SER 29; FIX 1; C= 000000; BIN=GOOD; NFRU=44.2; NFRD=47.9; LEAK RATE= 2.2  
ACT= 132.1; REL= 99.6; DIF= 32.5 PSI; ACTDR= 200.0ms; RELCR= 200.0

30 SER 30; FIX 2; C= 000000; BIN=GOOD; NFRU=44.2; NFRD=47.9; LEAK RATE= 2.2  
ACT= 128.3; REL= 100.9; DIF= 27.4 PSI; ACTDR= 200.0ms; RELCR= 200.0

SER 31; FIX 3; C= 000000; BIN=GOOD; NFRU=44.2; NFRD=47.9; LEAK RATE= 2.2  
ACT= 126.9; REL= 91.0; DIF= 35.9 PSI; ACTDR= 200.0ms; RELCR= 200.0

SER 32; FIX 4; C= 000000; BIN=GOOD; NFRU=44.2; NFRD=47.9; LEAK RATE= 2.2  
ACT= 132.6; REL= 95.6; DIF= 38.8 PSI; ACTDR= 200.0ms; RELCR= 200.0

17-APR-1992 10:25:28.45 OPER HOUR DID NOT CLOSE 1

SER 33; FIX 1; C= 000000; BIN=GOOD; NFRU=44.2; NFRD=48.6; LEAK RATE= 1.9  
ACT= 134.5; REL= 103.7; DIF= 30.9 PSI; ACTDR= 200.0ms; RELCR= 200.0

SER 34; FIX 2; C= 000000; BIN=GOOD; NFRU=44.2; NFRD=48.6; LEAK RATE= 1.9  
ACT= 130.5; REL= 99.5; DIF= 31.1 PSI; ACTDR= 200.0ms; RELCR= 200.0

SER 35; FIX 3; C= 000000; BIN=GOOD; NFRU=44.2; NFRD=48.6; LEAK RATE= 1.9  
ACT= 130.5; REL= 99.5; DIF= 31.1 PSI; ACTDR= 200.0ms; RELCR= 200.0

SER 35; FIX 4; C= 000000; BIN=GOOD; NPSL=44.2; NPSD=45.6; LEAK RATE= 1.9  
ACT= 123.7; REL= 68.8; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 37; FIX 1; C= 000000; BIN=GOOD; NPSL=44.1; NPSD=48.4; LEAK RATE= 2.0  
ACT= 135.6; REL= 104.5; DIF= 31.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 38; FIX 2; C= 000000; BIN=GOOD; NPSL=44.1; NPSD=48.4; LEAK RATE= 2.0  
ACT= 131.7; REL= 98.1; DIF= 33.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 39; FIX 3; C= 000000; BIN=GOOD; NPSL=44.1; NPSD=48.4; LEAK RATE= 2.0  
ACT= 139.6; REL= 108.9; DIF= 33.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

40 SER 40; FIX 4; C= 000000; BIN=GOOD; NPSL=44.1; NPSD=48.4; LEAK RATE= 2.0  
ACT= 133.5; REL= 101.9; DIF= 31.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:26:35.20 OPER DOOR DID NOT CLOSE 1

SER 41; FIX 1; C= 000000; BIN=GOOD; NPSL=44.1; NPSD=47.7; LEAK RATE= 1.9  
ACT= 124.9; REL= 94.7; DIF= 30.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 42; FIX 2; C= 000000; BIN=GOOD; NPSL=44.1; NPSD=47.7; LEAK RATE= 1.9  
ACT= 128.4; REL= 103.4; DIF= 24.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 43; FIX 3; C= 000000; BIN=GOOD; NPSL=44.1; NPSD=47.7; LEAK RATE= 1.9  
ACT= 125.9; REL= 93.4; DIF= 32.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 44; FIX 4; C= 000000; BIN=GOOD; NPSL=44.1; NPSD=47.7; LEAK RATE= 1.9  
ACT= 131.9; REL= 100.9; DIF= 31.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:27:06.17 OPER DOOR DID NOT CLOSE 1

SER 45; FIX 1; C= 000000; BIN=GOOD; NPSL=44.2; NPSD=47.5; LEAK RATE= 2.0  
ACT= 129.5; REL= 97.2; DIF= 32.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:27:52.52 OPER DOOR DID NOT CLOSE 1  
SER 47; FIX 3; C: 000000; BIN=GOOD; MFRU=44.2; MFRD=47.5; LEAK RATE= 2.0  
ACT= 129.2; REL= 96.3; DIF= 32.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 48; FIX 4; C: 000000; BIN=GOOD; MFRU=44.2; MFRD=47.5; LEAK RATE= 2.0  
ACT= 134.0; REL= 100.1; DIF= 33.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:28:12.52 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 10:28:26.19 TOOL CYCLE TIMEDOUT 1

SER 49; FIX 1; C: 000000; BIN=GOOD; MFRU=44.3; MFRD=48.1; LEAK RATE= 1.9  
ACT= 131.9; REL= 101.4; DIF= 30.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

*D* SER 50; FIX 2; C: 000000; BIN=GOOD; MFRU=44.3; MFRD=48.1; LEAK RATE= 1.9  
ACT= 133.2; REL= 98.8; DIF= 34.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 51; FIX 3; C: 000000; BIN=GOOD; MFRU=44.3; MFRD=48.1; LEAK RATE= 1.9  
ACT= 125.9; REL= 87.1; DIF= 38.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 52; FIX 4; C: 000000; BIN=GOOD; MFRU=44.3; MFRD=48.1; LEAK RATE= 1.9  
ACT= 127.2; REL= 95.2; DIF= 32.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:31:52.41 OPER DOOR DID NOT CLOSE 1

SER 53; FIX 1; C: 000000; BIN=GOOD; MFRU=44.0; MFRD=47.7; LEAK RATE= 1.9  
ACT= 123.3; REL= 92.4; DIF= 30.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 54; FIX 2; C: 000000; BIN=GOOD; MFRU=44.0; MFRD=47.7; LEAK RATE= 1.9  
ACT= 131.2; REL= 93.5; DIF= 37.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 55; FIX 3; C: 000000; BIN=GOOD; MFRU=44.0; MFRD=47.7; LEAK RATE= 1.9  
ACT= 122.5; REL= 85.6; DIF= 36.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 56; FIX 4; C: 000000; BIN=GOOD; MFRU=44.0; MFRD=47.7; LEAK RATE= 1.9  
ACT= 133.5; REL= 98.4; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 57; FIX 1; C: 000000; BIN=GOOD; MFRU=44.2; MFRD=47.5; LEAK RATE= 1.9

SER 58; FIX 2; C: 000000; BIN=8000; MFRU=44.2; MFRD=47.5; LEAK RATE= 1.9  
ACT= 138.0; REL= 107.9; DIF= 30.1 PSI; ACTDR= 200.0ms; RELDR= 200.0

SER 59; FIX 3; C: 000000; BIN=8000; MFRU=44.2; MFRD=47.5; LEAK RATE= 1.9  
ACT= 120.8; REL= 87.1; DIF= 33.6 PSI; ACTDR= 200.0ms; RELDR= 200.0

60 SER 60; FIX 4; C: 000000; BIN=8000; MFRU=44.2; MFRD=47.5; LEAK RATE= 1.9  
ACT= 122.3; REL= 88.1; DIF= 34.4 PSI; ACTDR= 200.0ms; RELDR= 200.0

17-APR-1992 10:32:33.71 OPER DOOR DID NOT CLOSE 1

SER 61; FIX 1; C: 000000; BIN=8000; MFRU=44.3; MFRD=48.0; LEAK RATE= 2.1  
ACT= 128.1; REL= 94.5; DIF= 33.6 PSI; ACTDR= 200.0ms; RELDR= 200.0

SER 62; FIX 2; C: 000000; BIN=8000; MFRU=44.3; MFRD=48.0; LEAK RATE= 2.1  
ACT= 135.3; REL= 101.8; DIF= 33.4 PSI; ACTDR= 200.0ms; RELDR= 200.0

SER 63; FIX 3; C: 000000; BIN=8000; MFRU=44.3; MFRD=48.0; LEAK RATE= 2.1  
ACT= 137.1; REL= 104.8; DIF= 32.4 PSI; ACTDR= 200.0ms; RELDR= 200.0

SER 64; FIX 4; C: 000000; BIN=8000; MFRU=44.3; MFRD=48.0; LEAK RATE= 2.1  
ACT= 135.8; REL= 103.3; DIF= 32.5 PSI; ACTDR= 200.0ms; RELDR= 200.0

17-APR-1992 10:33:00.40 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:33:20.40 OPER DOOR STILL DID NOT CLOSE 1

SER 65; FIX 1; C: 000000; BIN=8000; MFRU=43.7; MFRD=47.2; LEAK RATE= 1.7  
ACT= 136.9; REL= 104.6; DIF= 32.3 PSI; ACTDR= 200.0ms; RELDR= 200.0

SER 66; FIX 2; C: 000000; BIN=8000; MFRU=43.7; MFRD=47.2; LEAK RATE= 1.7  
ACT= 129.3; REL= 90.9; DIF= 38.4 PSI; ACTDR= 200.0ms; RELDR= 200.0

SER 67; FIX 3; C: 000000; BIN=8000; MFRU=43.7; MFRD=47.2; LEAK RATE= 1.7  
ACT= 140.6; REL= 104.6; DIF= 36.0 PSI; ACTDR= 200.0ms; RELDR= 200.0

SER 68; FIX 4; C: 000000; BIN=8000; MFRU=43.7; MFRD=47.2; LEAK RATE= 1.7  
ACT= 135.5; REL= 104.6; DIF= 30.9 PSI; ACTDR= 200.0ms; RELDR= 200.0

SER 69; FIX 1; C= 0000000; BIN=8000; MRRU=44.2; MRRD=47.8; LEAK RATE= 1.9  
ACT= 131.5; REL= 93.6; DIF= 37.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

70 SER 70; FIX 2; C= 0000000; BIN=8000; MRRU=44.2; MRRD=47.8; LEAK RATE= 1.9  
ACT= 132.8; REL= 94.5; DIF= 38.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 71; FIX 3; C= 0000000; BIN=8000; MRRU=44.2; MRRD=47.8; LEAK RATE= 1.9  
ACT= 134.0; REL= 102.1; DIF= 32.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 72; FIX 4; C= 0000000; BIN=8000; MRRU=44.2; MRRD=47.8; LEAK RATE= 1.9  
ACT= 127.4; REL= 92.4; DIF= 35.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:34:29.53 OPER DOOR DID NOT CLOSE 1

SER 73; FIX 1; C= 0000000; BIN=8000; MRRU=44.1; MRRD=47.5; LEAK RATE= 2.0  
ACT= 130.4; REL= 100.1; DIF= 30.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 74; FIX 2; C= 0000000; BIN=8000; MRRU=44.1; MRRD=47.5; LEAK RATE= 2.0  
ACT= 122.0; REL= 94.1; DIF= 27.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 75; FIX 3; C= 0000000; BIN=8000; MRRU=44.1; MRRD=47.5; LEAK RATE= 2.0  
ACT= 122.7; REL= 89.4; DIF= 33.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 76; FIX 4; C= 0000000; BIN=8000; MRRU=44.1; MRRD=47.5; LEAK RATE= 2.0  
ACT= 125.9; REL= 89.4; DIF= 36.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 77; FIX 1; C= 0000000; BIN=8000; MRRU=44.8; MRRD=47.3; LEAK RATE= 2.0  
ACT= 127.0; REL= 91.8; DIF= 35.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 78; FIX 2; C= 0000000; BIN=8000; MRRU=44.8; MRRD=47.3; LEAK RATE= 2.0  
ACT= 128.0; REL= 91.8; DIF= 34.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 79; FIX 3; C= 0000000; BIN=8000; MRRU=44.8; MRRD=47.3; LEAK RATE= 2.0  
ACT= 129.3; REL= 100.7; DIF= 28.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

80 SER 80; FIX 4; C= 0000000; BIN=8000; MRRU=44.8; MRRD=47.3; LEAK RATE= 2.0  
ACT= 138.6; REL= 107.5; DIF= 31.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 81; FIX 1; C= 0000000; BIN=8000; MRPL=44.3; MRPD=46.8; LEAK RATE= 2.0  
ACT= 127.3; REL= 93.3; DIF= 34.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 82; FIX 2; C= 0000000; BIN=8000; MRPL=44.3; MRPD=46.8; LEAK RATE= 2.0  
ACT= 121.7; REL= 89.8; DIF= 31.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 83; FIX 3; C= 0000000; BIN=8000; MRPL=44.3; MRPD=46.8; LEAK RATE= 2.0  
ACT= 129.2; REL= 94.5; DIF= 34.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 84; FIX 4; C= 0000000; BIN=8000; MRPL=44.3; MRPD=46.8; LEAK RATE= 2.0  
ACT= 131.6; REL= 99.6; DIF= 32.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:35:44.00 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:36:06.00 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 10:36:22.20 TOOL CYCLE TIMEOUT 1

SER 85; FIX 1; C= 0000000; BIN=8000; MRPL=43.9; MRPD=47.8; LEAK RATE= 2.1  
ACT= 131.6; REL= 96.7; DIF= 34.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 86; FIX 2; C= 0000000; BIN=8000; MRPL=43.9; MRPD=47.8; LEAK RATE= 2.1  
ACT= 117.2; REL= 83.0; DIF= 34.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 87; FIX 3; C= 0000000; BIN=8000; MRPL=43.9; MRPD=47.8; LEAK RATE= 2.1  
ACT= 130.4; REL= 99.4; DIF= 31.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 88; FIX 4; C= 0000000; BIN=8000; MRPL=43.9; MRPD=47.8; LEAK RATE= 2.1  
ACT= 119.8; REL= 90.8; DIF= 29.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:39:38.83 OPER DOOR DID NOT CLOSE 1

SER 89; FIX 1; C= 0000000; BIN=8000; MRPL=44.2; MRPD=47.8; LEAK RATE= 1.9  
ACT= 128.0; REL= 96.4; DIF= 31.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

90 SER 90; FIX 2; C= 0000000; BIN=8000; MRPL=44.2; MRPD=47.8; LEAK RATE= 1.9  
ACT= 133.9; REL= 99.9; DIF= 34.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 91; FIX 3; C= 0000000; BIN=8000; MRPL=44.2; MRPD=47.8; LEAK RATE= 1.9  
ACT= 126.1; REL= 98.8; DIF= 32.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 92; FIX 4; C= 0000000; BIN=8000; MRPL=44.2; MRPD=47.8; LEAK RATE= 1.9



SER 102; FIX 2; C: 0000000; BIN=8000; NRRU=44.1; NRRD=47.8; LEAK RATE= 1.9  
ACT= 132.4; REL= 90.2; DIF= 42.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 103; FIX 3; C: 0000000; BIN=8000; NRRU=44.1; NRRD=47.8; LEAK RATE= 1.9  
ACT= 138.2; REL= 103.8; DIF= 34.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 104; FIX 4; C: 0000000; BIN=8000; NRRU=44.1; NRRD=47.8; LEAK RATE= 1.9  
ACT= 125.9; REL= 91.4; DIF= 34.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 105; FIX 1; C: 0000000; BIN=8000; NRRU=44.1; NRRD=47.2; LEAK RATE= 1.8  
ACT= 140.4; REL= 113.1; DIF= 27.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 106; FIX 2; C: 0000000; BIN=8000; NRRU=44.1; NRRD=47.2; LEAK RATE= 1.8  
ACT= 138.8; REL= 100.6; DIF= 33.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 107; FIX 3; C: 0000000; BIN=8000; NRRU=44.1; NRRD=47.2; LEAK RATE= 1.8  
ACT= 132.4; REL= 94.4; DIF= 38.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 108; FIX 4; C: 0000000; BIN=8000; NRRU=44.1; NRRD=47.2; LEAK RATE= 1.8  
ACT= 139.1; REL= 105.9; DIF= 33.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:49:40.16 UPPER DOOR DID NOT CLOSE 1

SER 109; FIX 1; C: 0000000; BIN=8000; NRRU=44.4; NRRD=47.9; LEAK RATE= 2.0  
ACT= 127.6; REL= 100.8; DIF= 26.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

110. SER 110; FIX 2; C: 0000000; BIN=8000; NRRU=44.4; NRRD=47.9; LEAK RATE= 2.0  
ACT= 137.5; REL= 104.9; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 111; FIX 3; C: 0000000; BIN=8000; NRRU=44.4; NRRD=47.9; LEAK RATE= 2.0  
ACT= 131.3; REL= 100.8; DIF= 30.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 112; FIX 4; C: 0000000; BIN=8000; NRRU=44.4; NRRD=47.9; LEAK RATE= 2.0  
ACT= 129.0; REL= 97.0; DIF= 32.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 113; FIX 1; C: 0000000; BIN=8000; NRRU=44.2; NRRD=47.2; LEAK RATE= 2.0  
ACT= 125.3; REL= 92.2; DIF= 33.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 114; FIX 2; C: 0000000; BIN=8000; NRRU=44.2; NRRD=47.2; LEAK RATE= 2.0  
ACT= 133.2; REL= 102.1; DIF= 31.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 115; FIX 3; C: 0000000; BIN=8000; NRRU=44.2; NRRD=47.2; LEAK RATE= 2.0

SER 116; FIX 4; C= 000000; BIN=8000; NRRU=44.2; NRRD=47.2; LEAK RATE= 2.0  
ACT= 124.5; REL= 93.6; DIF= 30.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 117; FIX 1; C= 000000; BIN=8000; NRRU=44.2; NRRD=47.9; LEAK RATE= 2.1  
ACT= 132.4; REL= 104.7; DIF= 27.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 118; FIX 2; C= 000000; BIN=8000; NRRU=44.2; NRRD=47.9; LEAK RATE= 2.1  
ACT= 123.1; REL= 99.9; DIF= 33.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 119; FIX 3; C= 000000; BIN=8000; NRRU=44.2; NRRD=47.9; LEAK RATE= 2.1  
ACT= 119.8; REL= 88.7; DIF= 31.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

120 SER 120; FIX 4; C= 000000; BIN=8000; NRRU=44.2; NRRD=47.9; LEAK RATE= 2.1  
ACT= 132.4; REL= 96.2; DIF= 34.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 121; FIX 1; C= 000000; BIN=8000; NRRU=44.1; NRRD=47.8; LEAK RATE= 2.0  
ACT= 135.2; REL= 107.8; DIF= 27.4 PSI; ACTCR= 200.0ms; RELCR= 122.3

SER 122; FIX 2; C= 000000; BIN=8000; NRRU=44.1; NRRD=47.8; LEAK RATE= 2.0  
ACT= 130.6; REL= 93.8; DIF= 36.7 PSI; ACTCR= 200.0ms; RELCR= 15.0

SER 123; FIX 3; C= 000000; BIN=8000; NRRU=44.1; NRRD=47.8; LEAK RATE= 2.0  
ACT= 128.2; REL= 96.0; DIF= 32.2 PSI; ACTCR= 200.0ms; RELCR= 38.4

124 SER 124; FIX 4; C= 000000; BIN=8000; NRRU=44.1; NRRD=47.8; LEAK RATE= 2.0  
ACT= 177.8; REL= 92.6; DIF= 85.2 PSI; ACTCR= 200.0ms; RELCR= 0.6

17-APR-1992 10:51:29.38 OPER ERROR DID NOT CLOSE 1

SER 125; FIX 1; C= 000000; BIN=8000; NRRU=44.2; NRRD=47.3; LEAK RATE= 2.4  
ACT= 128.3; REL= 96.1; DIF= 32.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 126; FIX 2; C= 000000; BIN=8000; NRRU=44.2; NRRD=47.3; LEAK RATE= 2.4  
ACT= 123.4; REL= 89.6; DIF= 33.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 127; FIX 3; C= 000000; BIN=8000; NRRU=44.2; NRRD=47.3; LEAK RATE= 2.4  
ACT= 125.4; REL= 94.1; DIF= 31.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 128; FIX 4; C= 000000; BIN=8000; NRRU=44.2; NRRD=47.3; LEAK RATE= 2.4  
ACT= 131.2; REL= 94.3; DIF= 37.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:51:29.38 OPER ERROR DID NOT CLOSE

17-APR-1992 10:32:28.86 OPER DOOR STILL DID NOT CLOSE 1

SER 129; FIX 1; C= 0000000; BIN=GOOD; NRRU=44.1; NRRD=47.6; LEAK RATE= 2.2  
ACT= 134.4; REL= 107.6; DIF= 26.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

130 SER 130; FIX 2; C= 0000000; BIN=GOOD; NRRU=44.1; NRRD=47.6; LEAK RATE= 2.2  
ACT= 131.3; REL= 100.8; DIF= 30.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 131; FIX 3; C= 0000000; BIN=GOOD; NRRU=44.1; NRRD=47.6; LEAK RATE= 2.2  
ACT= 129.5; REL= 97.1; DIF= 32.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 132; FIX 4; C= 0000000; BIN=GOOD; NRRU=44.1; NRRD=47.6; LEAK RATE= 2.2  
ACT= 126.2; REL= 94.6; DIF= 33.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

✓

17-APR-1992 10:53:00.20 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:53:20.20 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 10:53:37.62 TOOL CYCLE TIMEOUT 1

SER 133; FIX 1; C= 0000000; BIN=GOOD; NRRU=44.5; NRRD=47.1; LEAK RATE= 1.8  
ACT= 137.2; REL= 106.1; DIF= 31.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 134; FIX 2; C= 0000000; BIN=GOOD; NRRU=44.5; NRRD=47.1; LEAK RATE= 1.8  
ACT= 128.7; REL= 96.9; DIF= 31.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 135; FIX 3; C= 0000000; BIN=GOOD; NRRU=44.5; NRRD=47.1; LEAK RATE= 1.8  
ACT= 129.1; REL= 99.5; DIF= 29.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 136; FIX 4; C= 0000000; BIN=GOOD; NRRU=44.5; NRRD=47.1; LEAK RATE= 1.8  
ACT= 127.3; REL= 91.8; DIF= 35.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:54:52.26 OPER DOOR DID NOT CLOSE 1

SER 137; FIX 1; C= 0000000; BIN=GOOD; NRRU=44.2; NRRD=47.2; LEAK RATE= 2.0

SER 135; FIX 2; C= 000000; BIN=GOOD; NRRL=44.2; NRFD=47.2; LEAK RATE= 2.0  
ACT= 130.7; REL= 87.1; DIF= 33.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 139; FIX 3; C= 000000; BIN=GOOD; NRRL=44.2; NRFD=47.2; LEAK RATE= 2.0  
ACT= 132.8; REL= 103.5; DIF= 29.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

140 SER 140; FIX 4; C= 000000; BIN=GOOD; NRRL=44.2; NRFD=47.2; LEAK RATE= 2.0  
ACT= 129.9; REL= 83.5; DIF= 36.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 141; FIX 1; C= 000000; BIN=GOOD; NRRL=44.4; NRFD=47.5; LEAK RATE= 2.0  
ACT= 127.7; REL= 96.6; DIF= 31.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 142; FIX 2; C= 000000; BIN=GOOD; NRRL=44.4; NRFD=47.5; LEAK RATE= 2.0  
ACT= 118.7; REL= 87.2; DIF= 31.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 143; FIX 3; C= 000000; BIN=GOOD; NRRL=44.4; NRFD=47.5; LEAK RATE= 2.0  
ACT= 124.4; REL= 88.5; DIF= 35.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 144; FIX 4; C= 000000; BIN=GOOD; NRRL=44.4; NRFD=47.5; LEAK RATE= 2.0  
ACT= 131.7; REL= 104.4; DIF= 27.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 145; FIX 1; C= 000000; BIN=GOOD; NRRL=43.8; NRFD=47.1; LEAK RATE= 2.2  
ACT= 136.3; REL= 106.9; DIF= 29.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 146; FIX 2; C= 000000; BIN=GOOD; NRRL=43.8; NRFD=47.1; LEAK RATE= 2.2  
ACT= 126.6; REL= 95.8; DIF= 30.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 147; FIX 3; C= 000000; BIN=GOOD; NRRL=43.8; NRFD=47.1; LEAK RATE= 2.2  
ACT= 131.5; REL= 97.3; DIF= 34.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 148; FIX 4; C= 000000; BIN=GOOD; NRRL=43.8; NRFD=47.1; LEAK RATE= 2.2  
ACT= 128.0; REL= 92.4; DIF= 35.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 149; FII 1; C= 0000000; BIN=8506; MFRU=44.2; MFRD=47.1; LEAK RATE= 2.2  
ACT= 132.2; REL= 102.1; DIF= 30.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

150 SER 150; FII 2; C= 0000000; BIN=8000; MFRU=44.2; MFRD=47.1; LEAK RATE= 2.2  
ACT= 131.0; REL= 98.3; DIF= 32.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 151; FII 3; C= 0020042; BIN=CONF; MFRU=44.2; MFRD=47.1; LEAK RATE= 2.2  
ACT= 178.0; REL= 140.7; DIF= 37.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 152; FII 4; C= 0000000; BIN=8000; MFRU=44.2; MFRD=47.1; LEAK RATE= 2.2  
ACT= 139.2; REL= 97.1; DIF= 42.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 153; FII 1; C= 0000000; BIN=8000; MFRU=44.4; MFRD=47.5; LEAK RATE= 1.9  
ACT= 129.4; REL= 95.8; DIF= 33.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 154; FII 2; C= 0000000; BIN=8000; MFRU=44.4; MFRD=47.5; LEAK RATE= 1.9  
ACT= 131.6; REL= 99.9; DIF= 31.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 155; FII 3; C= 0000000; BIN=8000; MFRU=44.4; MFRD=47.5; LEAK RATE= 1.9  
ACT= 132.5; REL= 99.9; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 156; FII 4; C= 0000000; BIN=8000; MFRU=44.4; MFRD=47.5; LEAK RATE= 1.9  
ACT= 136.1; REL= 102.3; DIF= 33.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 157; FII 1; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.6; LEAK RATE= 1.9  
ACT= 130.4; REL= 96.6; DIF= 33.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 158; FII 2; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.6; LEAK RATE= 1.9  
ACT= 134.1; REL= 97.8; DIF= 36.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 159; FII 3; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.6; LEAK RATE= 1.9  
ACT= 125.0; REL= 91.8; DIF= 33.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

160 SER 160; FII 4; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.6; LEAK RATE= 1.9  
ACT= 130.4; REL= 96.6; DIF= 33.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:57:25.69 DEPR DOOR BID NOT CLOSE 1

SER 161; FII 1; C= 0000000; BIN=8000; MFRU=43.9; MFRD=47.8; LEAK RATE= 1.9  
ACT= 133.2; REL= 99.4; DIF= 33.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 162; FII 2; C= 0000000; BIN=8000; MFRU=43.9; MFRD=47.8; LEAK RATE= 1.9  
ACT= 131.0; REL= 97.0; DIF= 34.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 163; FII 3; C= 0000000; BIN=8000; MFRU=43.9; MFRD=47.8; LEAK RATE= 1.9  
ACT= 127.2; REL= 93.3; DIF= 34.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 165; FIX 1; C= 000000; BIN=8000 ; MFRU=44.1; MFRD=47.7; LEAK RATE= 2.0  
ACT= 137.2; REL= 102.3; DIF= 34.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 166; FIX 2; C= 000000; BIN=8000 ; MFRU=44.1; MFRD=47.7; LEAK RATE= 2.0  
ACT= 129.3; REL= 98.3; DIF= 31.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 167; FIX 3; C= 000000; BIN=8000 ; MFRU=44.1; MFRD=47.7; LEAK RATE= 2.0  
ACT= 128.7; REL= 93.2; DIF= 35.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 168; FIX 4; C= 000000; BIN=8000 ; MFRU=44.1; MFRD=47.7; LEAK RATE= 2.0  
ACT= 125.3; REL= 86.7; DIF= 38.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:58:22.59 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:58:42.59 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 10:59:09.61 TOOL CYCLE TIMEOUT 1

SER 169; FIX 1; C= 000000; BIN=8000 ; MFRU=44.2; MFRD=47.7; LEAK RATE= 2.1  
ACT= 128.3; REL= 98.1; DIF= 30.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

170 SER 170; FIX 2; C= 000000; BIN=8000 ; MFRU=44.2; MFRD=47.7; LEAK RATE= 2.1  
ACT= 126.5; REL= 90.9; DIF= 35.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 171; FIX 3; C= 000000; BIN=8000 ; MFRU=44.2; MFRD=47.7; LEAK RATE= 2.1  
ACT= 127.1; REL= 94.4; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 172; FIX 4; C= 000000; BIN=8000 ; MFRU=44.2; MFRD=47.7; LEAK RATE= 2.1  
ACT= 123.6; REL= 98.7; DIF= 24.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:00:53.08 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:01:13.08 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 11:01:29.18 TOOL CYCLE TIMEOUT 1

SER 173; FIX 1; C= 000000; BIN=8000 ; MFRU=44.0; MFRD=47.0; LEAK RATE= 2.2  
ACT= 134.0; REL= 100.3; DIF= 33.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 174; FIX 2; C= 000000; BIN=8000 ; MFRU=44.0; MFRD=47.0; LEAK RATE= 2.2  
ACT= 142.9; REL= 112.3; DIF= 30.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 175; FIX 3; C= 000000; BIN=8000 ; MFRU=44.0; MFRD=47.0; LEAK RATE= 2.2  
ACT= 135.9; REL= 105.3; DIF= 30.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:03:27.36 OPER DOOR DID NOT CLOSE 1

SER 177; FIX 1; C= 0000000; BIN=8000; NRRU=43.7; NRRD=47.4; LEAK RATE= 1.9  
ACT= 132.2; REL= 101.0; DIF= 31.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 178; FIX 2; C= 0000000; BIN=8000; NRRU=43.7; NRRD=47.4; LEAK RATE= 1.9  
ACT= 128.0; REL= 98.4; DIF= 29.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 179; FIX 3; C= 0000000; BIN=8000; NRRU=43.7; NRRD=47.4; LEAK RATE= 1.9  
ACT= 131.7; REL= 97.2; DIF= 34.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

180 SER 180; FIX 4; C= 0000000; BIN=8000; NRRU=43.7; NRRD=47.4; LEAK RATE= 1.9  
ACT= 126.3; REL= 92.3; DIF= 33.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:03:52.53 OPER DOOR DID NOT CLOSE 1

SER 181; FIX 1; C= 0000000; BIN=8000; NRRU=44.3; NRRD=47.5; LEAK RATE= 2.0  
ACT= 131.7; REL= 97.7; DIF= 34.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 182; FIX 2; C= 0000000; BIN=8000; NRRU=44.3; NRRD=47.5; LEAK RATE= 2.0  
ACT= 128.5; REL= 96.4; DIF= 32.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 183; FIX 3; C= 0000000; BIN=8000; NRRU=44.3; NRRD=47.5; LEAK RATE= 2.0  
ACT= 133.1; REL= 101.5; DIF= 31.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 184; FIX 4; C= 0000000; BIN=8000; NRRU=44.3; NRRD=47.5; LEAK RATE= 2.0  
ACT= 131.7; REL= 101.1; DIF= 30.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:04:18.31 OPER DOOR DID NOT CLOSE 1

SER 185; FIX 1; C= 0000000; BIN=8000; NRRU=44.2; NRRD=47.6; LEAK RATE= 2.0

SER 186; FIX 2; C= 000000; BIN=8000; MFRU=44.2; MFRD=47.6; LEAK RATE= 2.0  
ACT= 135.3; REL= 104.0; DIF= 31.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 187; FIX 3; C= 000000; BIN=8000; MFRU=44.2; MFRD=47.6; LEAK RATE= 2.0  
ACT= 129.9; REL= 97.6; DIF= 32.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 188; FIX 4; C= 000000; BIN=8000; MFRU=44.2; MFRD=47.6; LEAK RATE= 2.0  
ACT= 132.6; REL= 102.6; DIF= 30.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1972 11:04:44.23 OPER DOOR DID NOT CLOSE 1

SER 189; FIX 1; C= 000000; BIN=8000; MFRU=44.5; MFRD=48.5; LEAK RATE= 1.8  
ACT= 135.8; REL= 106.3; DIF= 29.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

190 SER 190; FIX 2; C= 000000; BIN=8000; MFRU=44.5; MFRD=48.5; LEAK RATE= 1.8  
ACT= 125.0; REL= 90.4; DIF= 34.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 191; FIX 3; C= 000000; BIN=8000; MFRU=44.5; MFRD=48.5; LEAK RATE= 1.8  
ACT= 128.7; REL= 95.2; DIF= 33.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 192; FIX 4; C= 000000; BIN=8000; MFRU=44.3; MFRD=48.5; LEAK RATE= 1.8  
ACT= 132.4; REL= 100.0; DIF= 32.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 193; FIX 1; C= 000000; BIN=8000; MFRU=44.3; MFRD=47.7; LEAK RATE= 2.0  
ACT= 136.0; REL= 102.9; DIF= 33.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 194; FIX 2; C= 000000; BIN=8000; MFRU=44.3; MFRD=47.7; LEAK RATE= 2.0  
ACT= 133.3; REL= 98.0; DIF= 35.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 195; FIX 3; C= 000000; BIN=8000; MFRU=44.3; MFRD=47.7; LEAK RATE= 2.0  
ACT= 130.6; REL= 100.4; DIF= 30.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 196; FIX 4; C= 000000; BIN=8000; MFRU=44.3; MFRD=47.7; LEAK RATE= 2.0  
ACT= 122.1; REL= 90.6; DIF= 31.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

END

TI-NHTSA 006443

SER 198; FII 2; C= 0000000; BIN=8000; MFRU=44.2; MFRD=47.5; LEAK RATE= 2.2  
ACT= 129.8; REL= 95.5; DIF= 34.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 199; FII 3; C= 0000000; BIN=8000; MFRU=44.2; MFRD=47.5; LEAK RATE= 2.2  
ACT= 133.1; REL= 104.1; DIF= 28.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

200 SER 200; FII 4; C= 0000000; BIN=8000; MFRU=44.2; MFRD=47.5; LEAK RATE= 2.2  
ACT= 132.7; REL= 101.6; DIF= 31.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 201; FII 1; C= 0000000; BIN=8000; MFRU=44.2; MFRD=46.2; LEAK RATE= 2.3  
ACT= 141.4; REL= 111.0; DIF= 30.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 202; FII 2; C= 0000000; BIN=8000; MFRU=44.2; MFRD=46.2; LEAK RATE= 2.3  
ACT= 140.5; REL= 111.0; DIF= 29.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 203; FII 3; C= 0000000; BIN=8000; MFRU=44.2; MFRD=46.2; LEAK RATE= 2.3  
ACT= 130.8; REL= 100.3; DIF= 30.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 204; FII 4; C= 0000000; BIN=8000; MFRU=44.2; MFRD=46.2; LEAK RATE= 2.3  
ACT= 138.7; REL= 104.0; DIF= 34.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:06:27.81 OPER DOOR DID NOT CLOSE 1

SER 205; FII 1; C= 0000000; BIN=8000; MFRU=44.2; MFRD=48.0; LEAK RATE= 2.1  
ACT= 133.4; REL= 98.3; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 206; FII 2; C= 0000000; BIN=8000; MFRU=44.2; MFRD=48.0; LEAK RATE= 2.1  
ACT= 131.7; REL= 102.2; DIF= 29.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 207; FII 3; C= 0000000; BIN=8000; MFRU=44.2; MFRD=48.0; LEAK RATE= 2.1  
ACT= 134.6; REL= 102.2; DIF= 32.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 208; FII 4; C= 0000000; BIN=8000; MFRU=44.2; MFRD=48.0; LEAK RATE= 2.1  
ACT= 129.9; REL= 100.9; DIF= 29.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:07:09.87 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:07:29.87 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 11:07:46.87 TOOL CYCLE TIMEOUT 1

ACT= 128.4; REL= 97.6; DIF= 30.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

210 SER 210; FIX 2; C= 0000000; BIN=8000; NRRU=44.2; NRRD=47.4; LEAK RATE= 1.9  
ACT= 126.5; REL= 95.1; DIF= 31.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 211; FIX 3; C= 0000000; BIN=8000; NRRU=44.2; NRRD=47.4; LEAK RATE= 1.9  
ACT= 132.9; REL= 96.3; DIF= 36.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 212; FIX 4; C= 0000000; BIN=8000; NRRU=44.2; NRRD=47.4; LEAK RATE= 1.9  
ACT= 126.0; REL= 94.2; DIF= 31.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 213; FIX 1; C= 0000000; BIN=8000; NRRU=44.5; NRRD=47.5; LEAK RATE= 2.1  
ACT= 129.8; REL= 97.4; DIF= 32.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 214; FIX 2; C= 0000000; BIN=8000; NRRU=44.5; NRRD=47.5; LEAK RATE= 2.1  
ACT= 133.3; REL= 97.4; DIF= 35.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 215; FIX 3; C= 0000000; BIN=8000; NRRU=44.5; NRRD=47.5; LEAK RATE= 2.1  
ACT= 136.9; REL= 104.0; DIF= 32.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 216; FIX 4; C= 0000000; BIN=8000; NRRU=44.5; NRRD=47.5; LEAK RATE= 2.1  
ACT= 127.2; REL= 93.7; DIF= 33.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:16:06.03 OPER DOOR DID NOT CLOSE

SER 217; FIX 1; C= 0000000; BIN=8000; NRRU=44.3; NRRD=47.4; LEAK RATE= 2.0  
ACT= 133.4; REL= 102.5; DIF= 30.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 218; FIX 2; C= 0000000; BIN=8000; NRRU=44.3; NRRD=47.4; LEAK RATE= 2.0  
ACT= 125.0; REL= 92.7; DIF= 32.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 219; FIX 3; C= 0000000; BIN=8000; NRRU=44.3; NRRD=47.6; LEAK RATE= 2.0  
ACT= 139.7; REL= 108.2; DIF= 31.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

220 SER 220; FIX 4; C= 0000000; BIN=8000; NRRU=44.3; NRRD=47.6; LEAK RATE= 2.0  
ACT= 125.3; REL= 90.3; DIF= 35.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:16:31.42 OPER DOOR DID NOT CLOSE 1

SER 221; FII 1; C= 0000000; BIN=GOOD; NRRL=44.1; NRFD=47.7; LEAK RATE= 1.9  
ACT= 134.7; REL= 103.5; DIF= 31.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 222; FII 2; C= 0000000; BIN=GOOD; NRRL=44.1; NRFD=47.7; LEAK RATE= 1.9  
ACT= 127.5; REL= 94.6; DIF= 32.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 223; FII 3; C= 0000000; BIN=GOOD; NRRL=44.1; NRFD=47.7; LEAK RATE= 1.9  
ACT= 126.6; REL= 94.6; DIF= 32.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 224; FII 4; C= 0000000; BIN=GOOD; NRRL=44.1; NRFD=47.7; LEAK RATE= 1.9  
ACT= 133.8; REL= 101.1; DIF= 32.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:16:56.88 OPER DOOR DID NOT CLOSE 1

SER 225; FII 1; C= 0000000; BIN=GOOD; NRRL=44.3; NRFD=46.7; LEAK RATE= 1.9  
ACT= 132.5; REL= 98.0; DIF= 34.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 226; FII 2; C= 0000000; BIN=GOOD; NRRL=44.3; NRFD=46.7; LEAK RATE= 1.9  
ACT= 129.9; REL= 90.3; DIF= 39.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 227; FII 3; C= 0000000; BIN=GOOD; NRRL=44.3; NRFD=46.7; LEAK RATE= 1.9  
ACT= 133.5; REL= 105.4; DIF= 28.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 228; FII 4; C= 0000000; BIN=GOOD; NRRL=44.3; NRFD=46.7; LEAK RATE= 1.9  
ACT= 126.6; REL= 89.3; DIF= 37.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:17:29.27 OPER DOOR DID NOT CLOSE 1

SER 229; FII 1; C= 0000000; BIN=GOOD; NRRL=44.2; NRFD=47.5; LEAK RATE= 1.6  
ACT= 124.9; REL= 92.3; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

230 SER 230; FII 2; C= 0000000; BIN=GOOD; NRRL=44.2; NRFD=47.5; LEAK RATE= 1.6  
ACT= 127.2; REL= 93.3; DIF= 33.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 231; FII 3; C= 0000000; BIN=GOOD; NRRL=44.2; NRFD=47.5; LEAK RATE= 1.6

SER 232; FIX 4; C= 000000; BIN=8000; WRL=44.2; WRD=47.5; LEAK RATE= 1.6  
ACT= 130.8; REL= 77.1; DIF= 33.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:17:52.80 OPER EXOR DIS NOT CLOSE 1

SER 233; FIX 1; C= 000000; BIN=8000; WRL=43.8; WRD=47.6; LEAK RATE= 1.9  
ACT= 117.2; REL= 82.4; DIF= 34.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 234; FIX 2; C= 000000; BIN=8000; WRL=43.8; WRD=47.6; LEAK RATE= 1.9  
ACT= 128.9; REL= 95.0; DIF= 33.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 235; FIX 3; C= 000000; BIN=8000; WRL=43.8; WRD=47.6; LEAK RATE= 1.9  
ACT= 129.3; REL= 95.0; DIF= 34.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 236; FIX 4; C= 000000; BIN=8000; WRL=43.8; WRD=47.6; LEAK RATE= 1.9  
ACT= 128.7; REL= 96.3; DIF= 32.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 237; FIX 1; C= 000000; BIN=8000; WRL=44.1; WRD=47.9; LEAK RATE= 1.7  
ACT= 126.6; REL= 93.8; DIF= 32.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 238; FIX 2; C= 000000; BIN=8000; WRL=44.1; WRD=47.9; LEAK RATE= 1.7  
ACT= 132.4; REL= 98.7; DIF= 33.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 239; FIX 3; C= 000000; BIN=8000; WRL=44.1; WRD=47.9; LEAK RATE= 1.7  
ACT= 132.4; REL= 99.9; DIF= 32.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

240  
SER 240; FIX 4; C= 000000; BIN=8000; WRL=44.1; WRD=47.9; LEAK RATE= 1.7  
ACT= 128.9; REL= 92.6; DIF= 34.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 241; FIX 1; C= 000000; BIN=8000; WRL=44.5; WRD=47.5; LEAK RATE= 1.8  
ACT= 135.2; REL= 108.3; DIF= 28.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 242; FIX 2; C= 000000; BIN=8000; WRL=44.5; WRD=47.5; LEAK RATE= 1.8

SER 243; FIX 3; C= 000000; BIN=8000; MRRU=44.3; MRRD=47.3; LEAK RATE= 1.8  
ACT= 126.5; REL= 93.9; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 244; FIX 4; C= 000000; BIN=8000; MRRU=44.5; MRRD=47.5; LEAK RATE= 1.8  
ACT= 156.0; REL= 103.0; DIF= 33.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:19:07.88 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:19:27.88 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 11:19:46.19 TOOL CYCLE TIMEOUT 1

SER 245; FIX 1; C= 000000; BIN=8000; MRRU=44.3; MRRD=47.4; LEAK RATE= 1.8  
ACT= 138.9; REL= 104.2; DIF= 34.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 246; FIX 2; C= 000000; BIN=8000; MRRU=44.3; MRRD=47.4; LEAK RATE= 1.8  
ACT= 130.4; REL= 100.2; DIF= 30.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 247; FIX 3; C= 000000; BIN=8000; MRRU=44.3; MRRD=47.4; LEAK RATE= 1.8  
ACT= 126.4; REL= 96.4; DIF= 30.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 248; FIX 4; C= 000000; BIN=8000; MRRU=44.3; MRRD=47.4; LEAK RATE= 1.8  
ACT= 137.3; REL= 108.1; DIF= 31.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 249; FIX 1; C= 000000; BIN=8000; MRRU=44.2; MRRD=47.6; LEAK RATE= 2.1  
ACT= 126.4; REL= 92.3; DIF= 34.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

250 SER 250; FIX 2; C= 000000; BIN=8000; MRRU=44.2; MRRD=47.6; LEAK RATE= 2.1  
ACT= 137.5; REL= 109.2; DIF= 28.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 251; FIX 3; C= 000000; BIN=8000; MRRU=44.2; MRRD=47.6; LEAK RATE= 2.1  
ACT= 131.7; REL= 102.4; DIF= 29.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 252; FIX 4; C= 000000; BIN=8000; MRRU=44.2; MRRD=47.6; LEAK RATE= 2.1  
ACT= 128.2; REL= 92.3; DIF= 35.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:22:27.92 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:22:47.92 OPER DOOR STILL DID NOT CLOSE 1

SER 253; FIX 1; C= 000000; BIN=8000; MRRU=44.2; MRRD=47.0; LEAK RATE= 2.0  
ACT= 131.7; REL= 100.8; DIF= 30.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 254; FIX 2; C= 000000; BIN=8000; MRRU=44.2; MRRD=47.0; LEAK RATE= 2.0  
ACT= 134.4; REL= 99.5; DIF= 34.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 255; FIX 3; C= 000000; BIN=8000; MRRU=44.2; MRRD=47.0; LEAK RATE= 2.0

SER 254; FIX 4; C: 000000; BIN=8000; NRRU=44.2; NRRD=47.0; LEAK RATE= 2.0  
ACT= 120.3; REL= 87.5; DIF= 33.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:23:22.47 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:23:42.47 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 11:23:59.21 TOOL CYCLE TIMEOUT 1

SER 257; FIX 1; C: 000000; BIN=8000; NRRU=44.6; NRRD=47.8; LEAK RATE= 1.8  
ACT= 130.3; REL= 95.2; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 258; FIX 2; C: 000000; BIN=8000; NRRU=44.6; NRRD=47.8; LEAK RATE= 1.8  
ACT= 133.4; REL= 100.1; DIF= 33.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 259; FIX 3; C: 000000; BIN=8000; NRRU=44.6; NRRD=47.8; LEAK RATE= 1.8  
ACT= 124.2; REL= 98.8; DIF= 25.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 260; FIX 4; C: 000000; BIN=8000; NRRU=44.6; NRRD=47.8; LEAK RATE= 1.8  
ACT= 133.9; REL= 101.2; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:30:18.24 OPER DOOR DID NOT CLOSE 1

SER 261; FIX 1; C: 000000; BIN=8000; NRRU=44.2; NRRD=48.1; LEAK RATE= 2.1  
ACT= 133.7; REL= 101.4; DIF= 32.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 262; FIX 2; C: 000000; BIN=8000; NRRU=44.2; NRRD=48.1; LEAK RATE= 2.1  
ACT= 130.8; REL= 102.8; DIF= 27.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 263; FIX 3; C: 000000; BIN=8000; NRRU=44.2; NRRD=48.1; LEAK RATE= 2.1  
ACT= 128.1; REL= 92.7; DIF= 35.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 264; FIX 4; C: 000000; BIN=8000; NRRU=44.2; NRRD=48.1; LEAK RATE= 2.1  
ACT= 128.9; REL= 101.4; DIF= 27.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 265; FIX 1; C: 000000; BIN=8000; NRRU=44.4; NRRD=47.7; LEAK RATE= 2.3  
ACT= 130.8; REL= 95.9; DIF= 35.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 266; FIX 2; C: 000000; BIN=8000; NRRU=44.4; NRRD=47.7; LEAK RATE= 2.3  
ACT= 133.3; REL= 101.0; DIF= 32.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 267; FIX 3; C: 000000; BIN=8000; NRRU=44.4; NRRD=47.7; LEAK RATE= 2.3  
ACT= 127.2; REL= 92.5; DIF= 34.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 268; FIX 4; C: 000000; BIN=8000; NRRU=44.4; NRRD=47.7; LEAK RATE= 2.3  
ACT= 130.8; REL= 95.9; DIF= 35.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 269; FIX 1; C: 0000000; BIN=8000; NFRU=44.0; NFRD=47.3; LEAK RATE= 2.0  
ACT: 129.5; REL: 93.7; DIF= 35.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

270 SER 270; FIX 2; C: 0000000; BIN=8000; NFRU=44.0; NFRD=47.3; LEAK RATE= 2.0  
ACT: 130.3; REL: 95.5; DIF= 31.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 271; FIX 3; C: 0000000; BIN=8000; NFRU=44.0; NFRD=47.3; LEAK RATE= 2.0  
ACT: 142.8; REL: 107.8; DIF= 34.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 272; FIX 4; C: 0000000; BIN=8000; NFRU=44.0; NFRD=47.3; LEAK RATE= 2.0  
ACT: 129.1; REL: 94.9; DIF= 31.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 273; FIX 1; C: 0000000; BIN=8000; NFRU=44.2; NFRD=47.7; LEAK RATE= 1.5  
ACT: 127.1; REL: 91.1; DIF= 36.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 274; FIX 2; C: 0000000; BIN=8000; NFRU=44.2; NFRD=47.7; LEAK RATE= 1.5  
ACT: 130.7; REL: 97.2; DIF= 33.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 275; FIX 3; C: 0000000; BIN=8000; NFRU=44.2; NFRD=47.7; LEAK RATE= 1.5  
ACT: 134.7; REL: 104.8; DIF= 29.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 276; FIX 4; C: 0000000; BIN=8000; NFRU=44.2; NFRD=47.7; LEAK RATE= 1.5  
ACT: 127.6; REL: 97.2; DIF= 30.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:32:08.07 OPER DOOR DID NOT CLOSE L

SER 277; FIX 1; C: 0000000; BIN=8000; NFRU=44.4; NFRD=48.0; LEAK RATE= 1.8  
ACT: 127.2; REL: 93.6; DIF= 33.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 278; FIX 2; C: 0000000; BIN=8000; NFRU=44.4; NFRD=48.0; LEAK RATE= 1.8  
ACT: 129.1; REL: 89.0; DIF= 34.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 279; FIX 3; C: 0000000; BIN=8000; NFRU=44.4; NFRD=48.0; LEAK RATE= 1.8  
ACT: 129.9; REL: 96.1; DIF= 33.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

280 SER 280; FIX 4; C: 0000000; BIN=8000; NFRU=44.4; NFRD=48.0; LEAK RATE= 1.8  
ACT: 125.2; REL: 88.9; DIF= 37.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:32:33.64 OPER DOOR DID NOT CLOSE 1

SER 281; FIX 1; C= 000000; BIN=GOOD; NPSI=44.1; NPSD=47.7; LEAK RATE= 1.9  
ACT= 130.5; REL= 100.6; DIP= 29.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 282; FIX 2; C= 000000; BIN=GOOD; NPSI=44.1; NPSD=47.7; LEAK RATE= 1.9  
ACT= 123.6; REL= 93.2; DIP= 30.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 283; FIX 3; C= 000000; BIN=GOOD; NPSI=44.1; NPSD=47.7; LEAK RATE= 1.9  
ACT= 131.3; REL= 96.8; DIP= 34.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 284; FIX 4; C= 000000; BIN=GOOD; NPSI=44.1; NPSD=47.7; LEAK RATE= 1.9  
ACT= 134.2; REL= 100.6; DIP= 33.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:33:01.28 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:33:21.28 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 11:33:37.15 TOOL CYCLE TIMEOUT 1

SER 285; FIX 1; C= 000000; BIN=GOOD; NPSI=44.3; NPSD=48.7; LEAK RATE= 2.1  
ACT= 131.5; REL= 99.6; DIP= 32.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 286; FIX 2; C= 000000; BIN=GOOD; NPSI=44.3; NPSD=48.7; LEAK RATE= 2.1  
ACT= 137.6; REL= 103.6; DIP= 34.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 287; FIX 3; C= 000000; BIN=GOOD; NPSI=44.3; NPSD=48.7; LEAK RATE= 2.1  
ACT= 125.6; REL= 89.8; DIP= 35.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 288; FIX 4; C= 000000; BIN=GOOD; NPSI=44.3; NPSD=48.7; LEAK RATE= 2.1  
ACT= 129.1; REL= 99.6; DIP= 29.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:43:46.51 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:43:06.51 OPER DOOR STILL DID NOT CLOSE 1

SER 289; FIX 1; C= 000000; BIN=GOOD; NPSI=44.1; NPSD=48.0; LEAK RATE= 2.0  
ACT= 133.1; REL= 98.5; DIP= 34.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

290

SER 290; FIX 2; C= 000000; BIN=GOOD; NPSI=44.1; NPSD=48.0; LEAK RATE= 2.0  
ACT= 126.4; REL= 101.4; DIP= 35.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 271; FIX 3; C= 000000; BIN=8000; MFRU=44.1; MFRD=48.0; LEAK RATE= 2.0  
ACT= 129.4; REL= 99.6; DIF= 29.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 272; FIX 4; C= 000000; BIN=8000; MFRU=44.1; MFRD=48.0; LEAK RATE= 2.0  
ACT= 137.5; REL= 103.6; DIF= 33.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:43:52.41 OPER DOOR DID NOT CLOSE 1

SER 273; FIX 1; C= 000000; BIN=8000; MFRU=44.3; MFRD=47.6; LEAK RATE= 2.0  
ACT= 129.9; REL= 95.5; DIF= 34.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 274; FIX 2; C= 000000; BIN=8000; MFRU=44.3; MFRD=47.6; LEAK RATE= 2.0  
ACT= 125.2; REL= 93.0; DIF= 32.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 275; FIX 3; C= 000000; BIN=8000; MFRU=44.3; MFRD=47.6; LEAK RATE= 2.0  
ACT= 134.0; REL= 104.4; DIF= 29.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 276; FIX 4; C= 000000; BIN=8000; MFRU=44.3; MFRD=47.6; LEAK RATE= 2.0  
ACT= 122.9; REL= 87.3; DIF= 35.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:44:31.03 OPER DOOR DID NOT CLOSE 1

SER 277; FIX 1; C= 000000; BIN=8000; MFRU=44.2; MFRD=47.2; LEAK RATE= 1.9  
ACT= 131.0; REL= 99.1; DIF= 31.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 278; FIX 2; C= 000000; BIN=8000; MFRU=44.2; MFRD=47.2; LEAK RATE= 1.9  
ACT= 123.8; REL= 90.6; DIF= 33.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 279; FIX 3; C= 000000; BIN=8000; MFRU=44.2; MFRD=47.2; LEAK RATE= 1.9  
ACT= 123.8; REL= 97.5; DIF= 26.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

380  
\*

SER 300; FIX 4; C= 000000; BIN=8000; MFRU=44.2; MFRD=47.2; LEAK RATE= 1.9  
ACT= 126.9; REL= 91.8; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:45:11.54 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:45:31.54 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 11:45:46.25 TOOL CYCLE TIMEOUT 1

\*

SER 301; FIX 1; C= 000000; BIN=8000; MFRU=44.3; MFRD=47.7; LEAK RATE= 1.9

151

SER 302; FIX 2; C= 000000; BIN=8000; MFRU=44.3; MFRD=47.7; LEAK RATE= 1.9  
ACT= 127.4; REL= 89.5; DIF= 38.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 303; FIX 3; C= 000000; BIN=8000; MFRU=44.3; MFRD=47.7; LEAK RATE= 1.9  
ACT= 129.8; REL= 103.2; DIF= 26.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 304; FIX 4; C= 000000; BIN=8000; MFRU=44.3; MFRD=47.7; LEAK RATE= 1.9  
ACT= 133.4; REL= 101.8; DIF= 31.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:46:18.12 OPER DOOR DID NOT CLOSE 1

77-9 PRESSURE TESTER LOT REPORT

RATING: 77PBL2-1  
LOR ID: 1-R-2107  
LOT STARTED: 17-APR-1992 10:11:04.08  
TIME PRINTED: 17-APR-1992 11:46:18.93

SETUP DATA:

DISC LOT ID: 0.00  
DIBC MEAN ACTL 23.4 MEAN REL: 12.7  
LIMIT (NC)  
ACTUATION: 90.0 TO 160.0 PSI  
RELEASE: 20.0 TO 120.0 PSI  
DIFFERENTIAL: 0.0 TO 160.0 PSI  
MAX MILLIVOLT: 500.0 PSI  
ACT CREEP TIME: 25.0 PSI  
REL CREEP TIME: 150.0 PSI  
PRECYCLE PRESS: 800.0 PSI  
PRECYCLE COUNT: 2

NUMBER OF PIECES TESTED: 304  
NUMBER OF PIECES GOOD: 302  
YIELD: 99.34 %

REF: 01 000016

```

LEAK: 0 0.00 %
CONT: 2 100.00 %
ADCP: 0 0.00 %
ACLD: 0 0.00 %
ADHI: 0 0.00 %
RLHI: 0 0.00 %
MLLD: 0 0.00 %
DFLD: 0 0.00 %
RLCR: 0 0.00 %
DFHL: 0 0.00 %


```

```


STATISTICS      MEAN      SIGMA
ACTUATION:     130.6      4.89      2.00
RELEASE:        97.7      5.96      1.25
WILLVOLT:       0.0      0.00      0.00
DIFFERENTIAL:  32.9      3.19      3.44

```


HISTOGRAM OF ACTUATION PRESSURE




HISTOGRAM OF RELEASE PRESSURE




HISTOGRAM OF DIFFERENTIAL PRESSURE



HISTOGRAM OF ACTUATION CREEP



HISTOGRAM OF RELEASE CREEP



163.0 01 |  
165.0 01 |  
170.0 01 |  
175.0 01 |  
180.0 01 |  
185.0 01 |  
OVER 299 | \*\*\*\*\*

17-APR-1992 11:46:54.31 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:47:14.30 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 11:47:30.04 TOOL CYCLE TIMEOUT 1

**TEST REPORT**

TI-NHTSA 008457



# INITIAL SAMPLE WARRANT

No. **360068**

### PART INFORMATION

Part Name NEXT GENERATION SPEED CONTROL DEACTIVATION SWITCH Part Number F2AG-9F924-AA

Control Item  Yes  No Engineering Change Level \_\_\_\_\_ Date \_\_\_\_\_

Engineering Change Authorization \_\_\_\_\_ Date \_\_\_\_\_

Shown on Drawing No. F2AG-9F924-AA Part Weight \_\_\_\_\_ .062 kg

#### Reason for Initial Sample:

- Initial Submission
- Engineering Change(s)
- Tooling Transfer
- Other - Please Specify \_\_\_\_\_
- Change in Optional Construction or Material
- Additional, Replacement, or Refurbished Tooling
- Correction of Discrepancy (Resubmission No. \_\_\_\_\_)
- Process Change
- Change in Subcontractor or Source
- Parts Produced at Additional Location

### SUPPLIER INFORMATION (Manufacturing Location)

Supplier Name TEXAS INSTRUMENTS INC. Street Address 34 BORNST STREET

City ATTLEBORO State MA Postal Code 01703 Country USA

Supplier Mfg. Location Code - DUNS T095A/7325814 Customer Assigned \_\_\_\_\_

### CUSTOMER INFORMATION

Customer Name DANA CORPORATION Buyer GRANT SYMONS Buyer Code \_\_\_\_\_

Purchase Order Number \_\_\_\_\_ Sample Acceptance Level \_\_\_\_\_

Application NEXT GENERATION SPEED CONTROL DEACTIVATION SWITCH

### RESULTS

The results for dimensional measurements , material tests , and functional (ES) tests  meet all drawing and specification requirements  Yes  No

#### Submission Checklist

- Checked Print
- Auxiliary Drawings/Sketches
- Correct Number of Samples
- Dimensional Results
- Material Test Results
- Certifications
- Functional (ES) Test Results
- Product Engineering Approval
- Control Plan
- Process Capability Results
- Process Flow Diagram
- Gage (Measurement) Studies

Supporting data for all requirements are available upon request.

### COMMENTS:

### DECLARATION


I affirm that the samples represented by this warrant are representative of our parts and have been made to the applicable customer drawings and specifications from specified materials, on regular production tooling with no operations other than the regular production process.

Authorized Signature *Jim Watt* Date 8/19/92

Print Name JIM WATT Title QRA ENGINEER Phone No. (508) 699-1719

APPROVAL (When required by customer procedure)  Approved  Rejected

Signature \_\_\_\_\_ Date \_\_\_\_\_



# INITIAL SAMPLE WARRANT

No. 112389

### PART INFORMATION

Next Generation Speed Control  
Part Name Deactivation Safety Switch Part Number F2AC-9F924-AA

Control Item  Yes  No Engineering Change Level \_\_\_\_\_ Date \_\_\_\_\_

Engineering Change Authorization Bruce Haroff Date \_\_\_\_\_

Shown on Drawing No. F2AC-9F924-AA Part Weight -062 by \_\_\_\_\_

### Reason for Initial Sample:

- Initial Submission
- Change in Optional Construction or Material
- Process Change
- Engineering Change(s)
- Additional, Replacement, or Refurbished Tooling
- Change in Subcontractor or Source
- Tooling Transfer
- Correction of Discrepancy (Resubmission No. \_\_\_\_\_)
- Parts Produced at Additional Location
- Other - Please Specify \_\_\_\_\_

### SUPPLIER INFORMATION (Manufacturing Location)

Supplier Name Texas Instruments Street Address 34 Forest St.

City Attleboro State MA Postal Code 02703 Country USA

Supplier Mfg. Location Code - DUNS T097K/7325814 Customer Assigned \_\_\_\_\_

### CUSTOMER INFORMATION

Customer Name Ford Motor Co. NA&O Buyer Fred Mandarabot Buyer Code 165

Purchase Order Number \_\_\_\_\_ Sample Acceptance Level \_\_\_\_\_

Application Next Generation Speed Control Deactivation Safety Switch

### RESULTS

The results for dimensional requirements , material tests , and functional (ES) tests  meet all drawing and specification requirements  Yes  No PARTIAL

### Submission Checklist

- Checked Print
- Material Test Results
- Control Plan
- Auxiliary Drawings/Sketches
- Certifications
- Process Capability Results
- Correct Number of Samples
- Functional (ES) Test Results PARTIAL
- Process Flow Diagram
- Dimensional Results
- Product Engineering Approval
- Gage (Measurement) Studies

Supporting data for all requirements are available upon request.

### COMMENTS:

Partial ISW to expedite use of "Quiet" Switch, full submission to be complete by 6/23/92. Bruce Haroff visited TI on 4/13, 4/14 to review program status.

### DECLARATION

I affirm that the samples represented by this warrant are representative of our parts and have been made to the applicable customer drawings and specifications from specified materials, on regular production tooling with no operations other than the regular production process.

Authorized Signature Michael DeMatthia Date 4-13-92

Print Name Michael DeMatthia Title SQA ENGINEER Phone No. (508) 699-3090


APPROVAL (when required by customer procedure)  Approved  Rejected

Signature \_\_\_\_\_ Date \_\_\_\_\_

Doc # 292c

TI-NHTSA 006459





# INITIAL SAMPLE WARRANT

No. 112384

### PART INFORMATION

Part Name NEXT GENERATION SPEED CONTROL Part Number F2VC-9F924-AB

Control Item  Yes  No Engineering Change Level G Date 4-11-91

Engineering Change Authorization BRUCE DEASH Date \_\_\_\_\_

Shown on Drawing No. F2VC-9F924-AB Part Weight 062 kg

### Reason for Initial Sample:

- Initial Submission
- Engineering Change(s)
- Tooling Transfer
- Other - Please Specify \_\_\_\_\_
- Change in Optional Construction or Material
- Additional Replacement of Returned Tooling
- Correction of Discrepancy (Resubmission No. \_\_\_\_\_)
- SEE BELOW
- Process Change
- Change in Subcontractor or Source
- Parts Produced at Additional Location

### SUPPLIER INFORMATION (Manufacturing Location)

Supplier Name TEXAS INSTRUMENTS Street Address 34 FOREST STREET

City ATTLEBORO State MA Postal Code 02703 Country USA

Supplier Mfg. Location Code - IUNS TQ97K Customer Assigned FORD MOTOR CO - EED

### CUSTOMER INFORMATION

Customer Name FORD MOTOR CO - EED Buyer FRED HENDERSHOT Buyer Code 165

Purchase Order Number \_\_\_\_\_ Sample Acceptance Level 1

Application NEXT GENERATION SPEED CONTROL

### RESULTS

The results for dimensional measurements , material tests , and functional (E3) tests  meet all drawing and specification requirements  Yes  No

### Submission Checklist

- Checked Print
- Auxiliary Drawings/Sketches
- Correct Number of Samples
- Dimensional Results
- Material Test Results
- Certifications
- Functional (E3) Test Results
- Product Engineering Approval
- Control Plan
- Process Capability Results
- Process Flow Diagram
- Gage (Measurement) Studies

Supporting data for all requirements are available upon request.

### COMMENTS:

ISR SUPPLEMENT WITH ADDITIONAL TESTING TO CLOSE OUT ALERT NO. A10166193;  
ALSO, CORRECTED BASE MOLD DIMENSIONS. PART PREVIOUSLY APPROVED ON  
ISN # 112384, DATED 9/27/91

### DECLARATION

I affirm that the samples represented by this warrant are representative of our parts and have been made to the applicable customer drawings and specifications from specified materials, on regular production testing with no operations other than the regular production process.

Authorized Signature Jim Watt Date 12/20/91

Print Name: JIM WATT Title QA ENGINEER Phone No. 508-699-1719

APPROVAL (when required by customer procedures)  Approved  Rejected

Signature [Signature] Date 1/14/92

Stamp: 292C Vehicle Operations EDA

**FAL/PRINT**

**TI-NHTSA 006462**

**DRAWINGS AVAILABLE UPON  
REQUEST**