

**EA02025**

**TEXAS INSTRUMENTS, INC.'S**

**9/10/03 ATTACHMENT TO ODI**

**BOX 4, PARTS A - N**

**PART N**

## PROCESS POTENTIAL AND QUALITY INDEXES SUMMARY DATA SHEET

PART #: P2AC-DEB2A-AASUPPLIER: TEXAS INSTRUMENTSCODE: 1095AADDRESS: 34 FOREST ST.ATTLEBORO, MA 02703VEHICLE BUILD: EP VP FB OTHERSUPPLIER CONTACT: JIM WATTCONTACT PHONE: (508) 699-1719PART DESCRIPTION: NEXT GENERATION SPEED

CONTROL DEACTIVATION SWITCH

SQA CODE: \_\_\_\_\_

VEHICLE PROGRAM: PASS CAR RN53

## CHARACTERISTIC TYPE

▽ = FORD CRITICAL  
CHARACTERISTICSS.C. = FORD OR SUPPLIER SIGNIFICANT  
CHARACTERISTICS

## NUMBER OF CRITICAL AND SIGNIFICANT CHARACTERISTICS:

|                                |                 |                |                 |
|--------------------------------|-----------------|----------------|-----------------|
| 1: <u>ACTUATION</u>            | TYPE: <u>SC</u> | Cp = <u>**</u> | Cpk = <u>**</u> |
| 2: <u>RELEASE</u>              | TYPE: <u>SC</u> | Cp = <u>**</u> | Cpk = <u>**</u> |
| 3: <u>3/8-24UNF-2A THREADS</u> | TYPE: <u>SC</u> | Cp = <u>AS</u> | Cpk = <u>AS</u> |
| 4: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 5: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 6: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 7: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 8: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 9: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 10: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 11: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 12: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 13: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 14: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 15: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |

1833/  
 PIST = 1833 x 100 = 100 %

PIPC<sub>Cp</sub> = \_\_\_\_\_ x 100 = \_\_\_\_\_ %    PIPC<sub>Cpk</sub> = \_\_\_\_\_ x 100 = \_\_\_\_\_ %

## COMMENTS:

\*\* CALIBRATION CHECK IS DONE 100 PERCENT. PARTS TESTED 300 ;  
DEFECTIVE 0 PERCENT OF DEFECT 0.

AS THREADS ARE CHECKED ON A GO/NOGO GAGE

PREPARED BY:

ELAINE ROSEDATE: 8-19-92



INCORPORATED  
MATERIALS AND CONTAINER GROUP  
☐ ATTLEBORO, MA 01901 ☐ VERMILION, NY 14085  
☐ CENTRAL LAKE, MI 48826

REF. # \_\_\_\_\_ DATE SHIPPED 8/19/91  
SHIPPED VIA OVERSEAS TNT 1A

SHIP TO: **BAEA CORPORATION**  
**WATERLOO DIVISION**  
**100 ECHAMPT STREET**  
**ST. THOMAS, ONTARIO**  
**CANADA N5P 3K6**

USE CHECK ONE

732956055

CHARGE TO:

- ☐ SCRAP SALES  
☐ SALE OF ASSETS  
☐ OUTSIDE PROCESSING  
☐ TRANSFERS BETWEEN TI LOCATIONS  
☐ EXPENSE MATERIAL  
☒ OTHER, EXPLAIN: CUSTOMER DATA

DEVIACCT. # \_\_\_\_\_ CC: \_\_\_\_\_

| QUANTITY                                                                                 | DESCRIPTION/PART INFO                         | UNIT PRICE                | TOTAL                  |
|------------------------------------------------------------------------------------------|-----------------------------------------------|---------------------------|------------------------|
| 6                                                                                        | <sup>12-1</sup><br>77700-01 SAMPLES 03.97 ea. | n/c                       |                        |
| 1                                                                                        | 181R PEG.                                     | n/c                       |                        |
| <div style="text-align: right;"> <i>Rts</i><br/> <i>1 @ 6</i><br/> <i>8/19/91</i> </div> |                                               |                           |                        |
| OVERS WEIGHT                                                                             | NO. OF CONTAINERS                             | ORIGINATOR'S NAME (TYPED) | ORIGINATOR'S SIGNATURE |
| <u>5-5</u>                                                                               | <u>1</u>                                      | ELATHE BOX = 12-27        | <i>E. J. R. R.</i>     |

5-012540 1/82

ORIGINATOR COPY

TI-NHTSA 006938

**TEXAS INSTRUMENTS**

INCORPORATED

MATERIALS AND CONTROLS GROUP

☐ ATTLEBORO, MA 01903☐ VERBALKEN, NY 13294☐ CENTRAL LAKE, MI 48801**Shipping Order**

DATE: 8/19/92 S.O. # 271328

REF. # DATE SHIPPED / /

SHIPPED VIA: OVERNIGHT

USE (CHECK ONE)

☐ BORAP SALES☐ SALE OF ASSETS☐ OUTSIDE PROCESSING☐ TRANSFERS BETWEEN TI LOCATIONS☐ EXPENSE MATERIAL☒ OTHER, EXPLAIN: CUSTOMER DATA

DIV/ACCT. # CC:

SHIP TO:

DANA CORPORATION  
WEATHERHEAD DIVISION  
203 WEATHERHEAD STREET  
ANGOLA, INDIANA 46703

CHARGE TO:

| QUANTITY     | DESCRIPTION/PART #/PO | UNIT PRICE             | TOTAL                                          |
|--------------|-----------------------|------------------------|------------------------------------------------|
| 6            | 772SL3-1 SAMPLES      | n/c                    |                                                |
| 1            | 1912 PKG.             | n/c                    |                                                |
| GROSS WEIGHT |                       | NO. OF CONTAINERS      | ORIGINATOR'S NAME (TYPED)<br>ELAINE ROSE 12-27 |
|              |                       | ORIGINATOR'S SIGNATURE |                                                |

TI-NHTSA 008939

 **TEXAS INSTRUMENTS**
**Shipping Order**

INCORPORATED

MATERIALS AND CONTROLS GROUP

☐ ATTLEBORO, MA 01920☐ VERMILION, NY 14083☐ CENTRAL LAKE, MI 49622DATE: 8 / 19 / 92 R.O. # 271329REF. # \_\_\_\_\_ DATE SHIPPED 1 / 1SHIPPED VIA: OVERNIGHT

USE (CHECK ONE)

☐ SCRAP SALES☐ SALE OF ASSETS☐ OUTSIDE PROCESSING☐ TRANSFERS BETWEEN TI LOCATIONS☐ EXPENSE MATERIAL☒ OTHER, EXPLAIN: CUSTOMER DATA

DIV/AOCT. # \_\_\_\_\_ CC: \_\_\_\_\_

SHIP  
TO:

DANA CORPORATION  
WEATHERHEAD DIVISION  
109 INCREMENT STREET  
ST. THOMAS, ONTARIO  
CANADA N5P3G8

CHANGE  
TO:

| QUANTITY     | DESCRIPTION/PART #/PO      | UNIT PRICE             | TOTAL                                             |
|--------------|----------------------------|------------------------|---------------------------------------------------|
| 6            | 77PSL3-2 SAMPLES @3.97 ea. | n/c                    |                                                   |
| 1            | ISIR PKG.                  | n/c                    |                                                   |
| GROSS WEIGHT |                            | NO. OF CONTAINERS      | ORIGINATOR'S NAME (TYPED)<br>ELAINS ROSE on 12-27 |
|              |                            | ORIGINATOR'S SIGNATURE |                                                   |

TI-NHTSA 006940



**Ford**

**PROCESS POTENTIAL AND QUALITY INDEXES SUMMARY DATA SHEET**

PART #: F2AC-9F924-AA  
 SUPPLIER: TEXAS Instruments  
 CODE: 70958  
 ADDRESS: 34 FRONT ST.  
ATTLEBORO, MA.  
 VEHICLE BUILD: EP VP FB OTHER

SUPPLIER CONTACT: Jim Watt  
 CONTACT PHONE: (508) 699-1719  
 PART DESCRIPTION: Next Generation  
Speed Control Deactivation Safety  
 BGA CODE: \_\_\_\_\_  
 VEHICLE PROGRAM: PASS CAR

*Section*

**CHARACTERISTIC TYPE**

**▽ = FORD CRITICAL CHARACTERISTICS**

**S.C. = FORD OR SUPPLIER SIGNIFICANT CHARACTERISTICS**

**NUMBER OF CRITICAL AND SIGNIFICANT CHARACTERISTICS:**

|                               |                 |                |                 |
|-------------------------------|-----------------|----------------|-----------------|
| 1: <u>Activation Pressure</u> | TYPE: <u>SC</u> | Cp = <u>**</u> | Cpk = <u>**</u> |
| 2: <u>Release Pressure</u>    | TYPE: <u>SC</u> | Cp = <u>**</u> | Cpk = <u>**</u> |
| 3: <u>3/P-24UNF-2A TH.</u>    | TYPE: <u>SC</u> | Cp = <u>A*</u> | Cpk = <u>A*</u> |
| 4: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 5: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 6: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 7: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 8: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 9: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 10: _____                     | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 11: _____                     | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 12: _____                     | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 13: _____                     | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 14: _____                     | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 15: _____                     | TYPE: _____     | Cp = _____     | Cpk = _____     |

PIST =  $\frac{1833}{1823} \times 100 = 100\%$

PIPC<sub>Cp</sub> = \_\_\_\_\_  $\times 100 =$  \_\_\_\_\_ %    PIPC<sub>Cpk</sub> = \_\_\_\_\_  $\times 100 =$  \_\_\_\_\_ %

**COMMENTS:**

\* & Calibration check is done 100%. Part  
tested 300; defective 0. percent of  
defect 0.

A\* THREADS ARE CHECKED ON A Go/NoGo GAGE

**PREPARED BY:**

ELAINE RASE

**DATE:** 8-4-92



**TEXAS INSTRUMENTS, INC. ISIR SUBMISSION  
TO DANA CORPORATION  
FOR PART NUMBER F2AC-9F924-AA (77PSL3-1)**

4-21-92

PER CONVERSATION/MATT SELLERS:  
REWORK & REMEASURE  
# 2, 3, 4, 6

4-21-92

REWORKED + REMEASURED

Dim. # 3

#2 ~~0.228~~ 0.310 mm  
~~0.418~~ 0.452 mm

#3  
0.641 mm  
0.425 mm

#4 0.531 mm  
0.591 mm

#6 0.635 mm  
0.475 mm

Term. Pos. 0.75/0.25 mm

## SAMPLE REPORT

|                                                               |  |                                                                                                                                                                                                                                                                                                            |  |             |                 |             |
|---------------------------------------------------------------|--|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|-------------|-----------------|-------------|
| <b>REASON FOR REPORT</b>                                      |  | <b>VENDOR</b>                                                                                                                                                                                                                                                                                              |  | <b>P.O.</b> | <b>PART NO.</b> | <b>REV.</b> |
| NEW PART                                                      |  |                                                                                                                                                                                                                                                                                                            |  |             | 770543-1        | A           |
| REPLACEMENT TOOL                                              |  | REPORT REQ. BY                                                                                                                                                                                                                                                                                             |  | DATE        | INSPECTED BY    | DATE        |
| CORRECTED TOOL                                                |  | Elaine Rose                                                                                                                                                                                                                                                                                                |  | 4/14/92     | Sandy Gilbert   | 4/1         |
| REPAIRED TOOL                                                 |  |                                                                                                                                                                                                                                                                                                            |  |             |                 |             |
| REVIEW                                                        |  |                                                                                                                                                                                                                                                                                                            |  |             |                 |             |
| OTHER <u>Dim analysis</u> <input checked="" type="checkbox"/> |  | <p>THE DIMENSIONS INDICATED BELOW REPRESENT TEXAS INSTRUMENTS' FINDINGS REGARDING ACTUAL VALUES FOR ALL CHARACTERISTICS MEASURED. IN CASES WHERE ACTUAL VALUES DEPART FROM THE SPECIFIED DIMENSIONS, THE DISPOSITION MUST INDICATE THE REQUIRED ACTION EACH NON-CONFORMANCE IN THE APPROPRIATE COLUMN.</p> |  |             |                 |             |

|    |                                        | (CIRCLE ALL OUT OF TOLERANCE DIMENSIONS) |        |        |        | DISPOSITION |        |         |
|----|----------------------------------------|------------------------------------------|--------|--------|--------|-------------|--------|---------|
|    | Dimension                              | 1                                        | 2      | 3      | 4      | 5           | 6      | REMARKS |
| 1  | 1.85-2.06                              | 1.933                                    | 1.933  | 1.942  | 1.956  | 1.980       | 1.922  | Time    |
| 2  | Ø 19.05 max                            | 18.994                                   | 18.994 | 18.994 | 18.994 | 18.994      | 18.994 | "       |
| 3  | .25-.75                                | 0.599                                    | 0.561  | 0.552  | 0.522  | 0.552       | 0.495  | "       |
|    |                                        | 0.748                                    | 0.804  | 0.752  | 0.805  | 0.684       | 0.707  | "       |
| 4  | 2.79-3.10 2 pk                         | 2.90                                     | 2.90   | 2.91   | 2.92   | 2.91        | 2.91   | Cal     |
|    |                                        | 2.91                                     | 2.92   | 2.93   | 2.94   | 2.92        | 2.94   | "       |
| 5  | 19.45-19.81                            | 19.65                                    | 19.70  | 19.71  | 19.73  | 19.75       | 19.73  | "       |
| 6  | 11.40-11.90                            | 11.794                                   | 11.797 | 11.791 | 11.790 | 11.784      | 11.788 | Time    |
| 7  | 16.56-16.76                            | 16.623                                   | 16.652 | 16.636 | 16.654 | 16.626      | 16.646 | "       |
| 8  | 2.84-3.05                              | 2.936                                    | 2.948  | 2.927  | 2.924  | 2.910       | 2.919  | "       |
|    | Ø 0.15 A                               | 0.035                                    | 0.017  | 0.018  | 0.026  | 0.043       | 0.020  | "       |
| 9  | 1.24-1.45                              | 1.241                                    | 1.242  | 1.249  | 1.260  | 1.270       | 1.248  | "       |
| 10 | 11.60-11.92                            | 11.864                                   | 11.719 | 11.725 | 11.681 | 11.682      | 11.736 | "       |
| 11 | 1.24-1.55                              | 1.334                                    | 1.397  | 1.393  | 1.397  | 1.425       | 1.388  | "       |
| 12 | 57.15 max                              | 55.64                                    | 55.65  | 55.69  | 55.75  | 55.75       | 55.71  | Cal     |
| 13 | 12.59-13.11                            | 12.824                                   | 12.862 | 12.914 | 12.933 | 12.850      | 12.866 | NO      |
| 14 | 11.65-12.17                            | 12.023                                   | 12.025 | 12.146 | 12.126 | 12.068      | 12.087 | "       |
|    |                                        | 11.963                                   | 11.823 | 12.056 | 12.081 | 12.011      | 12.055 | "       |
| 15 | 6.60-6.81                              | 6.702                                    | 6.696  | 6.690  | 6.690  | 6.708       | 6.721  | Time    |
| 16 | NO Flash or<br>Burr on this<br>surface | OK                                       | OK     | OK     | OK     | OK          | OK     | Visual  |
| 17 | 2.79-3.41                              | 3.053                                    | 3.164  | 3.162  | 3.205  | 3.187       | 3.25   | Comp    |
| 18 | 0.68-1.30                              | 1.137                                    | 1.066  | 1.153  | 1.165  | 1.071       | 1.117  | "       |
| 19 | Stamp Date case<br>& Find PA.          | OK                                       | OK     | OK     | OK     | OK          | OK     | Visual  |

REMARKS AND/OR INSTRUCTIONS:

DISPOSITION: TOOL APPROVED FOR PROD.

RESUBMISSION REQ'D

MFG. ENG.:

QRA ENG.:

PURCH. AGENT:

# TEXAS INSTRUMENTS

ATTACHED: HANDBOOKS 00704

PAGE 2 OF

## SAMPLE REPORT

F2AC-9F924-AA

| REASON FOR REPORT           | VENDOR                                                                                                                                                                                                                                                                                                      | P.O.    | PART NO.      | REV. |
|-----------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------|---------------|------|
| NEW PART                    |                                                                                                                                                                                                                                                                                                             |         | 77PS23-1      | 1    |
| REPLACEMENT TOOL.           | REPORT REQ. BY                                                                                                                                                                                                                                                                                              | DATE    | INSPECTED BY  | DATE |
| CORRECTED TOOL.             | Elaine Rose                                                                                                                                                                                                                                                                                                 | 4/14/82 | Sandy Gilbert | 4/6  |
| REPAIRED TOOL.              |                                                                                                                                                                                                                                                                                                             |         |               |      |
| REVIEW                      |                                                                                                                                                                                                                                                                                                             |         |               |      |
| OTHER <u>Dim analysis</u> X | <p>THE DIMENSIONS INDICATED BELOW REPRESENT TEXAS INSTRUMENTS' FINDINGS REGARDING ACTUAL VALUES FOR ALL CHARACTERISTICS MEASURED. IN CASES WHERE ACTUAL VALUES DEVIATE FROM THE SPECIFIED DIMENSIONS, THE DISPOSITION MUST INDICATE THE REQUIRED ACTION EACH NON-CONFORMANCE IN THE APPROPRIATE COLUMN.</p> |         |               |      |

| CIRCLE ALL OUT OF TOLERANCE DIMENSIONS |       |      |      |         |      | DISPOSITION |                       |
|----------------------------------------|-------|------|------|---------|------|-------------|-----------------------|
| Dimension                              | 1     | 2    | 3    | 4       | 5    | 6           | METHOD OF MEASUREMENT |
| 20 3/8-24 UNF 2A                       | OK    | OK   | OK   | OK      | OK   | OK          | Visual                |
| 3667-3739                              | 3715  | 3725 | 3710 | 3715    | 3705 | 3710        | Cal                   |
| 21 1.10-1.40                           | 1.224 |      |      | section |      |             | TIME                  |
| 22 1.50                                | OK    |      |      | section |      |             | WIRE MEAS             |
| 23 0.16                                |       |      |      |         |      |             |                       |
| 24 410-430                             |       |      |      |         |      |             | TIME                  |
| 25 40°-50° cham                        |       |      |      |         |      | 46°9'       | COMP                  |
| 26 7.82-8.03                           |       |      |      |         |      | 7.920       | "                     |
| 27 152-204                             |       |      |      |         |      | 1.713       | "                     |
| 28 9.39-9.66                           |       |      |      |         |      | 9.447       | 2ND                   |
| 29 8.12 min                            |       |      |      |         |      | 8.881       | "                     |
| 30 14.23 max                           |       |      |      |         |      | 13.66       | Cal                   |
| 31 32.51 max                           |       |      |      |         |      | 31.48       | "                     |
| 32 5.58-5.85                           |       |      |      |         |      | 5.778       | TIME                  |
| 33 7.23-7.37                           |       |      |      |         |      | 7.317       | "                     |
| 34 3.30-3.60                           |       |      |      |         |      | 3.482       | "                     |
| 35 14.02-14.53 H                       |       |      |      |         |      | 14.24       | Cal                   |
| 36 0.58-0.68 2p                        |       |      |      |         |      | 0.607       | TIME                  |
| 37 2.59-2.80 2p                        |       |      |      |         |      | 2.615       | "                     |
| 38 0.25 (H) 4p                         |       |      |      |         |      | 2.638       | "                     |
| 39 30-8.72 2p                          |       |      |      |         |      | 0.044       | "                     |
| 40 2.5° 2 p                            |       |      |      |         |      | 0.103       | "                     |
| 41 2.5° 2 p                            |       |      |      |         |      | 8.343       | COMP                  |
| 42 2.5° 2 p                            |       |      |      |         |      | 1.322       | "                     |
| 43 2.5° 2 p                            |       |      |      |         |      | 25° 4'      | "                     |

REMARKS AND/OR INSTRUCTION

DISPOSITION: TOOL APPROV

MFG. ENG.:

FORM NO. 1078

TI-NHT8A 008946

## ATTENTION: MANAGING-EDITOR OF THE

PAGE 3 OF

## SAMPLE REPORT

|                   |                |                                                                                                                                                                                                                                                                                                          |         |               |          |      |
|-------------------|----------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------|---------------|----------|------|
| REASON FOR REPORT |                | VENDOR                                                                                                                                                                                                                                                                                                   |         | P.O.          | PART NO. | REV. |
| NEW PART          |                |                                                                                                                                                                                                                                                                                                          |         |               | 77PSL3-1 | /    |
| REPLACEMENT TOOL. |                | REPORT REQ. BY                                                                                                                                                                                                                                                                                           | DATE    | INSPECTED BY  |          | DATE |
| CORRECTED TOOL.   |                | Elaine Rose                                                                                                                                                                                                                                                                                              | 4/14/92 | Sandy Gilbert |          | 4/2  |
| REPAIRED TOOL.    |                | THE DIMENSIONS INDICATED BELOW REPRESENT TEXAS INSTRUMENTS' FINDINGS REGARDING ACTUAL VALUES FOR ALL CHARACTERISTICS MEASURED. IN CASES WHERE ACTUAL VALUES DEVIATE FROM THE SPECIFIED DIMENSIONS, THE DISPOSITION MUST INDICATE THE REQUIRED ACTION FOR EACH NON-CONFORMANCE IN THE APPROPRIATE COLUMN. |         |               |          |      |
| REVIEW            |                |                                                                                                                                                                                                                                                                                                          |         |               |          |      |
| OTHER             | Dim analysis X |                                                                                                                                                                                                                                                                                                          |         |               |          |      |

| (CIRCLE ALL OUT OF TOLERANCE DIMENSIONS) |                                   |         |         |         |         |         | DISPOSITION |                          |
|------------------------------------------|-----------------------------------|---------|---------|---------|---------|---------|-------------|--------------------------|
|                                          | Dimension                         | 1       | 2       | 3       | 4       | 5       | 6           | REMARKS<br>OF<br>FURNISH |
| 39                                       | Cont                              | 24° 21' | 23° 36' | 23° 42' | 22° 47' | 24° 20' | 23° 26'     | Stamp                    |
| 40                                       | Housing to be<br>NATURAL in color | OK      | OK      | OK      | OK      | OK      | OK          | Visual                   |
| 41                                       | (71.5°) 2 pks                     | 71° 49' | 71° 25' | 72° 21' | 71° 45' | 71° 43' | 71° 44'     | Stamp                    |
|                                          |                                   | 72° 37' | 72° 21' | 72° 14' | 72° 30' | 72° 5'  | 72° 26'     | "                        |

REMARKS AND/OR INSTRUCTIONS:

|                                      |                    |
|--------------------------------------|--------------------|
| DISPOSITION: TOOL APPROVED FOR PROD. | RESUBMISSION REQ'D |
| MFG. ENG.:                           | QRA ENG.:          |
|                                      | PURCH. AGENT:      |

**DRAWINGS AVAILABLE UPON  
REQUEST**

TEXAS INSTRUMENTS INCORPORATED  
CONTROL PRODUCTS DIVISION  
ATTLEBORO, MASSACHUSETTS 02703

QUALITY ASSURANCE WORK ORDER

\* INDICATE TYPE OF SERVICE REQUESTED:

NOTICE: TWO COPIES OF THE DRAWING MUST  
BE ENCLOSED WITH YOUR REQUEST.

IMPORTANT: SUPPLIER F.A.I. ENCLOSED WITH  
THIS REQUEST: YES/NO \_\_\_\_\_

☒ FIRST ARTICLE INSPECTION  
☐ PARTIAL "FAI"  
☐ TOOLPROOF  
☐ DIMENSIONAL ANALYSIS  
☐ MACHINE CAPABILITY  
☐ PROCESS CAPABILITY

\* INDICATE ONE OF THE FOLLOWING REASONS:

(▽ F&AC-9F924-AA)

☒ NEW PART / NEW TOOL / MOLD  
☐ CORRECTED TOOL / MOLD  
☐ OTHER \_\_\_\_\_

\* PART NUMBER: 77PSL3-1

DRAWING REVISION: A

NUMBER OF CAVITIES / STATIONS 6

TOOL ID: \_\_\_\_\_

TYPE OF MATERIAL: NORYL

PART DESCRIPTION: Pressure Switch

SUPPLIER: \_\_\_\_\_

SAMPLE / MOLD DATE: \_\_\_\_\_

\* DATE SUBMITTED: 4-14-92

DATE REQUIRED: 4/24/92

REQUESTED BY: ELAINE ROSE

H/S: 12-27

COST CENTER: 149

PRODUCT CODE: 88

EXT: 1907

PRIORITY ( INDICATE ONE ) : ☒ URGENT \* ☐ AS DATED

\*\* "URGENT" PRIORITY REQUIRES MANAGERS APPROVAL

APPROVED BY ( IF REQUIRED ) : N. D. Wells

ENGINEERING SPECIAL INSTRUCTIONS

NOTES

- 1.) A "FIRST ARTICLE INSPECTION", "PARTIAL F.A.I.", OR A "TOOLPROOF", ALL REQUIRE A "DISPOSITION" FROM THE MATERIALS REVIEW BOARD, INCLUDING ALL APPROPRIATE SIGNATURES. ALSO, THE DISPOSITIONED COPY MUST BE RETURNED TO RECEIVING INSPECTION CCH146 FOR PROPER RECORDING.
- 2.) RECORDS: A) COPIES OF ALL "FIRST ARTICLE INSPECTIONS" ( INCLUDING PROFILES ) WILL BE RETAINED BY RECEIVING INSPECTION FOR SEVEN YEARS.  
B) RECORDS OF ALL OTHER ANALYSIS WILL NOT BE RETAINED BY RECEIVING INSPECTION.
- 3.) "DIMENSIONAL ANALYSIS": ANY REQUEST FOR A DIMENSIONAL ANALYSIS THAT INCLUDES ALL DIMENSIONS, OR ALL "CRITICAL" & "HOLD" DIMENSIONS, WILL BE CONSIDERED A "FIRST ARTICLE INSPECTION" OR A "TOOLPROOF", AND WILL REQUIRE DISPOSITION BY THE MATERIALS REVIEW BOARD. THE APPROVED COPY MUST BE RETURNED TO RECEIVING INSPECTION CCH146.

QUALITY ASSURANCE

DATE REC.: \_\_\_\_\_

EST. HRS.: \_\_\_\_\_

COMPLETED: \_\_\_\_\_

BY: \_\_\_\_\_

RECEIVING INSPECTION

77PSL3-1

Act. 90-160 psi

6-29-92

Data obtained Apr. 16 '92

pg. 1 of 2

|    |       |       |           |         |       |       |
|----|-------|-------|-----------|---------|-------|-------|
| 1  | 128.2 | 125.9 | 130.4     | * 178.0 | 127.6 | 141.4 |
| 2  | 129.4 | 127.2 | 132.6     | 139.2   |       | 140.5 |
| 3  | 129.7 | 123.3 | 138.2     | 129.4   |       | 130.8 |
| 4  | 134.0 | 131.2 | 125.9     | 131.6   |       | 138.7 |
| 5  | 140.5 | 122.5 | 140.4     | 132.5   |       | 133.4 |
| 6  | 134.7 | 133.5 | 133.8     | 136.1   |       | 131.7 |
| 7  | 130.7 | 138.9 | 132.4     | 130.4   |       | 134.6 |
| 8  | 121.3 | 132.0 | 139.1     | 134.1   |       | 129.9 |
| 9  | 139.4 | 120.8 | 127.6     | 125.0   |       | 128.4 |
| 10 | 124.9 | 122.5 | 137.5     | 130.4   |       | 126.5 |
| 11 | 122.4 | 122.1 | 131.3     | 133.2   |       | 132.9 |
| 12 | 127.8 | 125.3 | 129.0     | 131.0   |       | 126.0 |
| 13 | 123.6 | 127.1 | 125.3     | 127.2   |       | 129.2 |
| 14 | 129.1 | 125.8 | 133.2     | 133.2   |       | 133.3 |
| 15 | 134.7 | 134.9 | 134.4     | 137.2   |       | 136.9 |
| 16 | 137.3 | 129.3 | 124.3     | 129.2   |       | 127.2 |
| 17 | 131.0 | 140.6 | 132.4     | 126.7   |       | 133.4 |
| 18 | 136.8 | 125.5 | 129.1     | 125.3   |       | 125.0 |
| 19 | 136.8 | 131.3 | 119.2     | 122.3   |       | 139.7 |
| 20 | 132.3 | 122.8 | 132.4     | 126.5   |       | 125.3 |
| 21 | 139.0 | 134.0 | 135.2     | 127.1   |       | 134.7 |
| 22 | 128.8 | 127.4 | 120.6     | 123.6   |       | 127.5 |
| 23 | 131.6 | 130.4 | 122.2     | 134.0   |       | 126.6 |
| 24 | 141.3 | 122.0 | * (177.2) | 143.6   | 142.9 | 133.8 |
| 25 | 120.7 | 122.7 | 122.5     | 125.9   |       | 132.5 |
| 26 | 133.6 | 125.9 | 125.4     | 134.5   |       | 129.9 |
| 27 | 131.7 | 127.0 | 125.4     | 132.2   |       | 133.5 |
| 28 | 127.5 | 126.0 | 131.2     | 128.0   |       | 126.6 |
| 29 | 132.1 | 129.3 | 134.4     | 131.7   |       | 124.9 |
| 30 | 128.3 | 132.6 | 131.3     | 126.3   |       | 127.2 |
| 31 | 126.4 | 127.3 | 129.5     | 131.7   |       | 126.3 |
| 32 | 132.6 | 121.7 | 122.2     | 122.5   |       | 130.2 |
| 33 | 134.5 | 129.2 | 137.2     | 133.1   |       | 117.2 |
| 34 | 130.5 | 131.6 | 122.7     | 121.7   |       | 128.9 |
| 35 | 128.3 | 141.6 | 129.1     | 123.3   |       | 129.3 |
| 36 | 126.7 | 117.2 | 127.3     | 135.3   |       | 128.7 |
| 37 | 135.6 | 130.4 | 128.1     | 129.9   |       | 126.6 |
| 38 | 131.7 | 119.2 | 130.7     | 132.6   |       | 132.4 |
| 39 | 139.6 | 128.0 | 132.8     | 125.8   |       | 132.4 |
| 40 | 133.5 | 133.9 | 129.9     | 125.0   |       | 126.9 |
| 41 | 134.9 | 136.1 | 132.7     | 122.9   |       | 135.2 |
| 42 | 128.4 | 126.1 | 119.7     | 122.4   |       | 131.0 |
| 43 | 125.9 | 132.5 | 124.4     | 130.0   |       | 126.5 |
| 44 | 121.9 | 129.3 | 131.7     | 133.3   |       | 136.0 |
| 45 | 120.9 | 129.2 | 132.3     | 130.6   |       | 138.9 |
| 46 | 126.3 | 125.6 | 126.6     | 122.1   |       | 130.4 |
| 47 | 129.2 | 132.4 | 131.5     | 132.4   |       | 126.4 |
| 48 | 134.0 | 132.9 | 122.0     | 129.8   |       | 139.3 |
| 49 | 131.2 | 133.6 | 132.2     | 133.1   |       | 126.4 |
| 50 | 133.2 | 124.6 | 131.0     | 132.7   |       | 137.5 |



77PSL3-1

Oct.

6-01-72

Data obtained Oct. 16 '92

Pg. 2 of 2

|    |       |
|----|-------|
| 1  | 131.7 |
| 2  | 128.2 |
| 3  | 131.7 |
| 4  | 124.4 |
| 5  | 137.1 |
| 6  | 120.6 |
| 7  | 130.3 |
| 8  | 133.4 |
| 9  | 124.2 |
| 10 | 133.9 |
| 11 | 133.7 |
| 12 | 130.6 |
| 13 | 128.1 |
| 14 | 128.9 |
| 15 | 130.9 |
| 16 | 133.3 |
| 17 | 127.2 |
| 18 | 130.8 |
| 19 | 129.5 |
| 20 | 130.3 |
| 21 | 142.8 |
| 22 | 126.1 |
| 23 | 127.1 |
| 24 | 130.7 |
| 25 | 134.7 |
| 26 | 127.6 |
| 27 | 127.2 |
| 28 | 123.1 |
| 29 | 128.7 |
| 30 | 125.8 |
| 31 | 130.5 |
| 32 | 123.6 |
| 33 | 131.3 |
| 34 | 134.2 |
| 35 | 131.5 |
| 36 | 137.6 |
| 37 | 125.6 |
| 38 | 129.1 |
| 39 | 133.1 |
| 40 | 126.6 |
| 41 | 128.4 |
| 42 | 137.5 |
| 43 | 129.9 |
| 44 | 125.2 |
| 45 | 134.0 |
| 46 | 122.9 |
| 47 | 131.0 |
| 48 | 123.8 |
| 49 | 123.8 |
| 50 | 126.9 |

TI-NHTSA 008952

77PSL3-1

Rel. 20 - 120 psi

6-21-72

Data obtained Apr. 16 '92

pg. 140

|    |       |       |        |         |       |       |
|----|-------|-------|--------|---------|-------|-------|
| 1  | 100.0 | 87.1  | 95.9   | * 140.7 | 89.5  | 111.0 |
| 2  | 104.0 | 95.2  | 90.2   | 97.1    |       | 116.0 |
| 3  | 88.1  | 92.4  | 103.8  | 95.8    |       | 108.3 |
| 4  | 95.6  | 93.5  | 91.4   | 99.9    |       | 104.0 |
| 5  | 111.6 | 85.6  | 113.1  | 99.9    |       | 98.3  |
| 6  | 102.0 | 92.4  | 100.6  | 102.3   |       | 102.2 |
| 7  | 98.1  | 103.9 | 94.4   | 96.6    |       | 102.2 |
| 8  | 84.2  | 107.9 | 105.9  | 97.8    |       | 100.9 |
| 9  | 105.3 | 87.1  | 100.8  | 91.8    |       | 97.6  |
| 10 | 90.2  | 88.1  | 104.9  | 96.6    |       | 95.1  |
| 11 | 97.1  | 94.5  | 100.8  | 94.4    |       | 96.3  |
| 12 | 99.8  | 101.8 | 97.0   | 97.0    |       | 94.2  |
| 13 | 100.0 | 104.8 | 92.2   | 93.3    |       | 97.4  |
| 14 | 92.6  | 103.3 | 102.1  | 95.7    |       | 97.4  |
| 15 | 106.4 | 104.6 | 98.2   | 102.3   |       | 104.1 |
| 16 | 105.3 | 90.9  | 93.6   | 98.3    |       | 93.7  |
| 17 | 95.9  | 104.6 | 104.7  | 93.2    |       | 102.5 |
| 18 | 106.1 | 104.6 | 89.9   | 86.7    |       | 92.7  |
| 19 | 107.7 | 93.6  | 88.7   | 98.1    |       | 108.2 |
| 20 | 98.2  | 94.5  | 98.2   | 90.9    |       | 90.3  |
| 21 | 103.9 | 102.1 | 107.8  | 94.4    |       | 103.5 |
| 22 | 98.4  | 92.4  | 93.8   | 96.7    |       | 94.6  |
| 23 | 93.6  | 100.1 | * 96.0 | 112.2   | 100.3 | 94.6  |
| 24 | 106.5 | 94.1  | 92.6   | 112.3   |       | 101.1 |
| 25 | 85.3  | 89.4  | 96.1   | 105.3   |       | 98.0  |
| 26 | 98.1  | 89.4  | 88.6   | 100.3   |       | 90.3  |
| 27 | 97.0  | 91.8  | 94.1   | 101.0   |       | 105.4 |
| 28 | 97.0  | 91.8  | 94.1   | 98.4    |       | 89.2  |
| 29 | 99.6  | 100.7 | 107.6  | 97.2    |       | 92.3  |
| 30 | 100.9 | 107.5 | 100.8  | 92.3    |       | 93.5  |
| 31 | 91.0  | 93.3  | 97.1   | 97.7    |       | 90.0  |
| 32 | 95.8  | 89.8  | 94.6   | 96.4    |       | 97.1  |
| 33 | 103.7 | 94.5  | 106.1  | 101.5   |       | 82.4  |
| 34 | 99.5  | 99.6  | 96.9   | 101.1   |       | 95.0  |
| 35 | 99.5  | 90.7  | 89.5   | 90.4    |       | 95.0  |
| 36 | 88.6  | 83.0  | 91.8   | 104.0   |       | 96.3  |
| 37 | 104.5 | 99.4  | 103.5  | 97.6    |       | 93.8  |
| 38 | 98.1  | 90.8  | 97.1   | 102.6   |       | 90.7  |
| 39 | 105.9 | 96.4  | 103.5  | 106.3   |       | 99.9  |
| 40 | 101.9 | 99.9  | 93.5   | 90.4    |       | 92.6  |
| 41 | 94.9  | 89.8  | 96.6   | 95.2    |       | 101.3 |
| 42 | 103.4 | 92.6  | 87.2   | 100.0   |       | 89.3  |
| 43 | 93.4  | 97.4  | 88.5   | 102.9   |       | 93.9  |
| 44 | 100.9 | 94.9  | 104.6  | 96.0    |       | 103.0 |
| 45 | 97.2  | 103.8 | 108.9  | 100.4   |       | 104.2 |
| 46 | 93.8  | 90.2  | 95.8   | 90.6    |       | 100.2 |
| 47 | 96.3  | 96.9  | 97.3   | 102.9   |       | 96.4  |
| 48 | 100.1 | 102.2 | 92.4   | 95.5    |       | 108.1 |
| 49 | 101.4 | 87.2  | 102.1  | 104.1   |       | 92.3  |
| 50 | 98.8  | 89.7  | 98.3   | 101.6   |       | 107.2 |

77PSL3-1

Data obtained Apr. 16 '92

Cal.

6-21-92

pg. 29

|    |       |
|----|-------|
| 1  | 102.4 |
| 2  | 92.3  |
| 3  | 100.8 |
| 4  | 99.5  |
| 5  | 100.8 |
| 6  | 87.3  |
| 7  | 95.2  |
| 8  | 100.1 |
| 9  | 98.8  |
| 10 | 101.2 |
| 11 | 101.4 |
| 12 | 102.8 |
| 13 | 92.7  |
| 14 | 101.4 |
| 15 | 95.9  |
| 16 | 101.0 |
| 17 | 92.5  |
| 18 | 95.9  |
| 19 | 93.7  |
| 20 | 98.5  |
| 21 | 102.8 |
| 22 | 94.9  |
| 23 | 91.1  |
| 24 | 97.2  |
| 25 | 104.8 |
| 26 | 97.2  |
| 27 | 93.6  |
| 28 | 89.0  |
| 29 | 96.1  |
| 30 | 88.0  |
| 31 | 100.6 |
| 32 | 94.2  |
| 33 | 96.8  |
| 34 | 100.6 |
| 35 | 99.6  |
| 36 | 103.6 |
| 37 | 89.8  |
| 38 | 99.6  |
| 39 | 98.5  |
| 40 | 101.0 |
| 41 | 90.6  |
| 42 | 103.6 |
| 43 | 95.5  |
| 44 | 93.0  |
| 45 | 104.4 |
| 46 | 87.3  |
| 47 | 98.1  |
| 48 | 90.6  |
| 49 | 97.5  |
| 50 | 91.8  |

17-APR-1992 09:43:52.33 OPER DOOR DID NOT CLOSE 1

17-APR-1992 09:44:12.39 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 09:44:29.35 TOOL CYCLE TIMEOUT 1

TI-NHT8A 006955

7705 PRESSURE TESTER LOT REPORT

NATINS:77PAL2-1  
LOT ID:MASTER8  
LOT STARTED:17-APR-1992 09:43:29.56  
LOT FINISHED:17-APR-1992 10:11:04.07

SETUP DATA:

DISC LOT ID: 0.00  
DISC MEAN ACT: 23.4 MEAN REL: 12.7  
LIMIT (MC)  
ACTUATION: 90.0 TO 160.0 PSI  
RELEASE: 20.0 TO 120.0 PSI  
DIFFERENTIAL: 0.0 TO 160.0 PSI  
MAX HILLWALT: 500.0 PSI  
ACT CREEP TIME: 25.0 PSI  
REL CREEP TIME: 150.0 PSI  
PRECYCLE PRESS: 800.0 PSI  
PRECYCLE COUNT: 2

NOT ENOUGH PARTS FOR REPORT ON FIXTURE Q

TI-NHTSA 008956

SER 1; FIX 1; C= 0000000; BIN=GOOD; MRRU=43.7; MRRD=47.4; LEAK RATE= 2.0  
ACT= 129.2; REL= 100.0; DIF= 25.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 2; FIX 2; C= 0000000; BIN=GOOD; MRRU=43.7; MRRD=47.4; LEAK RATE= 2.0  
ACT= 139.4; REL= 104.0; DIF= 35.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 3; FIX 3; C= 0000000; BIN=GOOD; MRRU=43.7; MRRD=47.4; LEAK RATE= 2.0  
ACT= 129.7; REL= 98.1; DIF= 41.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 4; FIX 4; C= 0000000; BIN=GOOD; MRRU=43.7; MRRD=47.4; LEAK RATE= 2.0  
ACT= 134.0; REL= 98.6; DIF= 35.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:11:26.79 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:11:46.79 OPER DOOR STILL DID NOT CLOSE 1

SER 5; FIX 1; C= 0000000; BIN=GOOD; MRRU=44.1; MRRD=48.2; LEAK RATE= 2.0  
ACT= 140.5; REL= 111.6; DIF= 28.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 6; FIX 2; C= 0000000; BIN=GOOD; MRRU=44.1; MRRD=48.2; LEAK RATE= 2.0  
ACT= 134.7; REL= 102.0; DIF= 32.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 7; FIX 3; C= 0000000; BIN=GOOD; MRRU=44.1; MRRD=48.2; LEAK RATE= 2.0  
ACT= 130.7; REL= 98.1; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 8; FIX 4; C= 0000000; BIN=GOOD; MRRU=44.1; MRRD=48.2; LEAK RATE= 2.0  
ACT= 122.3; REL= 84.2; DIF= 39.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:12:34.35 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:12:54.35 OPER DOOR STILL DID NOT CLOSE 1

SER 9; FIX 1; C= 0000000; BIN=GOOD; MRRU=44.1; MRRD=48.1; LEAK RATE= 2.0  
ACT= 139.4; REL= 105.3; DIF= 34.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

10 SER 10; FIX 2; C= 0000000; BIN=GOOD; MRRU=44.1; MRRD=48.1; LEAK RATE= 2.0  
ACT= 124.9; REL= 90.2; DIF= 34.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 11; FIX 3; C= 0000000; BIN=GOOD; MRRU=44.1; MRRD=48.1; LEAK RATE= 2.0

ACT= 127.8; REL= 97.4; DIF= 28.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:22:25.40 OPER DOOR DID NOT CLOSE 1

SER 13; FIX 1; C= 0000000; BIN=GOOD; MFRU=44.1; MFRD=47.3; LEAK RATE= 1.9  
ACT= 133.6; REL= 100.0; DIF= 33.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 14; FIX 2; C= 0000000; BIN=GOOD; MFRU=44.1; MFRD=47.3; LEAK RATE= 1.9  
ACT= 129.1; REL= 92.6; DIF= 36.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 15; FIX 3; C= 0000000; BIN=GOOD; MFRU=44.1; MFRD=47.3; LEAK RATE= 1.9  
ACT= 134.7; REL= 106.4; DIF= 26.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 16; FIX 4; C= 0000000; BIN=GOOD; MFRU=44.1; MFRD=47.3; LEAK RATE= 1.9  
ACT= 137.3; REL= 105.3; DIF= 32.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:23:04.03 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:23:29.05 OPER DOOR STILL DID NOT CLOSE 1

SER 17; FIX 1; C= 0000000; BIN=GOOD; MFRU=43.7; MFRD=46.1; LEAK RATE= 1.7  
ACT= 131.0; REL= 95.9; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 18; FIX 2; C= 0000000; BIN=GOOD; MFRU=43.7; MFRD=46.1; LEAK RATE= 1.7  
ACT= 136.8; REL= 106.1; DIF= 30.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 19; FIX 3; C= 0000000; BIN=GOOD; MFRU=43.7; MFRD=46.1; LEAK RATE= 1.7  
ACT= 136.8; REL= 107.7; DIF= 29.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

20 SER 20; FIX 4; C= 0000000; BIN=GOOD; MFRU=43.7; MFRD=46.1; LEAK RATE= 1.7  
ACT= 133.3; REL= 98.2; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 21; FIX 1; C= 0000000; BIN=GOOD; MFRU=44.1; MFRD=47.2; LEAK RATE= 1.9  
ACT= 139.0; REL= 108.9; DIF= 30.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 22; FIX 2; C= 0000000; BIN=GOOD; MFRU=44.1; MFRD=47.2; LEAK RATE= 1.9  
ACT= 128.5; REL= 98.4; DIF= 30.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 24; FIX 4; C= 0000000; BIN=8000 ; MFRU=44.1; MFRD=47.2; LEAK RATE= 1.9  
ACT= 141.3; REL= 106.5; DIF= 34.8 PSI; ACTCR= 200.0mm; RELCR= 200.0

SER 25; FIX 1; C= 0000000; BIN=8000 ; MFRU=44.4; MFRD=48.5; LEAK RATE= 2.2  
ACT= 120.7; REL= 85.3; DIF= 35.4 PSI; ACTCR= 200.0mm; RELCR= 200.0

SER 26; FIX 2; C= 0000000; BIN=8000 ; MFRU=44.4; MFRD=48.5; LEAK RATE= 2.2  
ACT= 133.4; REL= 98.1; DIF= 35.4 PSI; ACTCR= 200.0mm; RELCR= 200.0

SER 27; FIX 3; C= 0000000; BIN=8000 ; MFRU=44.4; MFRD=48.5; LEAK RATE= 2.2  
ACT= 131.7; REL= 97.0; DIF= 34.6 PSI; ACTCR= 200.0mm; RELCR= 200.0

SER 28; FIX 4; C= 0000000; BIN=8000 ; MFRU=44.4; MFRD=48.5; LEAK RATE= 2.2  
ACT= 127.5; REL= 97.0; DIF= 30.5 PSI; ACTCR= 200.0mm; RELCR= 200.0

SER 29; FIX 1; C= 0000000; BIN=8000 ; MFRU=44.2; MFRD=47.9; LEAK RATE= 2.2  
ACT= 132.1; REL= 99.4; DIF= 32.5 PSI; ACTCR= 200.0mm; RELCR= 200.0

30 SER 30; FIX 2; C= 0000000; BIN=8000 ; MFRU=44.2; MFRD=47.9; LEAK RATE= 2.2  
ACT= 128.3; REL= 100.9; DIF= 27.4 PSI; ACTCR= 200.0mm; RELCR= 200.0

SER 31; FIX 3; C= 0000000; BIN=8000 ; MFRU=44.2; MFRD=47.9; LEAK RATE= 2.2  
ACT= 128.9; REL= 91.0; DIF= 35.9 PSI; ACTCR= 200.0mm; RELCR= 200.0

SER 32; FIX 4; C= 0000000; BIN=8000 ; MFRU=44.2; MFRD=47.9; LEAK RATE= 2.2  
ACT= 132.4; REL= 95.5; DIF= 36.8 PSI; ACTCR= 200.0mm; RELCR= 200.0

17-SEP-1992 10:25:28.45 OPER DOOR DID NOT CLOSE 1

SER 33; FIX 1; C= 0000000; BIN=8000 ; MFRU=44.2; MFRD=48.6; LEAK RATE= 1.9  
ACT= 134.5; REL= 105.7; DIF= 30.9 PSI; ACTCR= 200.0mm; RELCR= 200.0

SER 34; FIX 2; C= 0000000; BIN=8000 ; MFRU=44.2; MFRD=48.6; LEAK RATE= 1.9  
ACT= 130.5; REL= 99.5; DIF= 31.1 PSI; ACTCR= 200.0mm; RELCR= 200.0



SER 36; FIX 4; C= 0000000; BIN=GOOD; MRAU=44.2; MRSD=46.4; LEAK RATE= 1.9  
ACT= 127.7; REL= 88.8; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 37; FIX 1; C= 0000000; BIN=GOOD; MRAU=44.1; MRSD=46.4; LEAK RATE= 2.0  
ACT= 135.6; REL= 104.5; DIF= 31.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 38; FIX 2; C= 0000000; BIN=GOOD; MRAU=44.1; MRSD=46.4; LEAK RATE= 2.0  
ACT= 131.7; REL= 98.1; DIF= 33.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 39; FIX 3; C= 0000000; BIN=GOOD; MRAU=44.1; MRSD=46.4; LEAK RATE= 2.0  
ACT= 139.6; REL= 105.9; DIF= 33.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

40 SER 40; FIX 4; C= 0000000; BIN=GOOD; MRAU=44.1; MRSD=46.4; LEAK RATE= 2.0  
ACT= 133.5; REL= 101.9; DIF= 31.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:26:35.20 OPER DOOR DID NOT CLOSE 1

SER 41; FIX 1; C= 0000000; BIN=GOOD; MRAU=44.1; MRSD=47.7; LEAK RATE= 1.9  
ACT= 124.9; REL= 94.7; DIF= 30.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 42; FIX 2; C= 0000000; BIN=GOOD; MRAU=44.1; MRSD=47.7; LEAK RATE= 1.9  
ACT= 128.4; REL= 103.4; DIF= 24.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 43; FIX 3; C= 0000000; BIN=GOOD; MRAU=44.1; MRSD=47.7; LEAK RATE= 1.9  
ACT= 125.5; REL= 93.4; DIF= 32.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 44; FIX 4; C= 0000000; BIN=GOOD; MRAU=44.1; MRSD=47.7; LEAK RATE= 1.9  
ACT= 131.9; REL= 100.9; DIF= 31.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:27:06.17 OPER DOOR DID NOT CLOSE 1

SER 45; FIX 1; C= 0000000; BIN=GOOD; MRAU=44.2; MRSD=47.5; LEAK RATE= 2.0

TI-NHTSA 006960

SER 40; FIX 4; C= 0000000; BIN=GOOD; MRRU=44.2; MRRD=47.3; LEAK RATE= 2.0  
ACT= 126.3; REL= 95.8; DIF= 32.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 47; FIX 3; C= 0000000; BIN=GOOD; MRRU=44.2; MRRD=47.5; LEAK RATE= 2.0  
ACT= 129.2; REL= 96.3; DIF= 32.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 48; FIX 4; C= 0000000; BIN=GOOD; MRRU=44.2; MRRD=47.5; LEAK RATE= 2.0  
ACT= 134.0; REL= 100.1; DIF= 33.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:27:52.52 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:28:12.52 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 10:28:26.15 TEST CYCLE TIMEOUT 1

SER 49; FIX 1; C= 0000000; BIN=GOOD; MRRU=44.3; MRRD=48.1; LEAK RATE= 1.9  
ACT= 131.5; REL= 101.4; DIF= 30.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

9 SER 50; FIX 2; C= 0000000; BIN=GOOD; MRRU=44.3; MRRD=48.1; LEAK RATE= 1.9  
ACT= 133.2; REL= 98.8; DIF= 34.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 51; FIX 3; C= 0000000; BIN=GOOD; MRRU=44.3; MRRD=48.1; LEAK RATE= 1.9  
ACT= 125.9; REL= 87.1; DIF= 38.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 52; FIX 4; C= 0000000; BIN=GOOD; MRRU=44.3; MRRD=48.1; LEAK RATE= 1.9  
ACT= 127.2; REL= 93.2; DIF= 32.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:31:52.41 OPER DOOR DID NOT CLOSE 1

SER 53; FIX 1; C= 0000000; BIN=GOOD; MRRU=44.0; MRRD=47.7; LEAK RATE= 1.9  
ACT= 125.3; REL= 92.4; DIF= 30.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 54; FIX 2; C= 0000000; BIN=GOOD; MRRU=44.0; MRRD=47.7; LEAK RATE= 1.9  
ACT= 131.2; REL= 93.5; DIF= 37.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 55; FIX 3; C= 0000000; BIN=GOOD; MRRU=44.0; MRRD=47.7; LEAK RATE= 1.9  
ACT= 122.3; REL= 85.6; DIF= 36.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 56; FIX 4; C= 0000000; BIN=GOOD; MRRU=44.0; MRRD=47.7; LEAK RATE= 1.9  
ACT= 133.5; REL= 98.4; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

REF: 128.0; REL: 107.9; DIF: 30.1 PSI; ACTOR: 200.0ms; RELCR: 200.0

SER 58; FIX 2; C: 0000000; BIN=GOOD; MRRU=44.2; MRRD=47.5; LEAK RATE= 1.9  
ACT= 128.0; REL= 107.9; DIF= 30.1 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 59; FIX 3; C: 0000000; BIN=GOOD; MRRU=44.2; MRRD=47.5; LEAK RATE= 1.9  
ACT= 120.8; REL= 87.1; DIF= 33.6 PSI; ACTOR= 200.0ms; RELCR= 200.0

60 SER 60; FIX 4; C: 0000000; BIN=GOOD; MRRU=44.2; MRRD=47.5; LEAK RATE= 1.9  
ACT= 122.5; REL= 88.1; DIF= 34.4 PSI; ACTOR= 200.0ms; RELCR= 200.0

17-APR-1992 10:32:03.72 OPER DOOR DID NOT CLOSE 1

SER 61; FIX 1; C: 0000000; BIN=GOOD; MRRU=44.3; MRRD=48.0; LEAK RATE= 2.1  
ACT= 128.1; REL= 94.5; DIF= 33.6 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 62; FIX 2; C: 0000000; BIN=GOOD; MRRU=44.3; MRRD=48.0; LEAK RATE= 2.1  
ACT= 135.3; REL= 101.8; DIF= 33.4 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 63; FIX 3; C: 0000000; BIN=GOOD; MRRU=44.3; MRRD=48.0; LEAK RATE= 2.1  
ACT= 137.1; REL= 104.8; DIF= 32.4 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 64; FIX 4; C: 0000000; BIN=GOOD; MRRU=44.3; MRRD=48.0; LEAK RATE= 2.1  
ACT= 135.8; REL= 103.3; DIF= 32.5 PSI; ACTOR= 200.0ms; RELCR= 200.0

17-APR-1992 10:33:00.40 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:33:20.40 OPER DOOR STILL DID NOT CLOSE 1

SER 65; FIX 1; C: 0000000; BIN=GOOD; MRRU=43.7; MRRD=47.2; LEAK RATE= 1.7  
ACT= 136.9; REL= 104.6; DIF= 32.3 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 66; FIX 2; C: 0000000; BIN=GOOD; MRRU=43.7; MRRD=47.2; LEAK RATE= 1.7  
ACT= 129.3; REL= 90.9; DIF= 38.4 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 67; FIX 3; C: 0000000; BIN=GOOD; MRRU=43.7; MRRD=47.2; LEAK RATE= 1.7  
ACT= 140.6; REL= 104.6; DIF= 36.0 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 68; FIX 4; C: 0000000; BIN=GOOD; MRRU=43.7; MRRD=47.2; LEAK RATE= 1.7  
ACT= 135.5; REL= 104.6; DIF= 30.9 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 69; FIX 1; C= 0000000; BIN=8000; MRU=44.2; MRD=47.8; LEAK RATE= 1.9  
ACT= 131.3; REL= 93.6; DIF= 37.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

70 SER 70; FIX 2; C= 0000000; BIN=8000; MRU=44.2; MRD=47.8; LEAK RATE= 1.9  
ACT= 132.5; REL= 94.5; DIF= 38.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 71; FIX 3; C= 0000000; BIN=8000; MRU=44.2; MRD=47.8; LEAK RATE= 1.9  
ACT= 134.0; REL= 102.1; DIF= 32.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 72; FIX 4; C= 0000000; BIN=8000; MRU=44.2; MRD=47.8; LEAK RATE= 1.9  
ACT= 127.4; REL= 92.4; DIF= 35.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:34:29.53 OPER DOOR DID NOT CLOSE 1

SER 73; FIX 1; C= 0000000; BIN=8000; MRU=44.1; MRD=47.5; LEAK RATE= 2.0  
ACT= 130.4; REL= 100.1; DIF= 30.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 74; FIX 2; C= 0000000; BIN=8000; MRU=44.1; MRD=47.5; LEAK RATE= 2.0  
ACT= 122.0; REL= 94.1; DIF= 27.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 75; FIX 3; C= 0000000; BIN=8000; MRU=44.1; MRD=47.5; LEAK RATE= 2.0  
ACT= 122.7; REL= 89.4; DIF= 33.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 76; FIX 4; C= 0000000; BIN=8000; MRU=44.1; MRD=47.5; LEAK RATE= 2.0  
ACT= 125.9; REL= 89.4; DIF= 36.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 77; FIX 1; C= 0000000; BIN=8000; MRU=44.5; MRD=47.3; LEAK RATE= 2.0  
ACT= 127.0; REL= 91.8; DIF= 35.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 78; FIX 2; C= 0000000; BIN=8000; MRU=44.8; MRD=47.3; LEAK RATE= 2.0  
ACT= 128.0; REL= 91.8; DIF= 34.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 79; FIX 3; C= 0000000; BIN=8000; MRU=44.8; MRD=47.3; LEAK RATE= 2.0  
ACT= 129.3; REL= 100.7; DIF= 28.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

80 SER 80; FIX 4; C= 0000000; BIN=8000; MRU=44.8; MRD=47.3; LEAK RATE= 2.0  
ACT= 138.6; REL= 107.5; DIF= 31.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

TI-NHTSA 000963

SER 81; FIX 1; C: 0000000; BIN=GOOD; MRRL=44.3; MRRL=46.8; LEAK RATE= 2.0  
ACT= 127.3; REL= 93.3; DIF= 34.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 82; FIX 2; C: 0000000; BIN=GOOD; MRRL=44.3; MRRL=46.8; LEAK RATE= 2.0  
ACT= 125.7; REL= 89.8; DIF= 31.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 83; FIX 3; C: 0000000; BIN=GOOD; MRRL=44.3; MRRL=46.8; LEAK RATE= 2.0  
ACT= 129.2; REL= 94.5; DIF= 34.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 84; FIX 4; C: 0000000; BIN=GOOD; MRRL=44.3; MRRL=46.8; LEAK RATE= 2.0  
ACT= 131.8; REL= 97.8; DIF= 32.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:35:46.00 OPEN DOOR DID NOT CLOSE 1

17-APR-1992 10:36:06.00 OPEN DOOR STILL DID NOT CLOSE 1

17-APR-1992 10:36:22.20 TOOL CYCLE TIMEOUT 1

SER 85; FIX 1; C: 0000000; BIN=GOOD; MRRL=43.9; MRRL=47.8; LEAK RATE= 2.1  
ACT= 131.6; REL= 96.7; DIF= 34.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 86; FIX 2; C: 0000000; BIN=GOOD; MRRL=43.9; MRRL=47.8; LEAK RATE= 2.1  
ACT= 117.2; REL= 83.0; DIF= 34.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 87; FIX 3; C: 0000000; BIN=GOOD; MRRL=43.7; MRRL=47.8; LEAK RATE= 2.1  
ACT= 130.4; REL= 99.4; DIF= 31.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 88; FIX 4; C: 0000000; BIN=GOOD; MRRL=43.9; MRRL=47.8; LEAK RATE= 2.1  
ACT= 119.8; REL= 90.8; DIF= 28.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:39:56.83 OPEN DOOR DID NOT CLOSE 1

SER 89; FIX 1; C: 0000000; BIN=GOOD; MRRL=44.2; MRRL=47.8; LEAK RATE= 1.9  
ACT= 128.0; REL= 96.4; DIF= 31.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

90 SER 90; FIX 2; C: 0000000; BIN=GOOD; MRRL=44.2; MRRL=47.8; LEAK RATE= 1.9  
ACT= 123.9; REL= 99.9; DIF= 34.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 91; FIX 3; C: 0000000; BIN=GOOD; MRRL=44.2; MRRL=47.8; LEAK RATE= 1.9  
ACT= 126.1; REL= 97.7; DIF= 32.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

ACT= 126.1; REL= 74.0; DIF= 33.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:40:40.32 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:41:00.32 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 10:41:17.61 TDM CYCLE TIMEOUT 1

SER 93; FIX 1; C= 0000000; BIN=8000; NFRU=44.4; NFRD=47.8; LEAK RATE= 2.0  
ACT= 132.5; REL= 97.4; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 94; FIX 2; C= 0000000; BIN=8000; NFRU=44.4; NFRD=47.8; LEAK RATE= 2.0  
ACT= 129.3; REL= 94.9; DIF= 34.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 95; FIX 3; C= 0000000; BIN=8000; NFRU=44.4; NFRD=47.8; LEAK RATE= 2.0  
ACT= 138.2; REL= 103.8; DIF= 34.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 96; FIX 4; C= 0000000; BIN=8000; NFRU=44.4; NFRD=47.8; LEAK RATE= 2.0  
ACT= 125.4; REL= 90.2; DIF= 35.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:44:39.32 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:44:59.32 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 10:45:17.91 TDM CYCLE TIMEOUT 1

SER 97; FIX 1; C= 0000000; BIN=8000; NFRU=43.8; NFRD=47.4; LEAK RATE= 1.9  
ACT= 132.4; REL= 76.9; DIF= 35.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 98; FIX 2; C= 0000000; BIN=8000; NFRU=43.8; NFRD=47.4; LEAK RATE= 1.9  
ACT= 132.7; REL= 102.2; DIF= 30.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 99; FIX 3; C= 0000000; BIN=8000; NFRU=43.6; NFRD=47.4; LEAK RATE= 1.9  
ACT= 123.6; REL= 87.2; DIF= 34.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

100 SER 100; FIX 4; C= 0000000; BIN=8000; NFRU=43.6; NFRD=47.4; LEAK RATE= 1.9  
ACT= 124.0; REL= 99.7; DIF= 35.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

TI-NHTSA 008965

ACT= 130.4; REL= 95.9; DIF= 34.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 102; FIX 2; C= 0000000; BIN=8000; NRRL=44.1; NRRL=47.8; LEAK RATE= 1.9  
ACT= 132.6; REL= 90.2; DIF= 42.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 103; FIX 3; C= 0000000; BIN=8000; NRRL=44.1; NRRL=47.8; LEAK RATE= 1.9  
ACT= 130.2; REL= 103.8; DIF= 34.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 104; FIX 4; C= 0000000; BIN=8000; NRRL=44.1; NRRL=47.8; LEAK RATE= 1.9  
ACT= 125.9; REL= 91.4; DIF= 34.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 105; FIX 1; C= 0000000; BIN=8000; NRRL=44.1; NRRL=47.2; LEAK RATE= 1.8  
ACT= 140.4; REL= 113.1; DIF= 27.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 106; FIX 2; C= 0000000; BIN=8000; NRRL=44.1; NRRL=47.2; LEAK RATE= 1.8  
ACT= 133.8; REL= 100.6; DIF= 33.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 107; FIX 3; C= 0000000; BIN=8000; NRRL=44.1; NRRL=47.2; LEAK RATE= 1.8  
ACT= 132.4; REL= 94.4; DIF= 38.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 108; FIX 4; C= 0000000; BIN=8000; NRRL=44.1; NRRL=47.2; LEAK RATE= 1.8  
ACT= 129.1; REL= 105.9; DIF= 23.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:49:40.16 OPER DOOR DID NOT CLOSE 1

SER 109; FIX 1; C= 0000000; BIN=8000; NRRL=44.4; NRRL=47.9; LEAK RATE= 2.0  
ACT= 127.6; REL= 100.8; DIF= 26.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

110 SER 110; FIX 2; C= 0000000; BIN=8000; NRRL=44.4; NRRL=47.9; LEAK RATE= 2.0  
ACT= 137.5; REL= 104.9; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 111; FIX 3; C= 0000000; BIN=8000; NRRL=44.4; NRRL=47.9; LEAK RATE= 2.0  
ACT= 131.3; REL= 100.8; DIF= 30.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 112; FIX 4; C= 0000000; BIN=8000; NRRL=44.4; NRRL=47.9; LEAK RATE= 2.0  
ACT= 129.0; REL= 97.0; DIF= 32.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 113; FIX 1; C= 0000000; BIN=8000; NRRL=44.2; NRRL=47.2; LEAK RATE= 2.0  
ACT= 125.3; REL= 92.2; DIF= 33.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 114; FIX 2; C= 0000000; BIN=8000; NRRL=44.2; NRRL=47.2; LEAK RATE= 2.0  
ACT= 133.2; REL= 102.1; DIF= 31.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

ACT= 130.9; REL= 98.2; DIF= 22.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 116; FIX 4; C= 0000000; BIN=GOOD; NFRU=44.2; NFRD=47.2; LEAK RATE= 2.0  
ACT= 124.3; REL= 93.6; DIF= 30.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 117; FIX 1; C= 0000000; BIN=GOOD; NFRU=44.2; NFRD=47.9; LEAK RATE= 2.1  
ACT= 132.4; REL= 104.7; DIF= 27.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 118; FIX 2; C= 0000000; BIN=GOOD; NFRU=44.2; NFRD=47.9; LEAK RATE= 2.1  
ACT= 123.1; REL= 89.9; DIF= 33.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 119; FIX 5; C= 0000000; BIN=GOOD; NFRU=44.2; NFRD=47.9; LEAK RATE= 2.1  
ACT= 119.8; REL= 88.7; DIF= 31.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

120 SER 120; FIX 4; C= 0000000; BIN=GOOD; NFRU=44.2; NFRD=47.9; LEAK RATE= 2.1  
ACT= 132.4; REL= 98.2; DIF= 34.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 121; FIX 1; C= 0000000; BIN=GOOD; NFRU=44.1; NFRD=47.8; LEAK RATE= 2.0  
ACT= 135.2; REL= 107.8; DIF= 27.4 PSI; ACTCR= 200.0ms; RELCR= 122.3

SER 122; FIX 2; C= 0000000; BIN=GOOD; NFRU=44.1; NFRD=47.8; LEAK RATE= 2.0  
ACT= 130.6; REL= 93.8; DIF= 36.7 PSI; ACTCR= 200.0ms; RELCR= 15.0

SER 123; FIX 5; C= 0000000; BIN=GOOD; NFRU=44.1; NFRD=47.8; LEAK RATE= 2.0  
ACT= 128.2; REL= 96.0; DIF= 32.2 PSI; ACTCR= 200.0ms; RELCR= 38.4

21 SER 124; FIX 4; C= 0020042; BIN=CONT; NFRU=44.1; NFRD=47.8; LEAK RATE= 2.0  
ACT= 177.8; REL= 92.6; DIF= 89.2 PSI; ACTCR= 200.0ms; RELCR= 0.6

17-APR-1992 10:51:29.38 OPER DOOR DID NOT CLOSE :

SER 125; FIX 1; C= 0000000; BIN=GOOD; NFRU=44.2; NFRD=47.3; LEAK RATE= 2.4  
ACT= 128.0; REL= 96.1; DIF= 32.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 126; FIX 2; C= 0000000; BIN=GOOD; NFRU=44.2; NFRD=47.3; LEAK RATE= 2.4  
ACT= 123.4; REL= 89.6; DIF= 33.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 127; FIX 3; C= 0000000; BIN=GOOD; NFRU=44.2; NFRD=47.3; LEAK RATE= 2.4  
ACT= 125.4; REL= 94.1; DIF= 31.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 128; FIX 4; C= 0000000; BIN=GOOD; NFRU=44.2; NFRD=47.3; LEAK RATE= 2.4  
ACT= 131.2; REL= 94.1; DIF= 37.0 PSI; ACTCR= 200.0ms; RELCR= 200.0



17-APR-1992 10:52:23.56 OPER DOOR STILL DID NOT CLOSE 1

SER 129; FIX 1; C= 0000000; BIN=8000; MFRU=44.1; MFRD=47.6; LEAK RATE= 2.2  
ACT= 124.4; REL= 107.6; DIF= 24.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

130 SER 130; FIX 2; C= 0000000; BIN=8000; MFRU=44.1; MFRD=47.6; LEAK RATE= 2.2  
ACT= 125.0; REL= 100.9; DIF= 31.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 131; FIX 3; C= 0000000; BIN=8000; MFRU=44.1; MFRD=47.6; LEAK RATE= 2.2  
ACT= 129.5; REL= 77.1; DIF= 32.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 132; FIX 4; C= 0000000; BIN=8000; MFRU=44.1; MFRD=47.6; LEAK RATE= 2.2  
ACT= 128.2; REL= 94.6; DIF= 33.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

✓

17-APR-1992 10:53:00.20 OPER DOOR DID NOT CLOSE 1

17-APR-1992 10:53:20.20 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 10:53:37.62 TOOL CYCLE TIMEOUT 1

SER 133; FIX 1; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.1; LEAK RATE= 1.8  
ACT= 137.2; REL= 106.1; DIF= 31.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 134; FIX 2; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.1; LEAK RATE= 1.8  
ACT= 128.7; REL= 76.9; DIF= 31.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 135; FIX 3; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.1; LEAK RATE= 1.8  
ACT= 126.1; REL= 99.5; DIF= 26.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 136; FIX 4; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.1; LEAK RATE= 1.8  
ACT= 127.0; REL= 91.6; DIF= 35.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:54:52.26 OPER DOOR DID NOT CLOSE 1

TI-NHTSA 006968

140 SER 138; FIX 2; C= 0000000; BIN=GOOD; MFRU=44.2; MFRD=47.2; LEAK RATE= 2.0  
ACT= 130.7; REL= 97.1; DIF= 33.6 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 139; FIX 3; C= 0000000; BIN=GOOD; MFRU=44.2; MFRD=47.2; LEAK RATE= 2.0  
ACT= 132.8; REL= 103.5; DIF= 29.3 PSI; ACTOR= 200.0ms; RELCR= 200.0

140 SER 140; FIX 4; C= 0000000; BIN=GOOD; MFRU=44.2; MFRD=47.2; LEAK RATE= 2.0  
ACT= 129.9; REL= 93.5; DIF= 34.3 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 141; FIX 1; C= 0000000; BIN=GOOD; MFRU=44.4; MFRD=47.5; LEAK RATE= 2.0  
ACT= 127.7; REL= 96.8; DIF= 31.1 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 142; FIX 2; C= 0000000; BIN=GOOD; MFRU=44.4; MFRD=47.5; LEAK RATE= 2.0  
ACT= 118.7; REL= 87.2; DIF= 31.5 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 143; FIX 3; C= 0000000; BIN=GOOD; MFRU=44.4; MFRD=47.5; LEAK RATE= 2.0  
ACT= 124.4; REL= 88.5; DIF= 35.9 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 144; FIX 4; C= 0000000; BIN=GOOD; MFRU=44.4; MFRD=47.5; LEAK RATE= 2.0  
ACT= 131.7; REL= 104.6; DIF= 27.1 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 145; FIX 1; C= 0000000; BIN=GOOD; MFRU=43.6; MFRD=47.1; LEAK RATE= 2.2  
ACT= 108.3; REL= 108.5; DIF= 29.4 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 146; FIX 2; C= 0000000; BIN=GOOD; MFRU=43.8; MFRD=47.1; LEAK RATE= 2.2  
ACT= 125.6; REL= 95.8; DIF= 30.8 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 147; FIX 3; C= 0000000; BIN=GOOD; MFRU=43.8; MFRD=47.1; LEAK RATE= 2.2  
ACT= 131.8; REL= 97.3; DIF= 34.2 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 148; FIX 4; C= 0000000; BIN=GOOD; MFRU=43.8; MFRD=47.1; LEAK RATE= 2.2  
ACT= 128.0; REL= 92.4; DIF= 35.6 PSI; ACTOR= 200.0ms; RELCR= 200.0

SER 149; FIX 1; C= 0000000; BIN=8000; MRRL=44.2; MRSD=47.1; LEAK RATE= 2.2  
ACT= 132.2; REL= 102.1; DIF= 30.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

150 SER 150; FIX 2; C= 0000000; BIN=8000; MRRL=44.2; MRSD=47.1; LEAK RATE= 2.2  
ACT= 131.0; REL= 98.3; DIF= 32.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 151; FIX 3; C= 0020012; BIN=8000; MRRL=44.2; MRSD=47.1; LEAK RATE= 2.2  
ACT= 178.0; REL= 140.7; DIF= 37.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 152; FIX 4; C= 0000000; BIN=8000; MRRL=44.2; MRSD=47.1; LEAK RATE= 2.2  
ACT= 139.2; REL= 97.1; DIF= 42.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 153; FIX 1; C= 0000000; BIN=8000; MRRL=44.4; MRSD=47.5; LEAK RATE= 1.9  
ACT= 129.4; REL= 95.8; DIF= 33.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 154; FIX 2; C= 0000000; BIN=8000; MRRL=44.4; MRSD=47.5; LEAK RATE= 1.9  
ACT= 131.3; REL= 99.9; DIF= 31.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 155; FIX 3; C= 0000000; BIN=8000; MRRL=44.4; MRSD=47.5; LEAK RATE= 1.9  
ACT= 132.5; REL= 99.9; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 156; FIX 4; C= 0000000; BIN=8000; MRRL=44.4; MRSD=47.5; LEAK RATE= 1.9  
ACT= 130.1; REL= 102.3; DIF= 33.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 157; FIX 1; C= 0000000; BIN=8000; MRRL=44.5; MRSD=47.6; LEAK RATE= 1.9  
ACT= 130.4; REL= 96.6; DIF= 33.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 158; FIX 2; C= 0000000; BIN=8000; MRRL=44.5; MRSD=47.6; LEAK RATE= 1.9  
ACT= 134.1; REL= 97.8; DIF= 36.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 159; FIX 3; C= 0000000; BIN=8000; MRRL=44.5; MRSD=47.6; LEAK RATE= 1.9  
ACT= 135.0; REL= 97.8; DIF= 38.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

160 SER 160; FIX 4; C= 0000000; BIN=8000; MRRL=44.5; MRSD=47.6; LEAK RATE= 1.9  
ACT= 130.4; REL= 98.8; DIF= 38.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 10:57:25.69 OPER ERROR GIL NOT CLOSED 1

SER 161; FIX 1; C= 0000000; BIN=8000; MRRL=45.9; MRSD=47.6; LEAK RATE= 1.9  
ACT= 133.2; REL= 99.4; DIF= 33.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 162; FIX 2; C= 0000000; BIN=8000; MRRL=45.9; MRSD=47.8; LEAK RATE= 1.9  
ACT= 131.0; REL= 97.0; DIF= 34.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 163; FIX 3; C= 0000000; BIN=8000; MRRL=45.9; MRSD=47.6; LEAK RATE= 1.9

ACT= 132.2; REL= 95.7; DIF= 37.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 165; FIX 1; C= 0000000; BIN=GOOD; MRAL=44.1; MRRO=47.7; LEAK RATE= 2.0  
ACT= 137.2; REL= 103.5; DIF= 34.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 166; FIX 2; C= 0000000; BIN=GOOD; MRAL=44.1; MRRO=47.7; LEAK RATE= 2.0  
ACT= 129.3; REL= 98.3; DIF= 31.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 167; FIX 3; C= 0000000; BIN=GOOD; MRAL=44.1; MRRO=47.7; LEAK RATE= 2.0  
ACT= 126.7; REL= 93.2; DIF= 33.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 168; FIX 4; C= 0000000; BIN=GOOD; MRAL=44.1; MRRO=47.7; LEAK RATE= 2.0  
ACT= 125.3; REL= 86.7; DIF= 38.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 19:58:22.59 OPER DOOR DID NOT CLOSE 1

17-APR-1992 19:58:42.59 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 19:59:00.61 TOOL CYCLE TIMEOUT 1

SER 169; FIX 1; C= 0000000; BIN=GOOD; MRAL=44.2; MRRO=47.7; LEAK RATE= 2.1  
ACT= 128.5; REL= 96.1; DIF= 30.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

170 SER 170; FIX 2; C= 0000000; BIN=GOOD; MRAL=44.2; MRRO=47.7; LEAK RATE= 2.1  
ACT= 126.5; REL= 90.8; DIF= 35.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 171; FIX 3; C= 0000000; BIN=GOOD; MRAL=44.2; MRRO=47.7; LEAK RATE= 2.1  
ACT= 127.1; REL= 94.4; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 172; FIX 4; C= 0000000; BIN=GOOD; MRAL=44.2; MRRO=47.7; LEAK RATE= 2.1  
ACT= 123.0; REL= 89.7; DIF= 26.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:00:30.06 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:01:13.08 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 11:01:29.19 TOOL CYCLE TIMEOUT 1

SER 173; FIX 1; C= 0000000; BIN=GOOD; MRAL=44.0; MRRO=47.0; LEAK RATE= 2.2  
ACT= 154.0; REL= 100.5; DIF= 33.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 174; FIX 2; C= 0000000; BIN=GOOD; MRAL=44.0; MRRO=47.0; LEAK RATE= 2.2  
ACT= 142.9; REL= 112.3; DIF= 39.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 175; FIX 3; C= 0000000; BIN=GOOD; MRAL=44.0; MRRO=47.0; LEAK RATE= 2.2

ACT= 134.5; REL= 100.3; DIF= 34.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:03:27.58 OPER DOOR DID NOT CLOSE 1

SER 177; FIX 1; C= 0000000; BIN=8000; MRSL=43.7; MRSD=47.4; LEAK RATE= 1.9  
ACT= 132.2; REL= 101.0; DIF= 31.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 178; FIX 2; C= 0000000; BIN=8000; MRSL=43.7; MRSD=47.4; LEAK RATE= 1.9  
ACT= 128.0; REL= 99.4; DIF= 29.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 179; FIX 3; C= 0000000; BIN=8000; MRSL=43.7; MRSD=47.4; LEAK RATE= 1.9  
ACT= 121.7; REL= 97.2; DIF= 34.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

180 SER 180; FIX 4; C= 0000000; BIN=8000; MRSL=43.7; MRSD=47.4; LEAK RATE= 1.9  
ACT= 126.3; REL= 92.3; DIF= 33.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:03:52.53 OPER DOOR DID NOT CLOSE 1

SER 181; FIX 1; C= 0000000; BIN=8000; MRSL=44.3; MRSD=47.5; LEAK RATE= 2.0  
ACT= 131.7; REL= 97.7; DIF= 34.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 182; FIX 2; C= 0000000; BIN=8000; MRSL=44.3; MRSD=47.5; LEAK RATE= 2.0  
ACT= 128.5; REL= 98.4; DIF= 32.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 183; FIX 3; C= 0000000; BIN=8000; MRSL=44.3; MRSD=47.5; LEAK RATE= 2.0  
ACT= 135.1; REL= 101.5; DIF= 31.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 184; FIX 4; C= 0000000; BIN=8000; MRSL=44.3; MRSD=47.5; LEAK RATE= 2.0  
ACT= 131.7; REL= 101.1; DIF= 30.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:04:18.31 OPER DOOR DID NOT CLOSE 1

TI-NHTSA 006972

PRF= 44.3; REL= 70.7; DIF= 31.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 186; FIX 2; C= 0000000; BIN=8000; NRRL=44.2; NRRL=47.6; LEAK RATE= 2.0  
ACT= 133.3; REL= 104.0; DIF= 31.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 187; FIX 3; C= 0000000; BIN=8000; NRRL=44.2; NRRL=47.6; LEAK RATE= 2.0  
ACT= 129.7; REL= 97.6; DIF= 32.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 188; FIX 4; C= 0000000; BIN=8000; NRRL=44.2; NRRL=47.6; LEAK RATE= 2.0  
ACT= 132.6; REL= 102.6; DIF= 30.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:04:44.23 OPER DOOR DID NOT CLOSE 1

SER 189; FIX 1; C= 0000000; BIN=8000; NRRL=44.5; NRRL=48.5; LEAK RATE= 1.8  
ACT= 135.8; REL= 106.5; DIF= 29.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

190 SER 190; FIX 2; C= 0000000; BIN=8000; NRRL=44.5; NRRL=48.5; LEAK RATE= 1.8  
ACT= 125.0; REL= 90.4; DIF= 34.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 191; FIX 3; C= 0000000; BIN=8000; NRRL=44.5; NRRL=48.5; LEAK RATE= 1.8  
ACT= 128.7; REL= 95.2; DIF= 33.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 192; FIX 4; C= 0000000; BIN=8000; NRRL=44.5; NRRL=48.5; LEAK RATE= 1.8  
ACT= 132.4; REL= 100.0; DIF= 32.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 193; FIX 1; C= 0000000; BIN=8000; NRRL=44.3; NRRL=47.7; LEAK RATE= 2.0  
ACT= 135.0; REL= 102.9; DIF= 32.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 194; FIX 2; C= 0000000; BIN=8000; NRRL=44.3; NRRL=47.7; LEAK RATE= 2.0  
ACT= 133.3; REL= 95.0; DIF= 38.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 195; FIX 3; C= 0000000; BIN=8000; NRRL=44.3; NRRL=47.7; LEAK RATE= 2.0  
ACT= 130.6; REL= 100.4; DIF= 30.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 196; FIX 4; C= 0000000; BIN=8000; NRRL=44.3; NRRL=47.7; LEAK RATE= 2.0  
ACT= 122.1; REL= 90.6; DIF= 31.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

ACT= 133.4; REL= 102.1; DIF= 30.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 198; FIX 2; C= 000000; SIN=GOOD; MRRU=44.2; MRRD=47.5; LEAK RATE= 2.2  
ACT= 129.8; REL= 95.5; DIF= 34.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 199; FIX 3; C= 000000; SIN=GOOD; MRRU=44.2; MRRD=47.5; LEAK RATE= 2.2  
ACT= 132.1; REL= 104.1; DIF= 28.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

200 SER 200; FIX 4; C= 000000; SIN=GOOD; MRRU=44.2; MRRD=47.5; LEAK RATE= 2.2  
ACT= 132.7; REL= 101.6; DIF= 31.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 201; FIX 1; C= 000000; SIN=GOOD; MRRU=44.2; MRRD=46.2; LEAK RATE= 2.3  
ACT= 141.4; REL= 111.0; DIF= 30.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 202; FIX 2; C= 000000; SIN=GOOD; MRRU=44.2; MRRD=46.2; LEAK RATE= 2.3  
ACT= 140.5; REL= 111.0; DIF= 29.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 203; FIX 3; C= 000000; SIN=GOOD; MRRU=44.2; MRRD=46.2; LEAK RATE= 2.3  
ACT= 130.8; REL= 100.3; DIF= 30.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 204; FIX 4; C= 000000; SIN=GOOD; MRRU=44.2; MRRD=46.2; LEAK RATE= 2.3  
ACT= 138.7; REL= 104.0; DIF= 34.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:06:27.81 OPER DOOR DID NOT CLOSE 1

SER 205; FIX 1; C= 000000; SIN=GOOD; MRRU=44.2; MRRD=46.0; LEAK RATE= 2.1  
ACT= 132.4; REL= 98.3; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 206; FIX 2; C= 000000; SIN=GOOD; MRRU=44.2; MRRD=46.0; LEAK RATE= 2.1  
ACT= 131.7; REL= 102.2; DIF= 29.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 207; FIX 3; C= 000000; SIN=GOOD; MRRU=44.2; MRRD=46.0; LEAK RATE= 2.1  
ACT= 134.0; REL= 102.2; DIF= 32.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 208; FIX 4; C= 000000; SIN=GOOD; MRRU=44.2; MRRD=46.0; LEAK RATE= 2.1  
ACT= 129.9; REL= 100.9; DIF= 29.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:07:09.67 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:07:29.67 OPER DOOR STILL DID NOT CLOSE 1

SER 209; F11 1; C= 0000000; BIN=8000; MFRU=44.2; MFRD=47.4; LEAK RATE= 1.9  
ACT= 128.4; REL= 97.6; DIF= 30.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

210

SER 210; F11 2; C= 0000000; BIN=8000; MFRU=44.2; MFRD=47.4; LEAK RATE= 1.9  
ACT= 126.5; REL= 95.1; DIF= 31.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 211; F11 3; C= 0000000; BIN=8000; MFRU=44.2; MFRD=47.4; LEAK RATE= 1.9  
ACT= 132.9; REL= 96.3; DIF= 36.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 212; F11 4; C= 0000000; BIN=8000; MFRU=44.2; MFRD=47.4; LEAK RATE= 1.9  
ACT= 126.0; REL= 94.2; DIF= 31.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 213; F11 1; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.5; LEAK RATE= 2.1  
ACT= 129.8; REL= 97.4; DIF= 32.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 214; F11 2; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.5; LEAK RATE= 2.1  
ACT= 133.2; REL= 97.4; DIF= 35.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 215; F11 3; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.5; LEAK RATE= 2.1  
ACT= 136.9; REL= 104.0; DIF= 35.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 216; F11 4; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.5; LEAK RATE= 2.1  
ACT= 127.2; REL= 98.7; DIF= 35.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-AUG-1992 11:15:18.08 GEAR DOOR DID NOT CLOSE 1

SER 217; F11 1; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.6; LEAK RATE= 2.0  
ACT= 133.4; REL= 102.2; DIF= 30.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 218; F11 2; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.6; LEAK RATE= 2.0  
ACT= 125.0; REL= 92.7; DIF= 32.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 219; F11 3; C= 0000000; BIN=8000; MFRU=44.5; MFRD=47.6; LEAK RATE= 2.0  
ACT= 129.1; REL= 106.2; DIF= 31.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

220

SER 220; F11 4; C= 0000000; BIN=8000; MFRU=44.3; MFRD=47.6; LEAK RATE= 2.0  
ACT= 125.3; REL= 90.3; DIF= 35.0 PSI; ACTCR= 200.0ms; RELCR= 200.0



17-APR-1992 11:16:51.42 OPER DOOR DID NOT CLOSE 1

SEP 221; FIX 1; C=0000000; SIN=6000; MFRU=44.1; MFRD=47.7; LEAK RATE= 1.9  
ACT= 134.7; REL= 133.0; DIF= 31.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEP 222; FIX 2; C=0000000; SIN=6000; MFRU=44.1; MFRD=47.7; LEAK RATE= 1.9  
ACT= 137.5; REL= 135.8; DIF= 32.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEP 223; FIX 3; C=0000000; SIN=6000; MFRU=44.1; MFRD=47.7; LEAK RATE= 1.9  
ACT= 139.6; REL= 137.9; DIF= 32.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEP 224; FIX 4; C=0000000; SIN=6000; MFRU=44.1; MFRD=47.7; LEAK RATE= 1.9  
ACT= 133.8; REL= 131.1; DIF= 32.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:16:56.68 OPER DOOR DID NOT CLOSE 1

SEP 225; FIX 1; C=0000000; SIN=6000; MFRU=44.3; MFRD=46.7; LEAK RATE= 1.9  
ACT= 132.5; REL= 130.8; DIF= 34.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEP 226; FIX 2; C=0000000; SIN=6000; MFRU=44.3; MFRD=46.7; LEAK RATE= 1.7  
ACT= 129.9; REL= 128.2; DIF= 37.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEP 227; FIX 3; C=0000000; SIN=6000; MFRU=44.3; MFRD=46.7; LEAK RATE= 1.9  
ACT= 133.5; REL= 131.8; DIF= 28.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEP 228; FIX 4; C=0000000; SIN=6000; MFRU=44.3; MFRD=46.7; LEAK RATE= 1.9  
ACT= 135.0; REL= 133.3; DIF= 37.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:17:29.27 OPER DOOR DID NOT CLOSE 1

SEP 229; FIX 1; C=0000000; SIN=6000; MFRU=44.2; MFRD=47.5; LEAK RATE= 1.6  
ACT= 134.9; REL= 133.2; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

230 SEP 230; FIX 2; C=0000000; SIN=6000; MFRU=44.2; MFRD=47.5; LEAK RATE= 1.6  
ACT= 137.2; REL= 135.5; DIF= 33.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

TI-NHTSA 008976

ACT= 132.8; REL= 77.1; DIF= 33.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 232; FIX 4; C= 0000000; BIN=8000; MFRU=44.2; MFRD=47.5; LEAK RATE= 1.6  
ACT= 130.8; REL= 77.1; DIF= 33.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:17:52.80 OPEN DOOR DID NOT CLOSE :

SER 233; FIX 1; C= 0000000; BIN=8000; MFRU=43.5; MFRD=47.0; LEAK RATE= 1.9  
ACT= 117.2; REL= 82.4; DIF= 34.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 234; FIX 2; C= 0000000; BIN=8000; MFRU=43.5; MFRD=47.6; LEAK RATE= 1.9  
ACT= 128.9; REL= 93.6; DIF= 33.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 235; FIX 3; C= 0000000; BIN=8000; MFRU=43.5; MFRD=47.6; LEAK RATE= 1.9  
ACT= 129.3; REL= 93.0; DIF= 34.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 236; FIX 4; C= 0000000; BIN=8000; MFRU=43.8; MFRD=47.6; LEAK RATE= 1.9  
ACT= 128.7; REL= 96.3; DIF= 32.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 237; FIX 1; C= 0000000; BIN=8000; MFRU=44.1; MFRD=47.9; LEAK RATE= 1.7  
ACT= 126.6; REL= 93.8; DIF= 22.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 238; FIX 2; C= 0000000; BIN=8000; MFRU=44.1; MFRD=47.9; LEAK RATE= 1.7  
ACT= 132.4; REL= 98.7; DIF= 33.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 239; FIX 3; C= 0000000; BIN=8000; MFRU=44.1; MFRD=47.9; LEAK RATE= 1.7  
ACT= 132.4; REL= 99.9; DIF= 32.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

240 SER 240; FIX 4; C= 0000000; BIN=8000; MFRU=44.1; MFRD=47.9; LEAK RATE= 1.7  
ACT= 128.4; REL= 97.8; DIF= 34.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 241; FIX 1; C= 0000000; BIN=8000; MFRU=44.0; MFRD=47.5; LEAK RATE= 1.8  
ACT= 129.3; REL= 101.3; DIF= 26.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

TI-NHTSA 006977

SER 243; FIX 3; C= 0000000; BIN=GOOD; MFRU=44.5; MFRD=47.5; LEAK RATE= 1.8  
ACT= 124.5; REL= 73.9; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 244; FIX 4; C= 0000000; BIN=GOOD; MFRU=44.5; MFRD=47.5; LEAK RATE= 1.8  
ACT= 134.0; REL= 103.0; DIF= 35.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:19:27.85 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:19:27.88 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 11:19:46.19 TOOL CYCLE TIMEOUT 1

SER 245; FIX 1; C= 0000000; BIN=GOOD; MFRU=44.3; MFRD=47.4; LEAK RATE= 1.8  
ACT= 136.9; REL= 104.2; DIF= 34.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 246; FIX 2; C= 0000000; BIN=GOOD; MFRU=44.3; MFRD=47.4; LEAK RATE= 1.8  
ACT= 136.4; REL= 100.2; DIF= 30.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 247; FIX 3; C= 0000000; BIN=GOOD; MFRU=44.3; MFRD=47.4; LEAK RATE= 1.8  
ACT= 116.4; REL= 98.4; DIF= 30.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 248; FIX 4; C= 0000000; BIN=GOOD; MFRU=44.3; MFRD=47.4; LEAK RATE= 1.8  
ACT= 139.3; REL= 108.1; DIF= 31.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 249; FIX 1; C= 0000000; BIN=GOOD; MFRU=44.2; MFRD=47.0; LEAK RATE= 2.1  
ACT= 124.4; REL= 72.3; DIF= 34.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

250 SER 250; FIX 2; C= 0000000; BIN=GOOD; MFRU=44.2; MFRD=47.0; LEAK RATE= 2.1  
ACT= 129.3; REL= 109.2; DIF= 26.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 251; FIX 3; C= 0000000; BIN=GOOD; MFRU=44.2; MFRD=47.0; LEAK RATE= 2.1  
ACT= 131.1; REL= 102.4; DIF= 25.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 252; FIX 4; C= 0000000; BIN=GOOD; MFRU=44.2; MFRD=47.0; LEAK RATE= 2.1  
ACT= 118.2; REL= 92.3; DIF= 35.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:21:27.72 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:21:47.42 OPER DOOR STILL DID NOT CLOSE 1

SER 253; FIX 1; C= 0000000; BIN=GOOD; MFRU=44.2; MFRD=47.0; LEAK RATE= 2.0  
ACT= 131.7; REL= 100.8; DIF= 30.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 254; FIX 2; C= 0000000; BIN=GOOD; MFRU=44.2; MFRD=47.0; LEAK RATE= 2.0  
ACT= 134.4; REL= 94.2; DIF= 34.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

TI-NHTSA 005978

17-APR-1992 11:23:12.47 OPER DOOR DID NOT CLOSE 1

SEN 256; FIX 4; C=0000000; BIN=8000; MFRU=44.2; MFRD=47.0; LEAK RATE= 2.0  
ACT= 120.5; REL= 87.5; DIF= 33.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:23:12.47 OPER DOOR DID NOT CLOSE 1

17-APR-1992 11:23:14.47 OPER DOOR STILL DID NOT CLOSE 1

17-APR-1992 11:23:17.21 LOG CYCLE TIMEOUT 1

SEN 257; FIX 1; C=0000000; BIN=8000; MFRU=44.6; MFRD=47.8; LEAK RATE= 1.8  
ACT= 130.3; REL= 95.2; DIF= 35.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 258; FIX 2; C=0000000; BIN=8000; MFRU=44.6; MFRD=47.8; LEAK RATE= 1.8  
ACT= 132.4; REL= 100.1; DIF= 33.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 259; FIX 3; C=0000000; BIN=8000; MFRU=44.6; MFRD=47.8; LEAK RATE= 1.8  
ACT= 126.2; REL= 98.8; DIF= 25.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

260 SEN 260; FIX 4; C=0000000; BIN=8000; MFRU=44.6; MFRD=47.8; LEAK RATE= 1.8  
ACT= 133.2; REL= 101.2; DIF= 32.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:23:18.24 OPER DOOR DID NOT CLOSE 1

SEN 261; FIX 1; C=0000000; BIN=8000; MFRU=44.2; MFRD=48.1; LEAK RATE= 2.1  
ACT= 132.7; REL= 101.4; DIF= 32.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 262; FIX 2; C=0000000; BIN=8000; MFRU=44.2; MFRD=48.1; LEAK RATE= 2.1  
ACT= 130.2; REL= 102.8; DIF= 27.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 263; FIX 3; C=0000000; BIN=8000; MFRU=44.2; MFRD=48.1; LEAK RATE= 2.1  
ACT= 123.1; REL= 92.7; DIF= 35.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 264; FIX 4; C=0000000; BIN=8000; MFRU=44.2; MFRD=48.1; LEAK RATE= 2.1  
ACT= 128.9; REL= 101.4; DIF= 27.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 265; FIX 1; C=0000000; BIN=8000; MFRU=44.4; MFRD=47.7; LEAK RATE= 2.3  
ACT= 130.8; REL= 95.4; DIF= 35.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 266; FIX 2; C=0000000; BIN=8000; MFRU=44.4; MFRD=47.7; LEAK RATE= 2.3  
ACT= 133.3; REL= 101.0; DIF= 32.3 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 267; FIX 3; C=0000000; BIN=8000; MFRU=44.4; MFRD=47.7; LEAK RATE= 2.3  
ACT= 127.2; REL= 92.0; DIF= 34.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 268; FIX 4; C=0000000; BIN=8000; MFRU=44.4; MFRD=47.7; LEAK RATE= 2.3  
ACT= 130.8; REL= 95.9; DIF= 35.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 269; FIX 1; C=0000000; BIN=GOOD; MRRL=44.0; MRRL=47.3; LEAK RATE= 2.0  
ACT= 129.5; REL= 91.7; DIF= 35.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

270 SER 270; FIX 2; C=0000000; BIN=GOOD; MRRL=44.0; MRRL=47.3; LEAK RATE= 2.0  
ACT= 130.3; REL= 95.5; DIF= 31.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 271; FIX 3; C=0000000; BIN=GOOD; MRRL=44.0; MRRL=47.3; LEAK RATE= 2.0  
ACT= 142.8; REL= 107.8; DIF= 34.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 272; FIX 4; C=0000000; BIN=GOOD; MRRL=44.0; MRRL=47.3; LEAK RATE= 2.0  
ACT= 125.1; REL= 94.9; DIF= 31.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 273; FIX 1; C=0000000; BIN=GOOD; MRRL=44.2; MRRL=47.7; LEAK RATE= 1.5  
ACT= 123.1; REL= 91.1; DIF= 36.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 274; FIX 2; C=0000000; BIN=GOOD; MRRL=44.2; MRRL=47.7; LEAK RATE= 1.5  
ACT= 130.7; REL= 77.2; DIF= 33.5 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 275; FIX 3; C=0000000; BIN=GOOD; MRRL=44.2; MRRL=47.7; LEAK RATE= 1.5  
ACT= 134.7; REL= 104.8; DIF= 29.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 276; FIX 4; C=0000000; BIN=GOOD; MRRL=44.2; MRRL=47.7; LEAK RATE= 1.5  
ACT= 127.6; REL= 97.2; DIF= 30.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:32:05.07 OPEN DOOR DID NOT CLOSE

SER 277; FIX 1; C=0000000; BIN=GOOD; MRRL=44.4; MRRL=48.0; LEAK RATE= 1.8  
ACT= 127.2; REL= 93.6; DIF= 33.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 278; FIX 2; C=0000000; BIN=GOOD; MRRL=44.4; MRRL=48.0; LEAK RATE= 1.8  
ACT= 123.1; REL= 89.0; DIF= 34.2 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 279; FIX 3; C=0000000; BIN=GOOD; MRRL=44.4; MRRL=48.0; LEAK RATE= 1.8  
ACT= 129.9; REL= 96.1; DIF= 33.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

280 SER 280; FIX 4; C=0000000; BIN=GOOD; MRRL=44.4; MRRL=48.0; LEAK RATE= 1.8

TI-NHTSA 008980

17-APR-1992 11:32:33.64 OPEN DOOR DID NOT CLOSE 1

SEN 281; FIX 1; C= 0000000; BIN=GOOD; WPRU=44.1; WPRD=47.7; LEAK RATE= 1.9  
ACT= 130.5; REL= 100.0; DIF= 29.9 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 282; FIX 2; C= 0000000; BIN=GOOD; WPRU=44.1; WPRD=47.7; LEAK RATE= 1.5  
ACT= 123.0; REL= 93.2; DIF= 30.4 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 283; FIX 3; C= 0000000; BIN=GOOD; WPRU=44.1; WPRD=47.7; LEAK RATE= 1.7  
ACT= 121.3; REL= 90.8; DIF= 34.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 284; FIX 4; C= 0000000; BIN=GOOD; WPRU=44.1; WPRD=47.7; LEAK RATE= 1.9  
ACT= 134.2; REL= 100.0; DIF= 33.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:33:04.26 OPEN DOOR DID NOT CLOSE 1

17-APR-1992 11:33:21.28 OPEN DOOR STILL DID NOT CLOSE 1

17-APR-1992 11:33:37.11 TMR CLOSE TIMEOUT 1

SEN 285; FIX 1; C= 0000000; BIN=GOOD; WPRU=44.0; WPRD=48.7; LEAK RATE= 2.1  
ACT= 101.5; REL= 55.0; DIF= 32.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 286; FIX 2; C= 0000000; BIN=GOOD; WPRU=44.0; WPRD=48.7; LEAK RATE= 2.1  
ACT= 107.0; REL= 100.0; DIF= 34.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 287; FIX 3; C= 0000000; BIN=GOOD; WPRU=44.0; WPRD=48.7; LEAK RATE= 2.1  
ACT= 120.0; REL= 59.0; DIF= 35.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 288; FIX 4; C= 0000000; BIN=GOOD; WPRU=44.0; WPRD=48.7; LEAK RATE= 2.1  
ACT= 129.0; REL= 77.0; DIF= 29.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:42:46.51 OPEN DOOR DID NOT CLOSE 1

17-APR-1992 11:43:06.51 OPEN DOOR STILL DID NOT CLOSE 1

SEN 289; FIX 1; C= 0000000; BIN=GOOD; WPRU=44.1; WPRD=48.0; LEAK RATE= 2.0  
ACT= 105.0; REL= 45.0; DIF= 34.6 PSI; ACTCR= 200.0ms; RELCR= 200.0

SEN 271; FIX 1; C=000000; SIN=8000; MFRU=44.1; MFRD=45.0; LEAK RATE= 2.0  
ACT= 129.4; REL= 59.0; DIF= 29.8 PSI; ACTDR= 200.0ms; RELDR= 200.0

SEN 272; FIX 4; C=000000; SIN=8000; MFRU=44.1; MFRD=46.0; LEAK RATE= 2.0  
ACT= 137.5; REL= 103.0; DIF= 33.5 PSI; ACTDR= 200.0ms; RELDR= 200.0

17-APR-1992 11:43:52.41 OPEN DOOR DID NOT CLOSE 1

SEN 273; FIX 1; C=000000; SIN=8000; MFRU=44.3; MFRD=47.6; LEAK RATE= 2.0  
ACT= 129.7; REL= 58.0; DIF= 34.4 PSI; ACTDR= 200.0ms; RELDR= 200.0

SEN 274; FIX 2; C=000000; SIN=8000; MFRU=44.3; MFRD=47.6; LEAK RATE= 2.0  
ACT= 125.1; REL= 52.0; DIF= 32.2 PSI; ACTDR= 200.0ms; RELDR= 200.0

SEN 275; FIX 3; C=000000; SIN=8000; MFRU=44.3; MFRD=47.6; LEAK RATE= 2.0  
ACT= 134.0; REL= 104.4; DIF= 29.5 PSI; ACTDR= 200.0ms; RELDR= 200.0

SEN 276; FIX 4; C=000000; SIN=8000; MFRU=44.3; MFRD=47.6; LEAK RATE= 2.0  
ACT= 122.9; REL= 87.3; DIF= 35.6 PSI; ACTDR= 200.0ms; RELDR= 200.0

17-APR-1992 11:44:31.03 OPEN DOOR DID NOT CLOSE 1

SEN 277; FIX 1; C=000000; SIN=8000; MFRU=44.2; MFRD=47.2; LEAK RATE= 1.9  
ACT= 131.0; REL= 59.1; DIF= 31.9 PSI; ACTDR= 200.0ms; RELDR= 200.0

SEN 278; FIX 2; C=000000; SIN=8000; MFRU=44.2; MFRD=47.2; LEAK RATE= 1.9  
ACT= 123.6; REL= 50.6; DIF= 33.2 PSI; ACTDR= 200.0ms; RELDR= 200.0

SEN 279; FIX 3; C=000000; SIN=8000; MFRU=44.2; MFRD=47.2; LEAK RATE= 1.9  
ACT= 125.8; REL= 97.5; DIF= 25.4 PSI; ACTDR= 200.0ms; RELDR= 200.0

300  
\*  
SEN 280; FIX 4; C=000000; SIN=8000; MFRU=44.2; MFRD=47.2; LEAK RATE= 1.9  
ACT= 126.5; REL= 92.6; DIF= 35.1 PSI; ACTDR= 200.0ms; RELDR= 200.0

17-APR-1992 11:45:11.54 OPEN DOOR DID NOT CLOSE 1

17-APR-1992 11:45:31.54 OPEN DOOR STILL DID NOT CLOSE 1

17-APR-1992 11:45:46.25 TOOL CYCLE TIMEOUT 1

124 ACT= 143.2; REL= 112.2; DIF= 31.0 PSI; ACTCR= 200.0ms; RELCR= 200.0

51 SER 302; FIX 2; C= 0000000; SIN=GOOD; MFRU=44.3; MFRD=47.7; LEAK RATE= 1.9  
ACT= 127.6; REL= 89.5; DIF= 38.1 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 303; FIX 3; C= 0000000; SIN=GOOD; MFRU=44.3; MFRD=47.7; LEAK RATE= 1.9  
ACT= 129.6; REL= 103.1; DIF= 26.7 PSI; ACTCR= 200.0ms; RELCR= 200.0

SER 304; FIX 4; C= 0000000; SIN=GOOD; MFRU=44.3; MFRD=47.7; LEAK RATE= 1.9  
ACT= 135.4; REL= 101.6; DIF= 33.8 PSI; ACTCR= 200.0ms; RELCR= 200.0

17-APR-1992 11:46:15.1L SPI- DOOR DTU NOT CLOSE 1

# 77-6 PRESSURE TESTER LOT REPORT

TESTING FILE=1

LOT 1071-A-3107

LOT STARTED:17-APR-1992 10:11:04.02

LOT FINISHED:17-APR-1992 11:46:142.95

## TEST DATA

TEST LOT ID: 0109

TEST WARM ACT: 23.4 WARM REL: 13.7

## LINE 100

ACTUATION: 0.0 TO 180.0 PSI

RELEASE: 180.0 TO 0.0 PSI

DIFFERENTIAL: 0.0 TO 180.0 PSI

MAX. HOLDING: 500.0 PSI

ACT. CREEP TIME: 25.0 PSI

REL. CREEP TIME: 150.0 PSI

CREEP CYCLE PRESS: 500.0 PSI


CREEP CYCLE COUNT: 2

UNPASS- 04 PRESS TESTED: 304

END OF TEST



| STATISTICS   | MEAN  | STDEV | CRK  |
|--------------|-------|-------|------|
| ACTUALTIME   | 14.74 | 4.89  | 3.90 |
| RELEASE      | 47.7  | 5.52  | 1.28 |
| RELEASE2     | 6.9   | 0.50  | 0.00 |
| DIFFERENTIAL | 32.9  | 3.15  | 3.44 |



|       |      |       | 20 | 40 | 60 | 80 | 100 | 120 | 140 | 160 | 180 | 200 |
|-------|------|-------|----|----|----|----|-----|-----|-----|-----|-----|-----|
| UNDER | 01   |       |    |    |    |    |     |     |     |     |     |     |
| 25.0  | 131  | ***   |    |    |    |    |     |     |     |     |     |     |
| 30.0  | 1211 | ***** |    |    |    |    |     |     |     |     |     |     |
| 35.0  | 1531 | ***** |    |    |    |    |     |     |     |     |     |     |
| 40.0  | 141  | ****  |    |    |    |    |     |     |     |     |     |     |
| 45.0  | 01   |       |    |    |    |    |     |     |     |     |     |     |
| 50.0  | 01   |       |    |    |    |    |     |     |     |     |     |     |
| 55.0  | 01   |       |    |    |    |    |     |     |     |     |     |     |
| 60.0  | 1    |       |    |    |    |    |     |     |     |     |     |     |
| OVER  | 0    |       |    |    |    |    |     |     |     |     |     |     |

# HISTOGRAM OF ACTUATION DREEP

|       |      |       | 5 | 10 | 15 | 20 | 25 | 30 | 35 | 40 | 45 | 50 |
|-------|------|-------|---|----|----|----|----|----|----|----|----|----|
| DREEP | 01   |       |   |    |    |    |    |    |    |    |    |    |
| 35.0  | 01   |       |   |    |    |    |    |    |    |    |    |    |
| OVER  | 3921 | ***** |   |    |    |    |    |    |    |    |    |    |

# HISTOGRAM OF RELEASE DREEP

|       |    |  | 5 | 10 | 15 | 20 | 25 | 30 | 35 | 40 | 45 | 50 |
|-------|----|--|---|----|----|----|----|----|----|----|----|----|
| UNDER | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 10.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 20.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 25.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 30.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 35.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 40.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 45.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 50.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 55.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 60.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 65.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 70.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 75.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 80.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 85.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 90.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 95.0  | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 100.0 | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 105.0 | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 110.0 | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 115.0 | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 120.0 | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 125.0 | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 130.0 | 01 |  |   |    |    |    |    |    |    |    |    |    |
| 135.0 | 01 |  |   |    |    |    |    |    |    |    |    |    |

```

165.0 01
170.0 01
175.0 01
180.0 01
185.0 01
OVER 279|*****

```

17-APR-1992 11:46:34.31 OPER DOOR DID NOT CLOSE :

17-APR-1992 11:47:04.01 OPER DOOR STILL DID NOT CLOSE :

17-APR-1992 11:47:30.04 TOL CYCLE TIMEOUT :

TI-NHTSA 006986



# INITIAL SAMPLE WARRANT

No. 360068

## PART INFORMATION

Part Name NEXT GENERATION SPEED CONTROL DEACTIVATION SWITCH Part Number F2AC-9F924-AA

Control Item ☐ Yes ☒ No Engineering Change Level \_\_\_\_\_ Date \_\_\_\_\_

Engineering Change Authorization \_\_\_\_\_ Date \_\_\_\_\_

Shown on Drawing No. F2AC-9F924-AA Part Weight .062 kg

### Reason for Initial Sample:

- |                                                        |                                                                             |                                                                |
|--------------------------------------------------------|-----------------------------------------------------------------------------|----------------------------------------------------------------|
| <input checked="" type="checkbox"/> Initial Submission | <input type="checkbox"/> Change in Optional Construction or Material        | <input type="checkbox"/> Process Change                        |
| <input type="checkbox"/> Engineering Change(s)         | <input type="checkbox"/> Additional, Replacement, or Refurbished Tooling    | <input type="checkbox"/> Change in Subcontractor or Source     |
| <input type="checkbox"/> Tooling Transfer              | <input type="checkbox"/> Correction of Discrepancy (Resubmission No. _____) | <input type="checkbox"/> Parts Produced at Additional Location |
| <input type="checkbox"/> Other - Please Specify _____  |                                                                             |                                                                |

## SUPPLIER INFORMATION (Manufacturing Location)

Supplier Name TEXAS INSTRUMENTS INC. Street Address 34 FOREST STREET

City ATTLEBORO State MA Postal Code 01703 Country USA

Supplier Mfg. Location Code - DUNS T095A/7325814 Customer Assigned \_\_\_\_\_

## CUSTOMER INFORMATION

Customer Name DATA CORPORATION Buyer GRANT SIMMONS Buyer Code \_\_\_\_\_

Purchase Order Number \_\_\_\_\_ Sample Acceptance Level \_\_\_\_\_

Application NEXT GENERATION SPEED CONTROL DEACTIVATION SWITCH

## RESULTS

The results for dimensional measurements ☒, material tests ☒, and functional (EB) tests ☒ meet all drawing and specification requirements ☒ Yes ☐ No

### Submission Checklist

- |                                                               |                                                                  |                                                                |
|---------------------------------------------------------------|------------------------------------------------------------------|----------------------------------------------------------------|
| <input checked="" type="checkbox"/> Checked Print             | <input checked="" type="checkbox"/> Material Test Results        | <input checked="" type="checkbox"/> Control Plan               |
| <input type="checkbox"/> Auxiliary Drawings/Sketches          | <input checked="" type="checkbox"/> Certifications               | <input checked="" type="checkbox"/> Process Capability Results |
| <input checked="" type="checkbox"/> Correct Number of Samples | <input checked="" type="checkbox"/> Functional (EB) Test Results | <input checked="" type="checkbox"/> Process Flow Diagram       |
| <input checked="" type="checkbox"/> Dimensional Results       | <input type="checkbox"/> Product Engineering Approval            | <input checked="" type="checkbox"/> Gage (Measurement) Studies |

Supporting data for all requirements are available upon request.

### COMMENTS:

## DECLARATION

I affirm that the samples represented by this warrant are representative of our parts and have been made to the applicable customer drawings and specifications from specified materials, on regular production tooling with no operations other than the regular production process.

Authorized Signature J. Watt Ford Date 8/19/92

Print Name JIM WATT Title QA ENGINEER Phone No. (508) 699-1719

APPROVAL (when required by customer procedure) ☐ Approved ☐ Rejected

Signature \_\_\_\_\_ Date \_\_\_\_\_

TI-NHTSA 006987



# PROCESS POTENTIAL AND QUALITY INDEXES SUMMARY DATA SHEET

PART #: X2AC-2E92A-AA  
SUPPLIER: TEXAS INSTRUMENTS  
CODE: T095A  
ADDRESS: 34 FOREST ST.  
ATLANTIC, MA 02703  
VEHICLE BUILD: EP VP FB OTHER

SUPPLIER CONTACT: JIM WATT  
CONTACT PHONE: (508) 699-1719  
PART DESCRIPTION: NEXT GENERATION SPEED  
CONTROL DEACTIVATION SWITCH  
SOA CODE: \_\_\_\_\_  
VEHICLE PROGRAM: PASS CAR FW53

## CHARACTERISTIC TYPE

▽ = FORD CRITICAL  
CHARACTERISTICS

S.C. = FORD OR SUPPLIER SIGNIFICANT  
CHARACTERISTICS

## NUMBER OF CRITICAL AND SIGNIFICANT CHARACTERISTICS:

|                                |                 |                |                 |
|--------------------------------|-----------------|----------------|-----------------|
| 1: <u>ACTUATION</u>            | TYPE: <u>SC</u> | Cp = <u>**</u> | Cpk = <u>**</u> |
| 2: <u>RELEASE</u>              | TYPE: <u>SC</u> | Cp = <u>**</u> | Cpk = <u>**</u> |
| 3: <u>3/8-24UNF-2A THREADS</u> | TYPE: <u>SC</u> | Cp = <u>AS</u> | Cpk = <u>AS</u> |
| 4: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 5: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 6: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 7: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 8: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 9: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 10: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 11: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 12: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 13: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 14: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 15: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |

1833/  
PIST = 1833 x 100 = 100 %

PIPC<sub>Cp</sub> = \_\_\_\_\_ x 100 = \_\_\_\_\_ % PIPC<sub>Cpk</sub> = \_\_\_\_\_ x 100 = \_\_\_\_\_ %

## COMMENTS:

\*\* CALIBRATION CHECK IS DONE 100 PERCENT. PARTS TESTED 300 :  
DEFECTIVE 0 PERCENT OF DEFECT 0.

AS THREADS ARE CHECKED ON A GO/NOGO GAGE

PREPARED BY:

ELAINE ROSE

DATE: 8-19-92

# **PROCESS POTENTIAL AND QUALITY INDEXES SUMMARY DATA SHEET**

PART #: E2AC-2002A-AA  
 SUPPLIER: TEXAS INSTRUMENTS  
 CODE: T095A  
 ADDRESS: 34 FOREST ST.  
ATL-BORO, MA 02703  
 VEHICLE BUILD: EP VP PB OTHER

SUPPLIER CONTACT: JIM WATT  
 CONTACT PHONE: (508) 699-1719  
 PART DESCRIPTION: NEXT GENERATION SPEED  
CONTROL DEACTIVATION SWITCH  
 SOA CODE: \_\_\_\_\_  
 VEHICLE PROGRAM: PAGE CAR EX51

## **CHARACTERISTIC TYPE**

**V = FORD CRITICAL  
CHARACTERISTICS**

**S.C. = FORD OR SUPPLIER SIGNIFICANT  
CHARACTERISTICS**

## **NUMBER OF CRITICAL AND SIGNIFICANT CHARACTERISTICS:**

|                                |                 |                |                 |
|--------------------------------|-----------------|----------------|-----------------|
| 1: <u>ACTUATION</u>            | TYPE: <u>SC</u> | Cp = <u>**</u> | Cpk = <u>**</u> |
| 2: <u>RELEASE</u>              | TYPE: <u>SC</u> | Cp = <u>**</u> | Cpk = <u>**</u> |
| 3: <u>3/8-24UNF-2A THREADS</u> | TYPE: <u>SC</u> | Cp = <u>**</u> | Cpk = <u>**</u> |
| 4: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 5: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 6: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 7: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 8: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 9: _____                       | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 10: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 11: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 12: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 13: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 14: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |
| 15: _____                      | TYPE: _____     | Cp = _____     | Cpk = _____     |

1833/  
 PIST = 1833 x 100 = 100 %

PIPC<sub>Cp</sub> = \_\_\_\_\_ x 100 = \_\_\_\_\_ %    PIPC<sub>Cpk</sub> = \_\_\_\_\_ x 100 = \_\_\_\_\_ %

## **COMMENTS:**

**\*\* CALIBRATION CHECK IS DONE 100 PERCENT. PARTS TESTED 300 :  
 DEFECTIVE 0 PERCENT OF DEFECT 0.**

**\*\* THREADS ARE CHECKED ON A GO/NOGO GAGE**

## **PREPARED BY:**

ELAINE ROSE

**DATE:** 8-19-92

Form 21605

TEST NO. 319-13-20

|                    |                           |                            |                                  |
|--------------------|---------------------------|----------------------------|----------------------------------|
| DEVICE<br>77p563-1 | DATE REQUESTED<br>8-11-72 | REQUESTED BY<br>PALE SODAK | REQUESTED COMPL. DATE<br>8-20-72 |
| PERFORMED BY       | DATE STARTED              | DATE COMPLETED             | APPROVED BY                      |

ADJECT TITLE: EVALUATION OF 1714 ATLAS ON PROD LINE FOR NET CARRP  
(25-50%)

CUSTOMER: **ESAP**

PURPOSE OF TEST: DETERMINE IF THERE ARE ACTUALLY TWO GROUPS OR IF THEY ARE LOW. IF IT IS NOT CLEAR THEN WE CAN SKIP IT AND CONSIDER DISABLING THE NET GROUP CHECK ON THE MINAL TEST

PROCEDURE: THERE ARE TWO LOTS (LOT 118, 120 AND 122) & LOT 132 PILOT  
PILLOT. TEST FOUR PIPES FROM EACH LOT FOR SOUND LEVEL, THEN TEST  
THE SAME PIPES FOR FORCE DEFLECTION WITH ELECTRICAL SIGNAL  
TO DETERMINE WHERE CORROSION OCCURS.


CONCLUSION: THEY ARE NOISE. THE LIMIT IS 30mV. THE SENSOR CURVES DO NOT SUGGEST ANYTHING WRONG WITH THE SAVED ASSEMBLY. LATER ANALYSIS DETERMINED THAT THE DISC COILS WERE BAD. THE DISCS WOULD NO LONGER A DIFFERENTIAL BEFORE HEAT TREAT.

| Device # | Signal path<br>Voltage |
|----------|------------------------|
| 119 - 1  | 0V <sub>RMS</sub>      |
| 2        | 0V <sub>RMS</sub>      |
| 3        | -160mV                 |
| 4        | -170mV                 |
| 5        | -75mV                  |
| 6        | -38                    |
| 7        | -36                    |
| 8        | -110                   |
| 9        | -95                    |
| 10       | -210 - 10-5m           |
| 132 - 1  | -180mV                 |
| 2        | -320mV                 |
| 3        | -150mV                 |
| 4        | -220                   |
| 5        | -60                    |
| 6        | -20                    |
| 7        | -110                   |
| 8        | -65                    |
| 9        | -120                   |
| 10       | -80                    |

TI-NHTSA 00699

TI-NHTSA 006990

(OVER)




TI-NHT8A 008991



LOT 119

|            |        |        |        |
|------------|--------|--------|--------|
| RANGES     | 2.250V | 10.00V | 3.750V |
| OFFSETS    | 0.0V   | 0.0V   | 0.0V   |
| TOTAL TIME | 1.00S  |        |        |
| POST-TRIG  | 0.0S   |        |        |
| TRIGGER    | MAN    |        |        |



TI-NHTSA 006992

101 119

|             |        |        |        |
|-------------|--------|--------|--------|
| RANGES:     | 2.250V | 10.00V | 3.750V |
| OFFSETS:    | 0.0V   | 0.0V   | 0.0V   |
| TOTAL TIME: | 1.00S  |        |        |
| POST TRIG:  | 0.0S   |        |        |
| TRIGGER:    | MAN    |        |        |

23.5

 $\Delta = 3.75$ 

20.75

#2

TI-NHTSA 006993

207 22

RANGES: 2.250V 10.00V 3.750V  
 OFFSETS: 0.0V 0.0V 0.0V  
 TOTAL TIME: 1.00S  
 POST-TRIG: 0.0S  
 TRIGGER: MAN

24 ps

0-4.00


20.5

#3

TI-NHITSA 006994


20 33

|             |        |        |        |
|-------------|--------|--------|--------|
| RANGES:     | 2.250V | 10.00V | 3.750V |
| OFFSETS:    | 0.0V   | 0.0V   | 0.0V   |
| TOTAL TIME: | 1.00S  |        |        |
| POST-TRIG:  | 0.0S   |        |        |
| TRIGGER:    | MAN    |        |        |



LOT 132

|             |        |        |        |
|-------------|--------|--------|--------|
| RANGES:     | 2.250V | 10.00V | 3.750V |
| OFFSETS:    | 0.0V   | 0.0V   | 0.0V   |
| TOTAL TIME: | 1.00s  |        |        |
| POST-TRIG:  | 0.0s   |        |        |
| TRIGGER:    | MAN    |        |        |



RED #6  
 BLUE #7  
 Green #8  
 Orange #9  
 Yellow #10

TI-NHTSA 006996

LOT 132

RANGES: 2.250V 10.00V 3.750V  
 OFFSETS: 0.0V 0.0V 0.0V  
 TOTAL TIME: 1.00S  
 POST-TRIG: 0.0S  
 TRIGGER: MAN

2.5 pA/div

1.5 mV/div

20 pA

$\theta = 4.25^\circ$

21.75

Blue #1  
 Green #2  
 Orange #3  
 Aqua #4  
 Purple #5

TI-NHTSA 006997

W DETENT  
 PART NO. 31062-35  
 DATE 8/21  
 CLOCK NO. 68904  
 QTY. 2000  
 LOT NO. #132  
 REEL NO. 4  
 S.S. 2  
 MIC. SETTINGS \_\_\_\_\_  
 A. \_\_\_\_\_  
 R. \_\_\_\_\_

"F. & HOUR

| FREE DISC PRESSURES |         |             |         |                  |          |
|---------------------|---------|-------------|---------|------------------|----------|
| B. H. T.            |         | 4TH READING |         |                  |          |
| ACTUATION           | RELEASE | ACTUATION   | RELEASE | ACTUATION        | RELEASE  |
|                     | 1       | YES         | ? / YES | NO               | NO       |
|                     | 2       | NO          | NO      | 7 NO             | NO       |
|                     | 3       | YES         | NO      | 8 YES<br>1 / YES | YES / NO |
|                     | 4       | NO          | NO      | 9 YES / YES      | NO       |
|                     | 5       | NO          | NO      | 11 NO            | 1?       |

MAT'L I.D. NO. 00449 A-2-4

FORM 21133

TI-NHTSA 006906

# TEXAS INSTRUMENTS



Dana Corporation  
Weatherhead Division  
109 Increment Street  
St. Thomas, Ontario  
Canada M5P3G8

August 20, 1992

Attn: Mr. Jerry Garber  
Quality Manager

Subj: Part Number F2AC-9F924-AA (Pressure Switch)  
TI Part Number 77PSL3-1

Dear Jerry,

Enclosed, please find the ISIR for the F2AC-9F924-AA pressure switch. An identical ISIR package has also been forwarded to the Dana Angola, Indiana facility.

Please let me know if you have any questions or if I may be of any further assistance.

Regards,

  
Jim Watt  
QRA Engineer  
Precision Controls Department  
Control Products Division

cc: Dave Czern, MS 12-29; Steve Offiler, MS 12-29  
Rick Conlin, MS 12-33; Gary Snyder, MS 12-33  
Andy McGuirk, MS 12-27  
Grant Simmons, Dana Purchasing Dept., Ontario, Canada  
Norm Freda, TI Farmington Hills, Michigan

encl: ISIR submission F2AC-9F924-AA

*original pkg.  
to  
Canada*

TI-NHT8A 006999



# TEXAS INSTRUMENTS



Dana Corporation  
Weatherhead Division  
203 Weatherhead Street  
Angola, Indiana 46703

August 20, 1983

Attn: Mr. Lynn Johnson  
Quality Manager

Subj: Part Number F2AC-9F924-AA (Pressure Switch)  
TI Part Number 77PSL3-1

Dear Lynn,

Enclosed, please find a copy of the ISIR for the F2AC-9F924-AA pressure switch. The original ISIR package has been forwarded to Dana Ontario, Canada facility.

Please let me know if you have any questions or if I may be of any further assistance.

Regards,

  
Jim Watt

QRA Engineer  
Precision Controls Department  
Control Products Division

cc: Dave Czern, MS 12-29; Steve Offiler, MS 12-29  
Rick Conlin, MS 12-33; Gary Snyder, MS 12-33  
Andy McGuirk, MS 12-27  
Mike Rogers, Dana Purchasing Dept., Angola, Indiana  
Norm Freda, TI Farmington Hills, Michigan

enc1: ISIR submission F2AC-9F924-AA

*copy of pkg.  
sent to  
Indiana*

TI-NHT8A 007000

REPORT OF ISR TESTING  
 FORD PASSENGER CAR  
 ELECTRONIC SPEED CONTROL  
 DEACTIVATION PRESSURE SWITCH  
 PS/92/82

TEXAS INSTRUMENTS INCORPORATED  
 CONTROL PRODUCTS DIVISION  
 PRECISION CONTROLS DEPARTMENT  
 34 FOREST STREET  
 ATTLEBORO, MA 02703

TI-NHTSA 007001

|                                |                                                                                                       |        |
|--------------------------------|-------------------------------------------------------------------------------------------------------|--------|
| TEST LOT NO.                   | TEST                                                                                                  | DEVICE |
| TESTED BY                      |                                                                                                       |        |
| APPROVED BY <i>[Signature]</i> | TEXAS INSTRUMENTS  | DOC.   |
| DATE 02-08-82                  | MATERIALS & CONTROLS GROUP<br>ATTLEBORO, MA 02703                                                     | PAGE 1 |

# TABLE OF CONTENTS

|      |                                                                |    |
|------|----------------------------------------------------------------|----|
| 1.0  | GENERAL                                                        | 3  |
| 2.0  | OBJECTIVE                                                      | 4  |
| 3.0  | TEST PROCEDURES AND RESULTS                                    | 4  |
| 3.1  | CALIBRATION                                                    | 4  |
| 3.2  | VOLTAGE DROP                                                   | 5  |
| 3.3  | CURRENT LEAKAGE                                                | 6  |
| 3.4  | PROOF                                                          | 7  |
| 3.5  | IMPULSE                                                        | 7  |
| 3.6  | BURST                                                          | 8  |
| 3.7  | HUMIDITY                                                       | 9  |
| 3.8  | SALT SPRAY                                                     | 9  |
| 3.9  | VIBRATION                                                      | 9  |
| 3.10 | TERMINAL STRENGTH                                              | 10 |
| 3.11 | VACUUM                                                         | 10 |
| 3.12 | TEMPERATURE CYCLE                                              | 11 |
| 3.13 | FLUID RESISTANCE                                               | 11 |
| 3.14 | NOISE                                                          | 12 |
| 4.0  | APPENDICES                                                     |    |
| 4.1  | Ford Engineering Specification<br>(inv delta) ES-F2VC-9F924-AA | 14 |
| 4.2  | Data                                                           | 33 |
| 4.3  | Noise Pressure Trace                                           | 38 |

TI-NHTSA 007002

|              |                   |        |
|--------------|-------------------|--------|
| TEST LOT NO. | TEST              | DEVICE |
| TESTED BY    |                   |        |
| APPROVED BY  |                   | DDO.   |
| DATE         | TEXAS INSTRUMENTS | PAGE 2 |

MATERIALS & CONTROLS  
GROUP  
ATTLEBORO, MA 01763

1.0 GENERAL

1.1 Customer: Ford Motor Company P.I.A. from Dana-Weatherhead

1.2 Part Numbers:

1.2.1 Ford P/N: F2AC-9F924-AA

1.2.2 Dana P/N: 120-55046

1.2.3 TI P/N: 77PSL3-1

1.3 Engineering Specification: (inv delta) ES-F2VC-9F924-AA

1.4 Date of Completion: 920811

1.5 Quantity of Units Tested: 72

1.6 Disposition of Tested Units: All devices are presently retained under quarantine, completely separate from any production devices, to be destroyed per the IA at a later date after full IQR approval is obtained.

1.7 TI test series number: 245-15-129

1.8 TI Pressure Switch test report number: PS/92/82

TI-NHTSA 007003

|                                                   |                                                                                                                 |        |
|---------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------|
| TEST LOT NO.                                      | TEST                                                                                                            | DEVICE |
| TESTED BY                                         | <br><b>TEXAS INSTRUMENTS</b> | DOC.   |
| APPROVED BY                                       |                                                                                                                 | PAGE   |
| DATE                                              |                                                                                                                 |        |
| MATERIALS & CONTROLS GROUP<br>ATTLEBORO, MA 02103 |                                                                                                                 |        |

## 2.0 OBJECTIVE

This testing was performed to demonstrate the ability of 77PSL3-1 to conform to customer specifications given in (inv delta) ES-F2VC-9F924-AA, in fulfillment of the requirements of the Initial Sample Report. Units tested were built using fully qualified production components and production assembly equipment.

## 3.0 TEST PROCEDURES AND RESULTS

All switches were tested per (Ford Engineering Specification (inv delta) ES-F2VC-9F924-AA. A copy of this ES is included in Appendix 4.1.

4.1. Procedural details are therefore omitted from the presentation of results in most cases. In those instances where the ES procedure methodology requires elaboration, a complete explanation of the procedure is presented. For all tests, raw data is included in Appendix 4.2.

### 3.1 CALIBRATION

3.1.1 Devices tested: 245-15-01 thru 72

3.1.2 Procedure: Calibration is checked at room temperature using ambient air as the pressure medium. Calibration settings, as specified on the part drawing, are actuation (electrical contacts opening) at 90 - 150 psig, and release (contacts reclosing) at 20 psig minimum. For the purpose of stabilization, actuation values are recorded on the sixth cycle, after subjecting the switch to two (2) pressure cycles to 800 psig minimum and back to zero, followed by three (3) cycles to approx. 10% above actuation pressure and back to approx. 10% below release pressure. The change in continuity is measured while conducting 750 +/- 50 milliamps at 13.0 +/- 1.0 volts DC.

TI-NHTSA 00700A

|               |                                                                                                       |                                                            |
|---------------|-------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
| TEST LOT NO.  | TEST                                                                                                  | DEVICE                                                     |
| TESTED BY     |                                                                                                       |                                                            |
| APPROVED BY   |                                                                                                       | DOQ.                                                       |
| DATE 87-08-17 | TEXAS INSTRUMENTS  | MATERIALS & CONTROL GROUP<br>ATTLEBORO, MA 01903<br>PAGE 4 |

3.1.3 Equipment: Custom TI designed and built pressure check station, using Heise Model CM96365 pressure gage calibrated on a regular quarterly schedule. Continuity change measured on custom TI designed and built equipment meeting the above electrical parameters.

3.1.4 Initial Results: Prior to proof testing, the average actuation was found to be 126 psi with a sigma of 6.2; after proof the average actuation was 131 psi with a sigma of 4.9. The average shift is 4%. Prior to proof testing, the average release was found to be 113 psi with a sigma of 6.5; after proof the average release was 119 psi with a sigma of 5.7. The average shift is 5%.

3.1.5 Final Results: Prior to proof testing, the average actuation was found to be 130 psi with a sigma of 5.4; after proof the average actuation was 129 psi with a sigma of 5.3. The average shift is -0.8%. Prior to proof testing, the average release was found to be 108 psi with a sigma of 7.7; after proof the average release was 108 psi with a sigma of 6.6. The average shift is 0.

### 3.2 VOLTAGE DROP

3.2.1 Devices tested: 245-15-01 thru 72

3.2.2 Procedure: Voltage drop is checked simultaneously with Calibration (see 3.1.2). The measurement is taken at room temperature using ambient air as the pressure medium. For the purpose of stabilization, data is recorded on the sixth cycle, after subjecting the switch to two (2) pressure cycles to 800 psig minimum and back to zero, followed by three (3) cycles to approx. 10% above actuation pressure and back to approx. 10% below release pressure. The voltage drop is measured while conducting 750 +/- 50 milliamps at 13.0 +/- 1.0 volts DC.

TI-NHTSA 007005

|                   |      |                                                 |
|-------------------|------|-------------------------------------------------|
| TEST LOT NO.      | TEST | DEVICE                                          |
| TESTED BY         |      |                                                 |
| APPROVED BY       |      |                                                 |
| DATE              |      |                                                 |
| TEXAS INSTRUMENTS |      | MATERIALS & CONTROLS GROUP<br>ATLANTA, GA 30308 |
|                   |      | DOC. PAGE                                       |

3.2.3 Equipment: Fluke Model 8020B Digital Multimeter, calibrated quarterly, used in conjunction with the continuity equipment in 3.1.3.

3.2.4 Initial results: Values for all devices fell below the specification of 200 millivolts maximum by close to two orders of magnitude; no specific statistics calculated for this reason.

3.2.5 Final results: With the exception of parts undergoing impulse testing (devices 245-15-01 thru 12 and 37 thru 48), all final results were comparable with initial results. The impulse parts experience an increase in the voltage drop reading due to the specified 25,000 cycles run at full electrical load, which causes a certain amount of normal erosion of the contact surfaces. All 24 impulse devices still fell significantly below 200 mV maximum, and statistics show a Cpk of 2.53.

### 3.3 CURRENT LEAKAGE

3.3.1 Devices tested: 245-15-01 thru 72.

3.3.2 Procedure: Per the ES section III. C. This test is conducted as a pass/fail.

3.3.3 Equipment: Associated Research HyFor test unit used as power source for 500 VAC, 60 Hz test circuit. Fluke Model 8020B Digital Multimeter, calibrated quarterly, used to measure voltage drop across a series resistance of one megohm (+/- 5%).

3.3.4 Initial results: All devices passed.

3.3.5 Final results: All devices passed.

TI-NHTSA 007006

|              |                                                                                                       |                                                  |
|--------------|-------------------------------------------------------------------------------------------------------|--------------------------------------------------|
| TEST LOT NO. | TEST                                                                                                  | DEVICE                                           |
| TESTED BY    |                                                                                                       |                                                  |
| APPROVED BY  | TEXAS INSTRUMENTS  | MATERIALS & CONTROL GROUP<br>ATTLESDON, MA 02109 |
| DATE         |                                                                                                       | PAGE 4                                           |

### 3.4 PROOF

- 3.4.1 Devices tested: 245-15-01 thru 72
- 3.4.2 Procedure: Per the ES section III. D. This test is conducted as a pass/fail. The test pressure specified on the part drawing is 3000 psi.
- 3.4.3 Equipment: Enerpak model P-392 hydraulic hand pump using Enerpak hydraulic fluid as the pressure medium. Hydraulic fluid is removed from the devices using a combination of vacuum and residue-free solvent Sprayon(TM) Hi-Tech 02002 TF Electrical Contact Cleaner. US Gauge #33714 reading to 5000 psig with 100 psi increments, resolvable to 50 psi., calibrated quarterly. Custom TI designed and built safety enclosure.
- 3.4.4 Initial Results: All devices passed.
- 3.4.5 Final Results: All devices passed.

### 3.5 IMPULSE

- 3.5.1 Devices tested: 245-15-01 thru 12 and -37 thru 48
- 3.5.2 Procedure: Per the ES section III. E.
- 3.5.3 Equipment: Thermotron model S-4 Mini-Max environmental chamber capable of -55 C to +200 C, humidity uncontrolled. Custom TI designed and built cyclor, utilizing Enerpak integrated hydraulic pressure source, TI315 Programmable Logic Controller, Moog servovalve and controller, Simpson signal generator, and opposing-piston fluid isolators, to produce a hydraulic-fluid flow-type primary, with a brake-fluid dead-end-type secondary terminated with a 24-station manifold equipped with internal heaters. Capability to 5 Hz at 0-1450 psig cycle. Custom TI designed and built 24 station Switch

TI-NHTSA 007007

|               |                                                                                                       |                                                             |
|---------------|-------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
| TEST LOT NO.  | TEST                                                                                                  | DEVICE                                                      |
| TESTED BY     |                                                                                                       |                                                             |
| APPROVED BY   |                                                                                                       | DOC.                                                        |
| DATE 89-08-17 | TEXAS INSTRUMENTS  | MATERIALS & CONTROLS GROUP<br>ATTLEBORO, MA 02703<br>PAGE 7 |



Monitor Circuit which automatically stops the cycler in the event of abnormal switch action, defined as continuity change which does not track the signal from the signal generator. Thermocouple readouts calibrated quarterly. 12-station inductive load bank, per the schematic found in the ES (figure 4) used in the last 25K cycles...

3.5.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

### 3.6 BURST

3.6.1 Devices tested: 245-13-67 thru 72.

3.6.2 Procedure: Per the ES section III. F. After holding 7000 psi for 30 seconds as specified, the devices were inadvertently pressurized to approx. 7600 psi.

3.6.3. Equipment: Same as 3.4.3, with the addition of Enerpak gauge reading to 10,000 psig with 100 psi increments, resolvable to 50 psi, calibrated quarterly.

3.6.4. Results: All six devices passed 30 seconds at 7000 psig without evidence of fluid leakage or seepage from the switch or threads.

At 7600 psi, one device (-70) displayed evidence of fluid seepage.

TI-NHTSA 007008

|               |                                                                                                              |        |
|---------------|--------------------------------------------------------------------------------------------------------------|--------|
| TEST LOT NO.  | TEST                                                                                                         | DEVICE |
| TESTED BY     |  <b>TEXAS INSTRUMENTS</b> | DOC.   |
| APPROVED BY   |                                                                                                              | PAGE   |
| DATE 97-06-17 |                                                                                                              |        |

MATERIALS & CONTROLS GROUP  
ATTLESBORO, MA 01703

### 3.7 HUMIDITY

3.7.1 Devices tested: 245-15-25 thru -30.

3.7.2 Procedure: Per the ES section III. G. Please note that performing a full characterization per the ES consists of measurement of actuation, release, voltage drop, current leakage, and proof. This battery of tests when performed on six (6) devices takes approximately 2 hours to complete. Therefore "Within 15 minutes..." called out in the ES (section III. G. 2. a.) is an acceptance requirement that is physically impossible to meet. Every effort is made to complete final characterization within the two hour period stated above.

3.7.3 Equipment: Humidity chamber RK model 55.

3.7.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

### 3.8 SALT SPRAY

3.8.1 Devices tested: 245-15-31 thru -36.

3.8.2 Procedure: Per the ES section III. H.

3.8.3 Equipment: Harshaw salt spray chamber.

3.8.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

### 3.9 VIBRATION

3.9.1 Devices tested: 156-15-61 thru 66.

3.9.2 Procedure: Per the ES section III. I.

TL-NHTSA 007009

|               |                                                                                                                 |        |
|---------------|-----------------------------------------------------------------------------------------------------------------|--------|
| TEST LOT NO.  | TEST                                                                                                            | DEVICE |
| TESTED BY     | <br><b>TEXAS INSTRUMENTS</b> | DOC.   |
| APPROVED BY   |                                                                                                                 | PAGE   |
| DATE 12-08-17 |                                                                                                                 |        |

MATERIALS & CONTROLS GROUP  
ATTLEBORO, MA 02703

3.9.3 Equipment: Vibration table, Ling, model A395 with Hewlett-Packard model 5427 controls. Air tank with 350 psig minimum pressurized Nitrogen used to actuate devices with at least 1.1 times maximum actuation specification on part drawing; 160 psig \* 1.1 = 176 psi minimum.

3.9.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

### 3.10 TERMINAL STRENGTH

3.10.1 Devices tested: 243-13-13 thru -24.

3.10.2 Procedure: Per the ES section III. J.

3.10.3 Equipment: Custom TI designed and built fixtures for gaging terminal movement after force application and for application of impact via a pendulum. This equipment is regularly used on the 57PS/77PS assembly lines in testing to TI Quality Assurance Specifications.

3.10.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

### 3.11 VACUUM

3.11.1 Devices tested: 243-13-55 thru 60.

3.11.2 Procedure: Per the ES section III. K.

3.11.3 Equipment: Kinney vacuum pump. Sensotec pressure transducer range 0-25 psia calibrated quarterly, with Fluke model 802QB Digital Multimeter readout, calibrated quarterly.

3.11.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

TI-NHTSA 007010

|               |                                                                                                       |         |
|---------------|-------------------------------------------------------------------------------------------------------|---------|
| TEST LOT NO.  | TEST                                                                                                  | DEVICE  |
| TESTED BY     |                                                                                                       |         |
| APPROVED BY   | TEXAS INSTRUMENTS  | DOO.    |
| DATE 97-08-17 | MATERIALS & CONTROLS GROUP<br>MILFORD, MA 02162                                                       | PAGE 10 |

### 3.12 TEMPERATURE CYCLE

3.12.1 Devices tested: 245-15-49 thru 54

3.12.2 Procedure: Per the ES section III. L.

3.12.3 Equipment: Same as 3.5.3.

3.12.4 Results: All devices passed the acceptance requirements of the ES (sections A, B, C, D).

### 3.13 FLOYD RESISTANCE

3.13.1 Devices tested: 245-15-01 thru -36.

3.13.2 Procedure: Per the ES section III. M.

3.13.3 Equipment: Fluids as called out in ES table in III. M. 1. c. plus appropriate beakers and storage apparatus; vented hood.

3.13.4 Results: The 36 devices were divided into groups as follows for subsequent testing. Results of these tests are reported in the section indicated.

3.13.4.1 Impulse (3.5), -01 thru -12

3.13.4.2 Terminal Strength (3.10), -13 thru -24.

3.13.4.3 Humidity (3.7), -25 thru -30.

3.13.4.4 Salt Spray (3.8), -31 thru -36.

TI-NHTSA 007011

|               |                                                                                                                                                         |         |
|---------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------|
| TEST LOT NO.  | TEST                                                                                                                                                    | DEVICE  |
| TESTED BY     |                                                                                                                                                         |         |
| APPROVED BY   |                                                                                                                                                         | DOC.    |
| DATE 92-08-17 | TEXAS INSTRUMENTS  MATERIALS & CONTROLS GROUP<br>ATTLEBORO, MA 01703 | PAGE 11 |

### 3.14 NOISE

In certain vehicle applications, the brake pressure switch action has been shown to be transmitted to the passenger compartment as audible noise and corresponding tactile feel in the brake pedal. A "silent" device has been developed by Texas Instruments in order to address this concern. At the same time, a means of quantifying the noise/feel was explored. The hypothesis was that a sudden motion of pressure-sensing components within the switch caused a pressure wave to propagate from the switch. Characterization of this effect using high-speed pressure transducers showed that "noisy" devices produce a large negative pressure spike at the point of switch activation, and supported the hypothesis. The "silent" devices produce little or no spike. See Appendix 4.3 for a pressure trace of a typical silent device.

Ultimately (inv delta) ES-F2VC-9F924-AA will be updated to include a section on noise testing, to be applicable only to devices designated as silent. For this validation, in lieu of an officially finalized noise specification, a total of 12 devices (6 from this test and 6 similar devices) were initially characterized for noise, then run through Impulse or Thermal Cycle testing, then recharacterized for noise at the end.

#### 3.14.1 Devices tested:

|                         |                      |
|-------------------------|----------------------|
| 77PSL3-1 Impulse:       | 245-15-37, 38, 39    |
| 77PSL3-1 Thermal Cycle: | 245-15-49, 50, 51    |
| 77PSL5-2 Impulse:       | 245-15-81, 82, 83    |
| 77PSL5-2 Thermal Cycle: | 245-15-105, 106, 107 |

3.14.2 Procedure: The device under test is installed on the test manifold. Air is evacuated via a vacuum pump. The manifold is filled with the test fluid. Pressure to 300 psi is applied and the signal from the high-speed transducer is captured on a digital oscilloscope.

TI-NHTSA 007012

|               |                                                                                                          |                                                     |
|---------------|----------------------------------------------------------------------------------------------------------|-----------------------------------------------------|
| TEST LOT NO.  | TEST                                                                                                     | DEVICE                                              |
| TESTED BY     |                                                                                                          |                                                     |
| APPROVED BY   |                                                                                                          |                                                     |
| DATE 92-08-17 | TEXAS<br>INSTRUMENTS  | MATERIALS & CONTROL<br>GROUP<br>ATTLEBORO, MA 01701 |
|               |                                                                                                          | DOC.                                                |
|               |                                                                                                          | PAGE 12                                             |

- 3.14.3 Equipment: Custom TI designed and built equipment, utilizing a single-port test manifold within a protective enclosure. The manifold is evacuated by a Piab H-125 pneumatic vacuum pump. DOT 3 Brake Fluid is introduced via a fluid reservoir. Pressure is applied via pressurized air which is introduced to an air-over-oil chamber which connects to the test manifold. The dynamic pressure signal during switch actuation is measured with a Kistler High-Frequency Dynamic Pressure Transducer model 606A (SN C46154) with a Kistler 5004 Charge Amplifier whose output connects to channel A of a dual-channel Nicolet 4094A Digital Oscilloscope. The electrical switching action of the device under test is recorded simultaneously on channel B using a 5-volt source and a 1K ohm load resistor.
- 3.14.4 Initial results: All twelve test devices produced zero pressure spike.
- 3.15.3 Final results: All twelve test devices produced zero pressure spike.

TI-NHTSA 007013

|               |                                                                                                                                                                   |        |
|---------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| TEST LOT NO.  | TEST                                                                                                                                                              | DEVICE |
| TESTED BY     |  <b>TEXAS INSTRUMENTS</b><br>MATERIALS & CONTROLS GROUP<br>ATTLEBORO, MA 02153 | DOC.   |
| APPROVED BY   |                                                                                                                                                                   | PAGE   |
| DATE 97-08-17 |                                                                                                                                                                   | 11     |

Appendix 4.1  
 Ford Engineering Specification  
 (inv delta) ES-F2VC-9F924-AA

TI-NHTSA 007014

|               |                                                                                                                                           |                                                                        |        |
|---------------|-------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------|--------|
| TEST LOT NO.  | <b>TEST</b><br><br><b>TEXAS</b><br><b>INSTRUMENTS</b>  | <b>MATERIALS &amp; CONTROLS</b><br><b>GROUP</b><br>ATTLEBORO, MA 02703 | DEVICE |
| TESTED BY     |                                                                                                                                           |                                                                        | DOC.   |
| APPROVED BY   |                                                                                                                                           |                                                                        | PAGE   |
| DATE 02-08-12 |                                                                                                                                           |                                                                        |        |

# **Engineering Specification**

|                                                         |     |    |                                                             |  |  |                                   |    |    |                                                   |  |  |
|---------------------------------------------------------|-----|----|-------------------------------------------------------------|--|--|-----------------------------------|----|----|---------------------------------------------------|--|--|
| PART NAME<br>SWITCH ASSEMBLY - SPEED CONTROL DEACTIVATE |     |    |                                                             |  |  | PART NUMBER<br>▽ ES-F270-9F924-11 |    |    |                                                   |  |  |
| LET                                                     |     |    |                                                             |  |  |                                   |    |    |                                                   |  |  |
| PR                                                      |     |    |                                                             |  |  |                                   |    |    |                                                   |  |  |
| LET                                                     |     |    |                                                             |  |  |                                   |    |    |                                                   |  |  |
| PR                                                      |     |    |                                                             |  |  |                                   |    |    |                                                   |  |  |
| DATE                                                    | LET | PR | REVISIONS                                                   |  |  |                                   | DR | CK | REFERENCE                                         |  |  |
| 11/13/80                                                |     |    | ADDED DATA TO COMPLETE SPEC. & RETYPED<br>NCODE 10079779002 |  |  |                                   |    |    | DESIGNED/APPROVED BY<br>R. J. Pendergast          |  |  |
|                                                         |     |    |                                                             |  |  |                                   |    |    | CHECKED BY                                        |  |  |
|                                                         |     |    |                                                             |  |  |                                   |    |    | DETAILS BY                                        |  |  |
|                                                         |     |    |                                                             |  |  |                                   |    |    | CONCURRENCE/APPROVAL SIGNATURE                    |  |  |
|                                                         |     |    |                                                             |  |  |                                   |    |    | DESIGN ENGINEERING SUPERVISOR<br>J. J. Pendergast |  |  |
|                                                         |     |    |                                                             |  |  |                                   |    |    | DESIGN ENGINEERING MGT.                           |  |  |
|                                                         |     |    |                                                             |  |  |                                   |    |    | MANUFACTURING ENGINEER                            |  |  |
|                                                         |     |    |                                                             |  |  |                                   |    |    | QUALITY CONTROL<br>J. J. Pendergast               |  |  |
|                                                         |     |    |                                                             |  |  |                                   |    |    | SUPERVISOR QUALITY ASSISTANCE<br>J. J. Pendergast |  |  |
|                                                         |     |    |                                                             |  |  |                                   |    |    | ELECTRONICS DIVISION<br>J. J. Pendergast          |  |  |

▽ CONTROL ITEM -- THE ▽ SYMBOL ALSO IDENTIFIES PRODUCT ENGINEERING DESIGNATED CRITICAL CHARACTERISTICS. THESE AND ADDITIONAL CRITICAL CHARACTERISTICS IDENTIFIED BY PROCESS REVIEWER MUST APPEAR ON THE Q-101 CONTROL PLAN WHICH SECURE PRODUCT ENGINEERING APPROVAL.



## Engineering Specification

### SWITCH ASSEMBLY - SPEED CONTROL DEACTIVATE

#### I. General

This specification covers the test requirements for the speed control deactivate switch - 9F524 - used in the electronic speed control system. Design changes on the switch assembly or its components shall not be made without compliance to Section V of this specification and written approval from the releasing Production Engineering Office.

This engineering specification is a supplement to the released drawing on the above part, and all requirements herein must be met in addition to all other requirements of the part drawing. Minimum measures necessary for demonstrating compliance to these requirements are given in each section.

The engineering tests, sample sizes, and test frequencies contained within this engineering specification reflect the minimum requirements established to provide a regular evaluation of conformance to design intent. The engineering test program is intended as a supplement to normal material inspections, dimensional checking and in-process controls, and should in no way adversely influence other inspection operations.

Q1 suppliers may implement different test sample sizes and frequencies providing which changes have been included in an alternate Control Plan approved by the design responsible Product Engineering Office and concurred in by SQA.

#### II. PRODUCTION VALIDATION AND IN-PROCESS TESTS


- Production Validation (PV) Tests must be completed satisfactorily with parts from production tooling (and processes where possible) before IPT approval and authorization for shipment of production parts can be effected. Parts must be revalidated completely, or per Section V whenever any change is made which could possibly affect part function or performance.
- In-Process Test Phase 1 (IP-1) - IP-1 tests are used to demonstrate process capability and must be completed using initial production parts from production tooling and processes prior to first production shipment approval. IP-1 tests are to continue in effect until process capability is demonstrated.
- In-Process Test Phase 2 (IP-2) - IP-2 test program may be implemented only after process capability has been established. Tests must be completed with production parts on a continuing basis. Samples for these tests must be selected on a random basis to represent the entire production population as much as possible. In the event that any of the requirements in these tests is not met, the reaction plan specified in Part Q101 Sect. 3.5, "Engineering Specification (ES) Test Performance Requirements" shall be invoked.

## SECTION III. TABLE OF TESTS

| Item | Test Name<br>Functional<br>Tests | FUNCTION VALIDATION       |                                               | IN-PROCESS IP-1           |                                               | IN-PROCESS IP-2           |                                               |
|------|----------------------------------|---------------------------|-----------------------------------------------|---------------------------|-----------------------------------------------|---------------------------|-----------------------------------------------|
|      |                                  | Minimum<br>Sample<br>Size | Statistical<br>Test<br>Acceptance<br>Criteria | Minimum<br>Sample<br>Size | Statistical<br>Test<br>Acceptance<br>Criteria | Minimum<br>Sample<br>Size | Statistical<br>Test<br>Acceptance<br>Criteria |
| III. |                                  |                           |                                               |                           |                                               |                           |                                               |
| ▽ A  | Calibration                      | 72                        | P90-.96                                       | 100%                      | All Must Pass                                 | 100%                      | All Must Pass                                 |
| B    | Voltage Drop                     | 72                        | P90-.96                                       | 12/No.                    | P90-.84                                       | 4/Lot                     | " " "                                         |
| C    | Current Leakage                  | 72                        | P90-.96                                       | 3/No.                     | P90-.56                                       | 4/Lot                     | " " "                                         |
| D    | Proof Test                       | 72                        | P90-.96                                       | 12/No.                    | P90-.84                                       | 4/Lot                     | " " "                                         |
| F    | Burst                            | 6                         | P90-.72                                       | 3/No.                     | P90-.56                                       | 4/Lot                     | " " "                                         |
| I    | Vibration                        | 6                         | P90-.72                                       | 3/No.                     | P90-.56                                       | 6/6 No.                   | P90-.72                                       |
| J    | Terminal Strength                | 12                        | P90-.84                                       | 6/No.                     | P90-.72                                       | 4/Lot                     | All Must Pass                                 |
| K    | Vacuum                           | 6                         | P90-.72                                       | 3/No.                     | P90-.56                                       | 6/6 No.                   | P90-.72                                       |
| L    | Temperature Cycle                | 6                         | P90-.72                                       | 3/No.                     | P90-.56                                       | 6/6 No.                   | P90-.72                                       |
| M    | Fluid Resistance                 | 36                        | P90-.94                                       | 36/12No.                  | P90-.84                                       | 36/12No.                  | P90-.94                                       |
|      | Reliability Tests                |                           |                                               |                           |                                               |                           |                                               |
| III. |                                  |                           |                                               |                           |                                               |                           |                                               |
| B    | Impulse                          | 24                        | P90-.90                                       | 12/No.                    | P90-.84                                       | 3/3 No.                   | P90-.56                                       |
| C    | Humidity                         | 6                         | P90-.72                                       | 3/No.                     | P90-.56                                       | 6/6 No.                   | P90-.72                                       |
| M    | Salt Spray                       | 6                         | P90-.72                                       | 3/No.                     | P90-.56                                       | 6/6 No.                   | P90-.72                                       |

# Engineering Specification

## PRODUCTION VALIDATION FLOW CHART



## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS

#### ▼ A. Calibration

##### 1. Test Requirements

- a. Switch calibration is to be checked at room temperature ( $15^{\circ}\text{C}$ - $35^{\circ}\text{C}$ ) using ambient air, or equivalent.
- b. Calibration settings shall be specified on the part drawing with the settings checked after 2 or more pressure cycles with ambient air, or equivalent. Pressure cycle range is to be determined by the manufacturer to insure switch calibration stability. The cut-in and differential set points are to be measured while conducting  $750 \pm 50$  milliamperes while  $13.0 \pm 1.0$  volts D.C. is applied. The cut-in point is to be checked with increasing pressure.
- c. The cut-out point is to be checked with decreasing pressure, and the differential set point is to be calculated using the cut-in pressure minus the cut-out pressure.

##### 2. Acceptance Requirements

- a. Nonconformance is defined as any switch point which falls outside the tolerance band specified on the part drawing.

#### B. Voltage Drop

##### 1. Test Requirements

- a. Voltage drop is to be measured after 2 or more cycles with ambient air or equivalent from 0 to  $10,000 \pm 172$  KPa ( $1450 \pm 25$  PSI) while conducting  $750 \pm 50$  milliamperes and  $13.0 \pm 1.0$  volts D.C. is applied to the switch. Under these conditions with the switch closed the voltage drop is to be measured. Millivolt connection interface at terminals to be less than 10 millivolts.

##### 2. Acceptance Requirements

- a. Nonconformance is defined as a voltage drop in excess of 200 millivolts.

## Engineering Specification

### 111. TEST PROCEDURES AND REQUIREMENTS (cont'd)

#### C. Current Leakage

##### 1. Test Requirements

- a. Current leakage is to be checked with 500 volts, 60 Hz alternating current.
- b. Current leakage is to be checked:
  - (1) Between the switch leads with the contacts open.
  - (2) Between the lead and the switch housing with contacts closed.
  - (3) Between either lead and switch housing with the contacts open.

##### 2. Acceptance Requirements

- a. Nonconformance is defined as any leakage current in excess of one hundred (100) microamperes.

#### D. Proof Test

##### 1. Test Requirements

- a. Subject sample switches to Section A to establish their initial switching pressures.
- b. Proof test is to be conducted using brake fluid or equivalent as the pressure medium. Test pressure shall be as specified on the part drawing. Test pressure shall be isolated from pressure source and held for not less than 30 seconds.
- c. Recheck the switches to Section A.

##### 2. Acceptance Requirements

- a. No evidence of fluid leakage, seepage, or drop in test pressure greater than 430 KPa. (62 PSI) is permitted.
- b. A change in cut-in and cut-out pressures greater than  $\pm 5\%$  from the initial value is not permitted.
- c. The test samples must be destroyed after testing.

## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS (cont'd)

#### E. Impulse

##### 1. Test Requirements

- a. Test the switch for a total of 500,000 cycles. Cycle pressure between (low) 0-276 KPa (0-40 psi), and (high)  $10,000 \pm 345$  KPa ( $1450 \pm 50$  psi).
  - 1) 0 - 475,000 cycles:  $13 \pm 1$  volts, trace current to monitor function.
  - 2) 475,001 - 500,000 cycles:  $13 \pm 1$  volts D.C.,  $750 \pm 50$  ma., per figure 4.
- b. Brake fluid temperature to be  $135 \pm 14^{\circ}\text{C}$  and ambient temperature to be  $107^{\circ}\text{C}$  min.
- c. Cycle rate is to be 110-120 cycles per minute.
- d. Switch must open and close each cycle.

##### 2. Acceptance Requirements

- a. After impulse test check to sections A, B, C, & D using the procedure established in each section.
- b. Nonconformance is defined as any switch not meeting the criteria in sections A, B, C, & D.

10c. Samples used for this test must be destroyed after all testing is completed.

#### F. Burst

##### 1. Test Requirements

- a. Burst strength is to be checked using brake fluid or equivalent as the pressure medium.
- b. Pressurize the switch to 48.3 KPa (7000 PSI) minimum and hold for 10 seconds minimum.

##### 2. Acceptance Requirements

- a. Nonconformance is defined as any evidence of fluid leakage or seepage from the switch or threads. Samples used for this test must be destroyed after testing is completed.

## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS (CONT.)

#### G. Humidity

##### 1. Test Requirements

- a. Mount the switch in the test port in a humidity chamber. Currently released mating electrical connector must be installed before start of test.
- b. Subject the switch to  $\pm 10\%$  continuous humidity cycles as follows:
  - (1) Raise temperature to  $45 \pm 10/-2$  °C over 2.5 hours; at 90-98% relative humidity.
  - (2) Hold 3 hours at  $45 \pm 10/-2$  °C at 90-98% relative humidity.
  - (3) Lower temperature to  $25 \pm 10/-2$  °C over 2.5 hours; at 80-98% relative humidity.

##### 2. Acceptance Requirements

- a. Within 15 minutes after completion of the tenth humidity cycle check the switch to sections A, B, C, D, using the procedure established in each section.
- b. Nonconformance is defined as any switch not meeting the criteria in sections A, B, C, or D.

#### H. Salt Spray

##### 1. Test Requirements

- a. Mount the switch in the test port in a salt spray chamber. The currently released mating electrical connector and wiring must be installed prior to start of test.
- b. Expose the switch assembly to 72 hours of salt spray per ASTM B-117.

##### 2. Acceptance Requirements

- a. After exposure, check the switch to sections A, B, C, D, using the procedure established in each section.
- b. Nonconformance is defined as any switch not meeting the criteria in sections A, B, C, or D. Samples used for this test must be destroyed after all testing is completed.

## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS (cont'd)

#### 1. Vibration

##### 1. Test Requirements

- a. Mount the switch in the test port and attach the currently released mating electrical connector before start of test.
- b. Switches are to be vibrated in all 3 planes with electrical continuity being monitored during the entire test. See Figure 1 for switch orientation in the 3 planes. Vibration tests are to be conducted at room temperature using brake fluid, ambient air, or equivalent as the pressure medium.
- c. Internal pressure shall be maintained at 0 MPa G, when the switch is in the closed position and 1.1 times max actuation pressure shown on print when the switch is in the open position.
- d. Vibrate the switch at 1.5 mm displacement (peak-to-peak) while varying the frequency uniformly from 5 to 50 to 5 Hz over a 5 minute period.
- e. Vibrate the switch in alternate one-hour periods in the open and closed positions for a total of 8 hours in each plane. (Total test time is 24 hours).

##### 2. Acceptance Requirements

- a. After the entire vibration sequence check the switches to sections A, B, C, or D using the procedure established in each section.
- b. Nonconformance is defined as any evidence of leakage or any change in electrical continuity/discontinuity during the vibration cycles, or any switch not meeting the criteria in sections A, B, C, or D. Samples used for this test must be destroyed after all testing is completed.



## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS (Cont'd)

#### J. Terminal Strength

##### 1. Test Requirements

- a. Mount the switch in the test port.
  - (1) Apply a  $89 \pm 9$  N axial force to each terminal.
  - (2) With a pendulum apply a  $45 \pm 5$  N impact force to the switch housing at the connector and, perpendicular to the centerline axis of the switch. See Figure 1 for force application point and direction.

##### 2. Acceptance Requirements

- a. Check the switch to sections A, B, C, and D using the procedures established in each section.
- b. Nonconformance is defined as any terminal or housing fracture, or any switch not meeting the criteria in sections A, B, C, or D.

#### K. Vacuum

##### 1. Test Requirements

- a. Mount the switch in the test port. Vacuum tests are to be conducted at room temperature using ambient air as the pressure medium.
- b. Subject the switch to 5 cycles of vacuum from atmospheric pressure (760 mm Hg) to an absolute pressure of 3-6 mm Hg. Maintain the vacuum for a minimum of 60 seconds.

##### 2. Acceptance Requirements

- a. Check the switch to sections A, B, C, and D using the procedure established in each section.
- b. Nonconformance is defined as any switch not meeting the criteria in sections A, B, C, and D.

## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS (cont'd)

#### 1. Temperature Cycle

##### 1. Test Requirements

- a. Mount switches in test ports; test to be run using currently released brake fluid.
- b. Repeat the following procedure 25 times.
  - (1) Lower the switch and fluid temperature to at least  $-40^{\circ}\text{C}$ .
  - (2) Cycle the switches ten times at 10 seconds/cycles. One cycle consists of a pressure variation from 0 - 276 KPa.G (0-40 psi) to  $10,000 \pm 145$  KPa.G ( $1450 \pm 50$  PSI).  
Note: Switch must open and close each cycle.
  - (3) Raise switch and fluid temperature to  $38^{\circ}\text{C}$  minimum.
  - (4) Repeat Step 2.
- c. At completion of Step b, check switches per sections A, B, C, and D.

##### 2. Acceptance Requirements

- a. Nonperformance is defined as any evidence of switch fluid leakage, seepage, or not meeting the criteria of sections A, B, C, and D.

#### X. Fluid Resistance

##### 1. Test Requirements

- a. Mount the switch in the test port and orient as installed in the vehicle.
- b. Install the currently released mating electrical connector (with wire leads) to the switch.
- c. Sequentially, immerse the switch into each of the specified fluids, at a temperature of  $23 \pm 2^{\circ}\text{C}$ , for  $5 \pm 1$  second. Remove the switch and drain and store the switch for the specified time at room temperature, prior to immersing into the next fluid.

## Engineering Specification

### III. TEST PROCEDURES AND REQUIREMENTS (cont'd)

| Fluid                                                                    | Drain Time  | Storage Time |
|--------------------------------------------------------------------------|-------------|--------------|
| Reference Fuel C<br>ASTM D471                                            | 60 ± 5 min. | none         |
| 10W40 Engine Oil                                                         | 24 ± 1 hour | 14 days      |
| Ethylene Glycol/ Water<br>50/50 by Volume                                | 24 ± 1 hour | 24 ± 1 hour  |
| Brake Fluid<br>DOT 3                                                     | 24 ± 1 hour | 48 ± 1 hour  |
| Automatic Transmission/<br>Power Steering Fluid<br>(same) NSF-MIL138-CJ  | 24 ± 1 hour | 14 days      |
| Isopropyl Alcohol/ Water<br>50/50 by Volume                              | 24 ± 1 hour | none         |
| Reference Fuel C,<br>ASTM D471 with<br>Methyl Alcohol<br>85/15 by Volume | 24 ± 1 hour | none         |

- d. For the Flow Chart, subject the prescribed number of immersed switches to the post immersion tests specified below:

- III. E. Impulse
- III. G. Humidity
- III. H. Salt Spray
- III. J. Terminal Strength

#### Acceptance Requirements

- a. Switches must fully meet the requirements of the specified post immersion test.
- b. Nonperformance is defined as any switch not meeting the criteria in sections A, B, C, or D. Samples used for this test must be destroyed after all testing is completed.

## Engineering Specification

### IV. STATISTICAL ANALYSIS METHODS

- A. For PV, IP-1 and IP-2 tests, all samples tested must pass. Having all the required sample size pass will provide data to support the conclusion that the switch has a minimum reliability R, at a given confidence of C. The notation Pa-R is interpreted as minimum reliability equal to R, at a confidence C; thus P90-.80 means a minimum reliability of 80% at 90% confidence.
- B. All samples must pass in the statistical test acceptance criteria stated for tests with 100% frequency; or samples from lots, which could have a variable size.

### V. REVALIDATION REQUIREMENTS

- A. No change in design, material, process or component supplier shall be made without prior approval from the releasing Product Engineering Office. As part of approving a change, the releasing Product Engineering Office will establish the portion of the Product Validation tests required to be run to revalidate the switch. The following table is to be used as a guide in determining the type of tests required for revalidation requirements.

#### ROUTING CHANGE REVALIDATION

| <u>Component</u>                                              | <u>Process or Material Change or New Supplier</u> |
|---------------------------------------------------------------|---------------------------------------------------|
| 1. Terminals, Contacts, or Connector                          | III, B, C, E, G, H, I, J, L, M.                   |
| 2. Case or Housing                                            | All Tests                                         |
| 3. Disc or Diaphragm                                          | III, A, D, E, F, I, K, L.                         |
| 4. Fitting or Fluid Connection                                | III, D, E, F, H, I, M.                            |
| 5. Annual revalidation is not required on carryover switches. |                                                   |

### VI. LOT DEFINITION

A lot is defined as no more than eight (8) hours of production up to 4,000 pieces. If shifts extend beyond eight (8) hours, or more than 4,000 pieces are produced in a shift, the product must be separated into at least two lots.

## Engineering Specification

### VII. RECORD RETENTION

- A. Recording and record retention shall conform with Ford Q-101.
- B. Production Validation test results and analysis are to be forwarded to the releasing Product Engineering Office before approval for shipment of production parts can be granted.
- C. In-process test results shall be available at the supplier's manufacturing facility for the releasing Product Engineering Office and Ford SQA or its representatives to review on request.

### VIII. INSTRUCTIONS AND NOTES

All switches are to be identified with the Ford part number, supplier identification, and a date code indicating final assembly.

All test equipment and test procedures for testing to this specification must be approved by the releasing Product Engineering Office and no change in equipment or procedure may be made without their written concurrence.

Test port configuration is shown in Figure 3.

O-rings, if used in the design, shall be free from cuts, nicks, abrasions or any other damage which would result in a fluid leak.

All switches must have a shipping cap installed over the port threads to prevent contamination. All shipping caps must be approved by the releasing Product Engineering Office prior to production incorporation.

All switches that do not pass the calibration test are to either be readjusted and rechecked, or scrapped. (Salvage of component parts permitted with 100% reinspection).

If product nonconformance occurs for test Sections III, B, C, D, E, F, and J, production shall be stopped and the problems corrected. All production lots shall be sorted 100% prior to shipment. Suspected nonconformance of any shipped parts shall be reported immediately to the releasing Product Engineering Office.

If nonconformance of the statistical acceptance criteria occurs for test Sections III, G, H, I, K, L and M, a cause to recall the subject weeks production and to stop production may result.

## Engineering Specification

### IX. COMPILATION OF REFERENCE DOCUMENTS


ASTM B-117, Salt Spray Testing

Ford Q-101, Quality System Standard - 1990 Edition

EE-702B-14AA64-AA, Specification - SLV Assy - Wire Connector


EE-77VF-9C739-AA, Specification - Servo Assembly Speed Control

**Engineering Specification**



**VIBRATION TEST - SWITCH ORIENTATION**


**FIGURE 1.**



**TERMINAL STRENGTH - LOAD ORIENTATION**

**FIGURE 2.**

**Engineering Specification**



**TEST FIXTURE PORT CONFIGURATION**


**FIGURE 3**

|       |    |         |  |                    |
|-------|----|---------|--|--------------------|
| 17    | 18 |         |  | ▽ 22-2270-27924-1A |
| FRAME | OF | REVISED |  | NUMBER             |

TI-NHTSA 007031



Engineering Specification



TEST SET UP

FIGURE 4

Appendix. 4.2  
Data

TI-NHTSA 007033

|               |                                                                                                                                                                                               |        |
|---------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| TEST LOT NO.  | TEST                                                                                                                                                                                          | DEVICE |
| TESTED BY     | <b>TEXAS</b><br><b>INSTRUMENTS</b>  <b>MATERIALS &amp; CONTROLS</b><br><b>GROUP</b><br>ATTLEBORO, MA 02763 | DOQ.   |
| APPROVED BY   |                                                                                                                                                                                               | PAGE   |
| DATE 02-08-17 |                                                                                                                                                                                               | 12     |

## PRESSURE SWITCH DATA

Form 21605

TEST NO. 245-15-129

|                                      |                           |                              |                       |
|--------------------------------------|---------------------------|------------------------------|-----------------------|
| DEVICE<br>77PSL 2-1, 77PSL 5-2       | DATE REQUESTED<br>9/24/13 | REQUESTED BY<br>S/ma OFF:101 | REQUESTED COMPL. DATE |
| PERFORMED BY<br>Jeffrey D. Bessinger | DATE STARTED<br>9/24/13   | DATE COMPLETED               | APPROVED BY           |
| PROJECT TITLE: Speed Control         |                           |                              |                       |

CUSTOMER:

PURPOSE OF TEST: Production Validation

PROCEDURE: D.E.S.-F200-95924-AA: Full IER

Natural Nonyl Pases

ultra-low diff discs.

Act 90-160

Rel 20 sec

TI-NHTSA 007034

77PSL 3-1

INTERNAL Characterizations

| Device #  | Act | Rel | Mo. Prop | Current Load | Pressure Proof | Act | Rel | Test      | Complete | Test        | Complete |
|-----------|-----|-----|----------|--------------|----------------|-----|-----|-----------|----------|-------------|----------|
| 245-15-01 | 114 | 112 | 4.1      | ✓            | ✓              | 140 | 112 | Fluid Act | ✓        | Impulse     | ✓        |
| -02       | 117 | 115 | 4.1      | ✓            | ✓              | 140 | 113 |           | ✓        |             | ✓        |
| -03       | 113 | 111 | 4.2      | ✓            | ✓              | 140 | 113 |           | ✓        |             | ✓        |
| -04       | 111 | 115 | 5.7      | ✓            | ✓              | 141 | 117 |           | ✓        |             | ✓        |
| -05       | 113 | 117 | 4.1      | ✓            | ✓              | 140 | 113 |           | ✓        |             | ✓        |
| -06       | 114 | 108 | 4.7      | ✓            | ✓              | 142 | 113 |           | ✓        |             | ✓        |
| -07       | 115 | 117 | 4.3      | ✓            | ✓              | 141 | 113 |           | ✓        |             | ✓        |
| -08       | 113 | 107 | 4.8      | ✓            | ✓              | 119 | 112 |           | ✓        |             | ✓        |
| -09       | 110 | 107 | 4.5      | ✓            | ✓              | 142 | 113 |           | ✓        |             | ✓        |
| -10       | 111 | 115 | 3.8      | ✓            | ✓              | 147 | 116 |           | ✓        |             | ✓        |
| -11       | 110 | 114 | 4.9      | ✓            | ✓              | 135 | 118 |           | ✓        |             | ✓        |
| -12       | 116 | 117 | 4.2      | ✓            | ✓              | 131 | 134 |           | ✓        |             | ✓        |
| -13       | 116 | 116 | 3.8      | ✓            | ✓              | 133 | 123 |           | ✓        | Free Sample | ✓        |
| -14       | 107 | 92  | 4.8      | ✓            | ✓              | 138 | 113 |           | ✓        |             | ✓        |
| -15       | 117 | 111 | 3.4      | ✓            | ✓              | 135 | 115 |           | ✓        |             | ✓        |
| -16       | 114 | 111 | 4.1      | ✓            | ✓              | 141 | 111 |           | ✓        |             | ✓        |
| -17       | 114 | 108 | 3.9      | ✓            | ✓              | 141 | 101 |           | ✓        |             | ✓        |
| -18       | 116 | 116 | 3.7      | ✓            | ✓              | 142 | 116 |           | ✓        |             | ✓        |
| -19       | 118 | 116 | 5.3      | ✓            | ✓              | 141 | 118 |           | ✓        |             | ✓        |
| -20       | 113 | 111 | 3.1      | ✓            | ✓              | 141 | 101 |           | ✓        |             | ✓        |
| -21       | 114 | 111 | 3.9      | ✓            | ✓              | 141 | 101 |           | ✓        |             | ✓        |
| -22       | 117 | 105 | 3.8      | ✓            | ✓              | 140 | 115 |           | ✓        |             | ✓        |
| -23       | 116 | 110 | 2.7      | ✓            | ✓              | 143 | 120 |           | ✓        |             | ✓        |
| -24       | 119 | 98  | 3.6      | ✓            | ✓              | 143 | 117 |           | ✓        |             | ✓        |
| -25       | 114 | 110 | 3.1      | ✓            | ✓              | 147 | 110 |           | ✓        | Free diff   | ✓        |
| -26       | 119 | 108 | 3        | ✓            | ✓              | 145 | 117 |           | ✓        |             | ✓        |

| Dr. co # | Art | Art | Hy. Drop | Complete<br>100% | Complete<br>Pigot | Art | Art | Test       | Complete | Test      | Complete |
|----------|-----|-----|----------|------------------|-------------------|-----|-----|------------|----------|-----------|----------|
| MF-10-23 | 124 | 114 | 3.3      | ✓                | ✓                 | 124 | 114 | Phil der   | ✓        | Humidify  | ✓        |
| - 10     | 114 | 104 | 3.3      | ✓                | ✓                 | 124 | 114 |            | ✓        |           | ✓        |
| - 11     | 129 | 114 | 3.9      | ✓                | ✓                 | 129 | 114 |            | ✓        | Soft Soap | ✓        |
| - 12     | 124 | 115 | 2.6      | ✓                | ✓                 | 124 | 115 |            | ✓        |           | ✓        |
| - 13     | 124 | 104 | 2.3      | ✓                | ✓                 | 124 | 104 |            | ✓        |           | ✓        |
| - 14     | 124 | 114 | 2.3      | ✓                | ✓                 | 124 | 114 |            | ✓        |           | ✓        |
| - 15     | 118 | 104 | 2.0      | ✓                | ✓                 | 123 | 113 |            | ✓        |           | ✓        |
| - 16     | 122 | 117 | 2.9      | ✓                | ✓                 | 127 | 115 |            | ✓        |           | ✓        |
| - 17     | 121 | 119 | 3.1      | ✓                | ✓                 | 124 | 118 | Engage     | ✓        | None      | ✓        |
| - 18     | 122 | 118 | 2.6      | ✓                | ✓                 | 126 | 115 |            | ✓        |           | ✓        |
| - 19     | 124 | 125 | 2.6      | ✓                | ✓                 | 125 | 124 |            | ✓        |           | ✓        |
| - 20     | 124 | 112 | 2.7      | ✓                | ✓                 | 129 | 125 |            | ✓        |           | ✓        |
| - 21     | 125 | 112 | 2.8      | ✓                | ✓                 | 127 | 112 |            | ✓        |           | ✓        |
| - 22     | 116 | 106 | 2.7      | ✓                | ✓                 | 120 | 112 |            | ✓        |           | ✓        |
| - 23     | 117 | 106 | 2.7      | ✓                | ✓                 | 127 | 117 |            | ✓        |           | ✓        |
| - 24     | 120 | 101 | 2.7      | ✓                | ✓                 | 131 | 105 |            | ✓        |           | ✓        |
| - 25     | 124 | 124 | 2.7      | ✓                | ✓                 | 125 | 121 |            | ✓        |           | ✓        |
| - 26     | 124 | 114 | 2.4      | ✓                | ✓                 | 120 | 110 |            | ✓        |           | ✓        |
| - 27     | 124 | 117 | 2.7      | ✓                | ✓                 | 123 | 112 |            | ✓        |           | ✓        |
| - 28     | 116 | 107 | 2.7      | ✓                | ✓                 | 123 | 120 |            | ✓        |           | ✓        |
| - 29     | 124 | 112 | 3.7      | ✓                | ✓                 | 127 | 115 | T-Cycle    | ✓        | None      | ✓        |
| - 30     | 122 | 121 | 2.9      | ✓                | ✓                 | 125 | 121 |            | ✓        |           | ✓        |
| - 31     | 122 | 101 | 2.0      | ✓                | ✓                 | 120 | 120 |            | ✓        |           | ✓        |
| - 32     | 127 | 121 | 3.8      | ✓                | ✓                 | 126 | 124 |            | ✓        |           | ✓        |
| - 33     | 127 | 121 | 2.0      | ✓                | ✓                 | 124 | 122 |            | ✓        |           | ✓        |
| - 34     | 121 | 122 | 3.8      | ✓                | ✓                 | 125 | 114 |            | ✓        |           | ✓        |
| - 35     | 122 | 125 | 3.0      | ✓                | ✓                 | 127 | 119 | Vacuum     | ✓        |           | ✓        |
| - 36     | 121 | 114 | 2.8      | ✓                | ✓                 | 128 | 112 |            | ✓        |           | ✓        |
| - 37     | 127 | 117 | 2.7      | ✓                | ✓                 | 120 | 119 |            | ✓        |           | ✓        |
| - 38     | 122 | 111 | 3.2      | ✓                | ✓                 | 120 | 120 |            | ✓        |           | ✓        |
| - 39     | 123 | 112 | 3.1      | ✓                | ✓                 | 125 | 124 |            | ✓        |           | ✓        |
| - 40     | 121 | 117 | 2.4      | ✓                | ✓                 | 123 | 121 |            | ✓        |           | ✓        |
| - 41     | 127 | 119 | 3.8      | ✓                | ✓                 | 124 | 120 | Vibration  | ✓        |           | ✓        |
| - 42     | 127 | 117 | 2.7      | ✓                | ✓                 | 127 | 124 |            | ✓        |           | ✓        |
| - 43     | 128 | 111 | 2.6      | ✓                | ✓                 | 123 | 125 |            | ✓        |           | ✓        |
| - 44     | 128 | 117 | 3.5      | ✓                | ✓                 | 126 | 125 |            | ✓        |           | ✓        |
| - 45     | 121 | 112 | 2.8      | ✓                | ✓                 | 126 | 112 |            | ✓        |           | ✓        |
| - 46     | 118 | 107 | 2.7      | ✓                | ✓                 | 127 | 115 |            | ✓        |           | ✓        |
| - 47     | 122 | 123 | 2.9      | ✓                | ✓                 | 124 | 123 | Boost      | Pass     |           | ✓        |
| - 48     | 126 | 119 | 2.9      | ✓                | ✓                 | 121 | 123 |            | Pass     |           | ✓        |
| - 49     | 128 | 128 | 2.7      | ✓                | ✓                 | 120 | 124 |            | Pass     |           | ✓        |
| - 50     | 119 | 124 | 2.9      | ✓                | ✓                 | 129 | 121 | Boost 7600 | Pass     |           | ✓        |
| - 51     | 127 | 120 | 3.7      | ✓                | ✓                 | 122 | 127 |            | Pass     |           | ✓        |
| - 52     | 125 | 119 | 2.8      | ✓                | ✓                 | 126 | 126 |            | Pass     |           | ✓        |
| - 53     | 125 | 120 | 2.8      | ✓                | ✓                 | 127 | 124 | No used    |          |           | ✓        |
| - 54     | 124 | 118 | 2.9      | ✓                | ✓                 | 128 | 120 |            |          |           | ✓        |
| - 55     | 119 | 112 | 3.4      | ✓                | ✓                 | 126 | 117 |            |          |           | ✓        |
| - 56     | 118 | 102 | 2.4      | ✓                | ✓                 | 121 | 117 |            |          |           | ✓        |
| - 57     | 120 | 104 | 3.1      | ✓                | ✓                 | 126 | 112 |            |          |           | ✓        |
| - 58     | 111 | 101 | 2.4      | ✓                | ✓                 | 125 | 113 |            |          |           | ✓        |
| - 59     | 112 | 105 | 2.9      | ✓                | ✓                 | 127 | 117 |            |          |           | ✓        |
| - 60     | 121 | 124 | 2.7      | ✓                | ✓                 | 126 | 120 |            |          |           | ✓        |

TI-NHTSA 007035

## PRESSURE SWITCH DATA

Form 21605

TEST NO. \_\_\_\_\_

|              |                |                |                       |
|--------------|----------------|----------------|-----------------------|
| DEVICE       | DATE REQUESTED | REQUESTED BY   | REQUESTED COMPL. DATE |
| PERFORMED BY | DATE STARTED   | DATE COMPLETED | APPROVED BY           |

PROJECT TITLE:

CUSTOMER:

PURPOSE OF TEST:

PROCEDURE:

771563-1

Final Characterization

| Device | Set | Flt. Amp | Pass | Recd | Test | Test    | Test | Test | Test |
|--------|-----|----------|------|------|------|---------|------|------|------|
| 121    | 104 | 39.6     | ✓    | ✓    | ✓    | 121-104 |      |      |      |
| 122    | 97  | 39.4     | ✓    | ✓    | ✓    | 122-105 |      |      |      |
| 123    | 102 | 30.6     | ✓    | ✓    | ✓    | 123-108 |      |      |      |
| 124    | 101 | 37.0     | ✓    | ✓    | ✓    | 124-104 |      |      |      |
| 125    | 108 | 25.2     | ✓    | ✓    | ✓    | 125-110 |      |      |      |
| 126    | 95  | 72.1     | ✓    | ✓    | ✓    | 126-97  |      |      |      |
| 127    | 103 | 45.6     | ✓    | ✓    | ✓    | 127-105 |      |      |      |
| 128    | 99  | 12.2     | ✓    | ✓    | ✓    | 128-103 |      |      |      |
| 129    | 96  | 74.3     | ✓    | ✓    | ✓    | 129-105 |      |      |      |
| 130    | 100 | 85.5     | ✓    | ✓    | ✓    | 130-101 |      |      |      |
| 131    | 99  | 25.9     | ✓    | ✓    | ✓    | 131-108 |      |      |      |
| 132    | 102 | 46.8     | ✓    | ✓    | ✓    | 132-105 |      |      |      |
| 133    | 109 | 4.3      | ✓    | ✓    | ✓    | 133-115 |      |      |      |
| 134    | 92  | 2.7      | ✓    | ✓    | ✓    | 134-95  |      |      |      |
| 135    | 107 | 2.8      | ✓    | ✓    | ✓    | 135-115 |      |      |      |
| 136    | 111 | 2.9      | ✓    | ✓    | ✓    | 136-120 |      |      |      |
| 137    | 107 | 3.6      | ✓    | ✓    | ✓    | 137-116 |      |      |      |
| 138    | 99  | 3.2      | ✓    | ✓    | ✓    | 138-105 |      |      |      |
| 139    | 99  | 2.7      | ✓    | ✓    | ✓    | 139-115 |      |      |      |
| 140    | 97  | 3.5      | ✓    | ✓    | ✓    | 140-111 |      |      |      |
| 141    | 80  | 4.7      | ✓    | ✓    | ✓    | 141-122 |      |      |      |
| 142    | 107 | 5.1      | ✓    | ✓    | ✓    | 142-112 |      |      |      |
| 143    | 101 | 7.6      | ✓    | ✓    | ✓    | 143-102 |      |      |      |
| 144    | 103 | 2.5      | ✓    | ✓    | ✓    | 144-114 |      |      |      |
| 145    | 105 | 2.1      | ✓    | ✓    | ✓    | 145-114 |      |      |      |
| 146    | 117 | 5.0      | ✓    | ✓    | ✓    | 146-108 |      |      |      |

TI-NHT8A 007036

| Dist. No. | Lat. | Long. | Alt. | Temp. | Humidity | Wind | Clouds | Pressure   | Remarks |
|-----------|------|-------|------|-------|----------|------|--------|------------|---------|
| 101       | 12.1 | 101.1 | 2.7  | ✓     | ✓        | ✓    | ✓      | 12.1-101.1 |         |
| 102       | 12.2 | 101.2 | 2.8  | ✓     | ✓        | ✓    | ✓      | 12.2-101.2 |         |
| 103       | 12.3 | 101.3 | 2.9  | ✓     | ✓        | ✓    | ✓      | 12.3-101.3 |         |
| 104       | 12.4 | 101.4 | 3.0  | ✓     | ✓        | ✓    | ✓      | 12.4-101.4 |         |
| 105       | 12.5 | 101.5 | 3.1  | ✓     | ✓        | ✓    | ✓      | 12.5-101.5 |         |
| 106       | 12.6 | 101.6 | 3.2  | ✓     | ✓        | ✓    | ✓      | 12.6-101.6 |         |
| 107       | 12.7 | 101.7 | 3.3  | ✓     | ✓        | ✓    | ✓      | 12.7-101.7 |         |
| 108       | 12.8 | 101.8 | 3.4  | ✓     | ✓        | ✓    | ✓      | 12.8-101.8 |         |
| 109       | 12.9 | 101.9 | 3.5  | ✓     | ✓        | ✓    | ✓      | 12.9-101.9 |         |
| 110       | 13.0 | 102.0 | 3.6  | ✓     | ✓        | ✓    | ✓      | 13.0-102.0 |         |
| 111       | 13.1 | 102.1 | 3.7  | ✓     | ✓        | ✓    | ✓      | 13.1-102.1 |         |
| 112       | 13.2 | 102.2 | 3.8  | ✓     | ✓        | ✓    | ✓      | 13.2-102.2 |         |
| 113       | 13.3 | 102.3 | 3.9  | ✓     | ✓        | ✓    | ✓      | 13.3-102.3 |         |
| 114       | 13.4 | 102.4 | 4.0  | ✓     | ✓        | ✓    | ✓      | 13.4-102.4 |         |
| 115       | 13.5 | 102.5 | 4.1  | ✓     | ✓        | ✓    | ✓      | 13.5-102.5 |         |
| 116       | 13.6 | 102.6 | 4.2  | ✓     | ✓        | ✓    | ✓      | 13.6-102.6 |         |
| 117       | 13.7 | 102.7 | 4.3  | ✓     | ✓        | ✓    | ✓      | 13.7-102.7 |         |
| 118       | 13.8 | 102.8 | 4.4  | ✓     | ✓        | ✓    | ✓      | 13.8-102.8 |         |
| 119       | 13.9 | 102.9 | 4.5  | ✓     | ✓        | ✓    | ✓      | 13.9-102.9 |         |
| 120       | 14.0 | 103.0 | 4.6  | ✓     | ✓        | ✓    | ✓      | 14.0-103.0 |         |
| 121       | 14.1 | 103.1 | 4.7  | ✓     | ✓        | ✓    | ✓      | 14.1-103.1 |         |
| 122       | 14.2 | 103.2 | 4.8  | ✓     | ✓        | ✓    | ✓      | 14.2-103.2 |         |
| 123       | 14.3 | 103.3 | 4.9  | ✓     | ✓        | ✓    | ✓      | 14.3-103.3 |         |
| 124       | 14.4 | 103.4 | 5.0  | ✓     | ✓        | ✓    | ✓      | 14.4-103.4 |         |
| 125       | 14.5 | 103.5 | 5.1  | ✓     | ✓        | ✓    | ✓      | 14.5-103.5 |         |
| 126       | 14.6 | 103.6 | 5.2  | ✓     | ✓        | ✓    | ✓      | 14.6-103.6 |         |
| 127       | 14.7 | 103.7 | 5.3  | ✓     | ✓        | ✓    | ✓      | 14.7-103.7 |         |
| 128       | 14.8 | 103.8 | 5.4  | ✓     | ✓        | ✓    | ✓      | 14.8-103.8 |         |
| 129       | 14.9 | 103.9 | 5.5  | ✓     | ✓        | ✓    | ✓      | 14.9-103.9 |         |
| 130       | 15.0 | 104.0 | 5.6  | ✓     | ✓        | ✓    | ✓      | 15.0-104.0 |         |
| 131       | 15.1 | 104.1 | 5.7  | ✓     | ✓        | ✓    | ✓      | 15.1-104.1 |         |
| 132       | 15.2 | 104.2 | 5.8  | ✓     | ✓        | ✓    | ✓      | 15.2-104.2 |         |
| 133       | 15.3 | 104.3 | 5.9  | ✓     | ✓        | ✓    | ✓      | 15.3-104.3 |         |
| 134       | 15.4 | 104.4 | 6.0  | ✓     | ✓        | ✓    | ✓      | 15.4-104.4 |         |
| 135       | 15.5 | 104.5 | 6.1  | ✓     | ✓        | ✓    | ✓      | 15.5-104.5 |         |
| 136       | 15.6 | 104.6 | 6.2  | ✓     | ✓        | ✓    | ✓      | 15.6-104.6 |         |
| 137       | 15.7 | 104.7 | 6.3  | ✓     | ✓        | ✓    | ✓      | 15.7-104.7 |         |
| 138       | 15.8 | 104.8 | 6.4  | ✓     | ✓        | ✓    | ✓      | 15.8-104.8 |         |
| 139       | 15.9 | 104.9 | 6.5  | ✓     | ✓        | ✓    | ✓      | 15.9-104.9 |         |
| 140       | 16.0 | 105.0 | 6.6  | ✓     | ✓        | ✓    | ✓      | 16.0-105.0 |         |
| 141       | 16.1 | 105.1 | 6.7  | ✓     | ✓        | ✓    | ✓      | 16.1-105.1 |         |
| 142       | 16.2 | 105.2 | 6.8  | ✓     | ✓        | ✓    | ✓      | 16.2-105.2 |         |
| 143       | 16.3 | 105.3 | 6.9  | ✓     | ✓        | ✓    | ✓      | 16.3-105.3 |         |
| 144       | 16.4 | 105.4 | 7.0  | ✓     | ✓        | ✓    | ✓      | 16.4-105.4 |         |
| 145       | 16.5 | 105.5 | 7.1  | ✓     | ✓        | ✓    | ✓      | 16.5-105.5 |         |
| 146       | 16.6 | 105.6 | 7.2  | ✓     | ✓        | ✓    | ✓      | 16.6-105.6 |         |
| 147       | 16.7 | 105.7 | 7.3  | ✓     | ✓        | ✓    | ✓      | 16.7-105.7 |         |
| 148       | 16.8 | 105.8 | 7.4  | ✓     | ✓        | ✓    | ✓      | 16.8-105.8 |         |
| 149       | 16.9 | 105.9 | 7.5  | ✓     | ✓        | ✓    | ✓      | 16.9-105.9 |         |
| 150       | 17.0 | 106.0 | 7.6  | ✓     | ✓        | ✓    | ✓      | 17.0-106.0 |         |
| 151       | 17.1 | 106.1 | 7.7  | ✓     | ✓        | ✓    | ✓      | 17.1-106.1 |         |
| 152       | 17.2 | 106.2 | 7.8  | ✓     | ✓        | ✓    | ✓      | 17.2-106.2 |         |
| 153       | 17.3 | 106.3 | 7.9  | ✓     | ✓        | ✓    | ✓      | 17.3-106.3 |         |
| 154       | 17.4 | 106.4 | 8.0  | ✓     | ✓        | ✓    | ✓      | 17.4-106.4 |         |
| 155       | 17.5 | 106.5 | 8.1  | ✓     | ✓        | ✓    | ✓      | 17.5-106.5 |         |
| 156       | 17.6 | 106.6 | 8.2  | ✓     | ✓        | ✓    | ✓      | 17.6-106.6 |         |
| 157       | 17.7 | 106.7 | 8.3  | ✓     | ✓        | ✓    | ✓      | 17.7-106.7 |         |
| 158       | 17.8 | 106.8 | 8.4  | ✓     | ✓        | ✓    | ✓      | 17.8-106.8 |         |
| 159       | 17.9 | 106.9 | 8.5  | ✓     | ✓        | ✓    | ✓      | 17.9-106.9 |         |
| 160       | 18.0 | 107.0 | 8.6  | ✓     | ✓        | ✓    | ✓      | 18.0-107.0 |         |
| 161       | 18.1 | 107.1 | 8.7  | ✓     | ✓        | ✓    | ✓      | 18.1-107.1 |         |
| 162       | 18.2 | 107.2 | 8.8  | ✓     | ✓        | ✓    | ✓      | 18.2-107.2 |         |
| 163       | 18.3 | 107.3 | 8.9  | ✓     | ✓        | ✓    | ✓      | 18.3-107.3 |         |
| 164       | 18.4 | 107.4 | 9.0  | ✓     | ✓        | ✓    | ✓      | 18.4-107.4 |         |
| 165       | 18.5 | 107.5 | 9.1  | ✓     | ✓        | ✓    | ✓      | 18.5-107.5 |         |
| 166       | 18.6 | 107.6 | 9.2  | ✓     | ✓        | ✓    | ✓      | 18.6-107.6 |         |
| 167       | 18.7 | 107.7 | 9.3  | ✓     | ✓        | ✓    | ✓      | 18.7-107.7 |         |
| 168       | 18.8 | 107.8 | 9.4  | ✓     | ✓        | ✓    | ✓      | 18.8-107.8 |         |
| 169       | 18.9 | 107.9 | 9.5  | ✓     | ✓        | ✓    | ✓      | 18.9-107.9 |         |
| 170       | 19.0 | 108.0 | 9.6  | ✓     | ✓        | ✓    | ✓      | 19.0-108.0 |         |
| 171       | 19.1 | 108.1 | 9.7  | ✓     | ✓        | ✓    | ✓      | 19.1-108.1 |         |
| 172       | 19.2 | 108.2 | 9.8  | ✓     | ✓        | ✓    | ✓      | 19.2-108.2 |         |
| 173       | 19.3 | 108.3 | 9.9  | ✓     | ✓        | ✓    | ✓      | 19.3-108.3 |         |
| 174       | 19.4 | 108.4 | 10.0 | ✓     | ✓        | ✓    | ✓      | 19.4-108.4 |         |
| 175       | 19.5 | 108.5 | 10.1 | ✓     | ✓        | ✓    | ✓      | 19.5-108.5 |         |
| 176       | 19.6 | 108.6 | 10.2 | ✓     | ✓        | ✓    | ✓      | 19.6-108.6 |         |
| 177       | 19.7 | 108.7 | 10.3 | ✓     | ✓        | ✓    | ✓      | 19.7-108.7 |         |
| 178       | 19.8 | 108.8 | 10.4 | ✓     | ✓        | ✓    | ✓      | 19.8-108.8 |         |
| 179       | 19.9 | 108.9 | 10.5 | ✓     | ✓        | ✓    | ✓      | 19.9-108.9 |         |
| 180       | 20.0 | 109.0 | 10.6 | ✓     | ✓        | ✓    | ✓      | 20.0-109.0 |         |
| 181       | 20.1 | 109.1 | 10.7 | ✓     | ✓        | ✓    | ✓      | 20.1-109.1 |         |
| 182       | 20.2 | 109.2 | 10.8 | ✓     | ✓        | ✓    | ✓      | 20.2-109.2 |         |
| 183       | 20.3 | 109.3 | 10.9 | ✓     | ✓        | ✓    | ✓      | 20.3-109.3 |         |
| 184       | 20.4 | 109.4 | 11.0 | ✓     | ✓        | ✓    | ✓      | 20.4-109.4 |         |
| 185       | 20.5 | 109.5 | 11.1 | ✓     | ✓        | ✓    | ✓      | 20.5-109.5 |         |
| 186       | 20.6 | 109.6 | 11.2 | ✓     | ✓        | ✓    | ✓      | 20.6-109.6 |         |
| 187       | 20.7 | 109.7 | 11.3 | ✓     | ✓        | ✓    | ✓      | 20.7-109.7 |         |
| 188       | 20.8 | 109.8 | 11.4 | ✓     | ✓        | ✓    | ✓      | 20.8-109.8 |         |
| 189       | 20.9 | 109.9 | 11.5 | ✓     | ✓        | ✓    | ✓      | 20.9-109.9 |         |
| 190       | 21.0 | 110.0 | 11.6 | ✓     | ✓        | ✓    | ✓      | 21.0-110.0 |         |
| 191       | 21.1 | 110.1 | 11.7 | ✓     | ✓        | ✓    | ✓      | 21.1-110.1 |         |
| 192       | 21.2 | 110.2 | 11.8 | ✓     | ✓        | ✓    | ✓      | 21.2-110.2 |         |
| 193       | 21.3 | 110.3 | 11.9 | ✓     | ✓        | ✓    | ✓      | 21.3-110.3 |         |
| 194       | 21.4 | 110.4 | 12.0 | ✓     | ✓        | ✓    | ✓      | 21.4-110.4 |         |
| 195       | 21.5 | 110.5 | 12.1 | ✓     | ✓        | ✓    | ✓      | 21.5-110.5 |         |
| 196       | 21.6 | 110.6 | 12.2 | ✓     | ✓        | ✓    | ✓      | 21.6-110.6 |         |
| 197       | 21.7 | 110.7 | 12.3 | ✓     | ✓        | ✓    | ✓      | 21.7-110.7 |         |
| 198       | 21.8 | 110.8 | 12.4 | ✓     | ✓        | ✓    | ✓      | 21.8-110.8 |         |
| 199       | 21.9 | 110.9 | 12.5 | ✓     | ✓        | ✓    | ✓      | 21.9-110.9 |         |
| 200       | 22.0 | 111.0 | 12.6 | ✓     | ✓        | ✓    | ✓      | 22.0-111.0 |         |
| 201       | 22.1 | 111.1 | 12.7 | ✓     | ✓        | ✓    | ✓      | 22.1-111.1 |         |
| 202       | 22.2 | 111.2 | 12.8 | ✓     | ✓        | ✓    | ✓      | 22.2-111.2 |         |
| 203       | 22.3 | 111.3 | 12.9 | ✓     | ✓        | ✓    | ✓      | 22.3-111.3 |         |
| 204       | 22.4 | 111.4 | 13.0 | ✓     | ✓        | ✓    | ✓      | 22.4-111.4 |         |
| 205       | 22.5 | 111.5 | 13.1 | ✓     | ✓        | ✓    | ✓      | 22.5-111.5 |         |
| 206       | 22.6 | 111.6 | 13.2 | ✓     | ✓        | ✓    | ✓      | 22.6-111.6 |         |
| 207       | 22.7 | 111.7 | 13.3 | ✓     | ✓        | ✓    | ✓      | 22.7-111.7 |         |
| 208       | 22.8 | 111.8 | 13.4 | ✓     | ✓        | ✓    | ✓      | 22.8-111.8 |         |
| 209       | 22.9 | 111.9 | 13.5 | ✓     | ✓        | ✓    | ✓      | 22.9-111.9 |         |
| 210       | 23.0 | 112.0 | 13.6 | ✓     | ✓        | ✓    | ✓      | 23.0-112.0 |         |
| 211       | 23.1 | 112.1 | 13.7 | ✓     | ✓        | ✓    | ✓      | 23.1-112.1 |         |
| 212       | 23.2 | 112.2 | 13.8 | ✓     | ✓        | ✓    | ✓      | 23.2-112.2 |         |
| 213       | 23.3 | 112.3 | 13.9 | ✓     | ✓        | ✓    | ✓      | 23.3-112.3 |         |
| 214       | 23.4 | 112.4 | 14.0 | ✓     | ✓        | ✓    | ✓      | 23.4-112.4 |         |
| 215       | 23.5 | 112.5 | 14.1 | ✓     | ✓        | ✓    | ✓      | 23.5-112.5 |         |
| 216       | 23.6 | 112.6 | 14.2 | ✓     | ✓        | ✓    | ✓      | 23.6-112.6 |         |
| 217       | 23.7 | 112.7 | 14.3 | ✓     | ✓        | ✓    | ✓      | 23.7-112.7 |         |
| 218       | 23.8 | 112.8 | 14.4 | ✓     | ✓        | ✓    | ✓      | 23.8-112.8 |         |
| 219       | 23.9 | 112.9 | 14.5 | ✓     | ✓        | ✓    | ✓      | 23.9-112.9 |         |
| 220       | 24.0 | 113.0 | 14.6 | ✓     | ✓        | ✓    | ✓      | 24.0-113.0 |         |
| 221       | 24.1 | 113.1 | 14.7 | ✓     | ✓        | ✓    | ✓      | 24.1-113.1 |         |
| 222       | 24.2 | 113.2 | 14.8 | ✓     | ✓        | ✓    | ✓      | 24.2-113.2 |         |
| 223       | 24.3 | 113.3 | 14.9 | ✓     | ✓        | ✓    | ✓      | 24.3-113.3 |         |
| 224       | 24.4 | 113.4 | 15.0 | ✓     | ✓        | ✓    | ✓      | 24.4-113.4 |         |
| 225       | 24.5 | 113.5 | 15.1 | ✓     | ✓        | ✓    | ✓      | 24.5-113.5 |         |
| 226       | 24.6 | 113.6 | 15.2 | ✓     | ✓        | ✓    | ✓      | 24.6-113.6 |         |
| 227       | 24.7 | 113.7 | 15.3 | ✓     | ✓        | ✓    | ✓      | 24.7-113.7 |         |
| 228       | 24.8 | 113.8 | 15.4 | ✓     | ✓        | ✓    | ✓      | 24.8-113.8 |         |
| 229       | 24.9 | 113.9 | 15.5 | ✓     | ✓        | ✓    | ✓      | 24.9-113.9 |         |
| 230       | 25.0 | 114.0 | 15.6 | ✓     | ✓        | ✓    | ✓      | 25.0-114.0 |         |
| 231       | 25.1 | 114.1 | 15.7 | ✓     | ✓        | ✓    | ✓      | 25.1-114.1 |         |
| 232       | 25.2 | 114.2 | 15.8 | ✓     | ✓        | ✓    | ✓      | 25.2-114.2 |         |
| 233       | 25.3 | 114.3 | 15.9 | ✓     | ✓        | ✓    | ✓      | 25.3-114.3 |         |
| 234       | 25.4 | 114.4 | 16.0 | ✓     | ✓        | ✓    | ✓      | 25.4-114.4 |         |
| 235       | 25.5 | 114.5 | 16.1 | ✓     | ✓        | ✓    | ✓      | 25.5-114.5 |         |
| 236       | 25.6 | 114.6 | 16.2 | ✓     | ✓        | ✓    | ✓      | 25.6-114.6 |         |
| 237       | 25.7 | 114.7 | 16.3 | ✓     | ✓        | ✓    | ✓      | 25.7-114.7 |         |
| 238       | 25.8 | 114.8 | 16.4 | ✓     | ✓        | ✓    | ✓      | 25.8-114.8 |         |
| 239       | 25.9 | 114.9 | 16.5 | ✓     | ✓        | ✓    | ✓      | 25.9-114.9 |         |
| 240       | 26.0 | 115.0 | 16.6 | ✓     | ✓        | ✓    | ✓      | 26.0-115.0 |         |
| 241       | 26.1 | 115.1 | 16.7 | ✓     | ✓        | ✓    | ✓      | 26.1-115.1 |         |
| 242       | 26.2 | 115.2 | 16.8 | ✓     | ✓        | ✓    | ✓      | 26.2-115.2 |         |
| 243       | 26.3 | 115.3 | 16.9 | ✓     | ✓        | ✓    | ✓      | 26.3-115.3 |         |
| 244       | 26.4 | 115.4 | 17.0 | ✓     | ✓        | ✓    | ✓      | 26.4-115.4 |         |
| 245       | 26.5 | 115.5 | 17.1 | ✓     | ✓        | ✓    | ✓      | 26.5-115.5 |         |
| 246       | 26.6 | 115.6 | 17.2 | ✓     | ✓        | ✓    | ✓      | 26.6-115.6 |         |
| 247       | 26.7 | 115.7 | 17.3 | ✓     | ✓        | ✓    | ✓      | 26.7-115.7 |         |
| 248       | 26.8 | 115.8 | 17.4 | ✓     | ✓        | ✓    | ✓      | 26.8-115.8 |         |
| 249       | 26.9 | 115.9 | 17.5 | ✓     | ✓        | ✓    | ✓      | 26.9-115.9 |         |
| 250       | 27.0 |       |      |       |          |      |        |            |         |

Appendix 4.3  
Noise Pressure Trace

TI-NHT&A 007038

|               |                                                                                                                                                                          |         |
|---------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------|
| TEST LOT NO.  | TEST                                                                                                                                                                     | DEVICE  |
| TESTED BY     |                                                                                                                                                                          |         |
| APPROVED BY   |                                                                                                                                                                          | DOC.    |
| DATE 02-08-12 | <b>TEXAS INSTRUMENTS</b>  <b>MATERIALS &amp; CONTROL GROUP</b><br>ATTLEBORO, MA 02703 | PAGE 18 |

77PSL3-1

F2AC-9F924-AA

"QUIET"




FIGURE 3



MATERIAL  
ANALYSIS

TI-NHTSA 007040

TEXAS  
INSTRUMENTS

## CERTIFICATION OF COMPLIANCE TEST

CUSTOMER: DANA CORPORATION

CUSTOMER ORDER NO.:

TI ORDER NO.:

F2AC-9F924-AA

CUSTOMER PART NO.:

77PSL3-1

TI PART NO.:

CUSTOMER SPEC: \_\_\_\_\_ TI SR: \_\_\_\_\_

QUANTITY: 6 pcs DATE SHIPPED: 8/20/92

IT IS HEREBY CERTIFIED THAT THE GOODS SPECIFIED ABOVE CONFORM TO THE  
TI ORDER SHOWN ABOVE, AS REVISED BY MUTUALLY AGREED WRITTEN AMENDMENTS,  
IF ANY. Further, component parts utilized have been scrutinized  
and do not violate Ford Engineering Materials Specifications  
WSS-M99P8999-A1/A2/A3 restrictions.

J. M. Math, Asst Engr.  
PRECISION CONTROLS QUALITY CONTROLDATED: 8/20/92

TEXAS  
INSTRUMENTS

## CERTIFICATION OF COMPLIANCE TEST

CUSTOMER: DANA CORPORATION

CUSTOMER ORDER NO.:

TI ORDER NO.:

F2AC-9F924-AA77P8L3-1

CUSTOMER PART NO.:

TI PART NO.:

CUSTOMER SPEC: \_\_\_\_\_

TI SR: \_\_\_\_\_

QUANTITY: 6 pcsDATE SHIPPED: 8/20/92

IT IS HEREBY CERTIFIED THAT THE GOODS SPECIFIED ABOVE CONFORM TO THE  
TI ORDER SHOWN ABOVE, AS REVISED BY MUTUALLY AGREED WRITTEN AMENDMENTS,  
IF ANY. Further, component parts utilized have been scrutinized  
and do not violate Ford Engineering Materials Specifications  
WSS-M99P9999-A1/A2/A3 restrictions.

J. L. Math, Asst Engr.  
PRECISION CONTROLS QUALITY CONTROLDATED: 8/20/92

TI-NHTSA 007042

F2AC-9F924-AA

MATERIAL ANALYSIS

PARTS LIST

|    | PART NAME     | PART #     | CERTIFIED |
|----|---------------|------------|-----------|
| 1  | BASE          | 46513-3    | YES       |
| 2  | STA. TERM.    | 36889-1    | YES       |
| 3  | MOVE. CONTACT | 74408-1    | YES       |
| 4  | RIVET         | 74171-1    | YES       |
| 5  | MOVE. TERM.   | 36887-1    | YES       |
| 6  | SPRING ARM    | 36889-1    | YES       |
| 7  | J512 HEXPORT  | 36900-1    | YES       |
| 8  | GASKET        | 74353-1    | YES       |
| 9  | CUP           | 27713-1    | YES       |
| 10 | SEAL          | 74176-1    | YES       |
| 11 | KAPTON STRIP  | 27225-1    | YES       |
| 12 | WASHER        | 27639-1    | YES       |
| 13 | CONVERTER     | 27406-1    | YES       |
| 14 | KAPTON TAPE   | 74224-1    | YES       |
| 15 | SPACER        | 73958-2/-3 | YES       |
| 16 | CRIMP RING    | 74797-1    | YES       |
| 17 | TRANSFER PIN  | 74078-BEL  | YES       |
| 18 | ENVIO. SEAL   | 74247-4    | YES       |

TI-NHTSA 007043