

RECEIVED
2007 OCTOBER 1 9:00A
DEFECTS INVESTIGATION
RECALL MGMT DIV.

07E-076



Cummins Power Generation
1400 73rd Avenue NE
Fridley, Minnesota
55432 USA

September 26, 2007

***** IMPORTANT SAFETY NOTICE *****

Dear Customer:

This notice is sent to you in accordance with the requirements of the National Traffic and Motor Vehicle Safety Act.

Cummins Inc. has decided that a defect which relates to motor vehicle safety exists in Cummins Onan Quiet Diesel 3200 generator sets that were shipped between May 21, 2007 and August 27, 2007 and installed in Winnebago View and Itasca Navion motorhomes built between June 11, 2007 and August 3, 2007. We believe that your recreational vehicle is included in that group. The specific information is as follows:

Generator Serial Number: E07F000035
Vehicle Manufacturer: Winnebago
Vehicle Identification Number: WDXPF445679340522

The defect affects the controller that is located within the generator housing. Should the generator's internal controller fail and its electrical circuits remain energized beyond the designed period, the preheater element which aids cold starts can overheat and could cause a fire in the generator air intake system.

Cummins Onan has identified a remedy that resolves the safety issue and allows you to use your generator as intended to minimize the disruption to you. The campaign repair involves replacement of components located within the generator (including replacement of the generator controller). If you have not already done so, please contact your dealer or distributor to schedule a repair. This repair will be performed free of charge. This repair should take approximately 3 hours to complete, but you may have your unit out of service for up to 1 day. We urge you to contact your nearest Cummins authorized repair location to conduct this campaign. You may also contact the Cummins Onan Customer Assistance Center at 1-800-888-ONAN (1-800-888-6626).

If you are a lessor of vehicles with generator sets that are in the affected population, Federal Law requires vehicle lessors receiving this recall notice to forward a copy of this

Cummins Power Generation
1400 73rd Avenue N.E.
Minneapolis, MN 55432 USA
Phone 1 763 574 5000
cumminspower.com

notice to the lessee within ten (10) days. You may be eligible to receive a reimbursement for the cost of obtaining a pre-notification remedy related to this recall. Please note our contact number below.

If you have a complaint relative to this campaign, you may report it to the following:

Administrator, National Highway Traffic Safety Administration
1200 New Jersey Avenue, S.E.
Washington, DC 20590

Or, you may call the toll free Auto Safety Hotline at 1-888-327-4236 (TTY: 1-800-424-9153); or go to <http://www.safercar.gov>.

We apologize for the inconvenience this campaign may cause. Cummins is initiating this action because of the sense of responsibility Cummins has for customer safety and customer satisfaction with our products. Thank you for your attention to this matter.

Sincerely,



Dave Sollars,
Manager Field Service
Cummins Onan Branded Products
Cummins Inc.