



Abilene
4601 Hartford
Abilene, Texas
79605-4699
325 793 3400

San Angelo
3001 South Jackson
San Angelo, Texas
76904-5129
325-223 6300

Ozona
908 1st Street
P.O. Box 728
Ozona, Texas
76943
325-392-9872

SAFETY RECALL NOTICE

"Date"

Carrie Neathery
1527 CR 165
Rochester, TX 79544

RE: Safety Standard Non-Compliance Recall Notification Ricon #07E-095

This notice is sent to you in accordance with the requirements of the National Traffic and Motor Vehicle Safety Act.

Ricon Wheelchair Lift Serial #195802/Model#S1200

Dear Sir:

West Texas Rehab Center has decided that certain Ricon Wheelchair Lifts fail to conform to Federal Motor Vehicle Safety Standard No. 110, "Platform lift systems for motor vehicles". Our records show that you may have a vehicle altered by West Texas Rehab Center that has a wheelchair lift built by Ricon Corporation between April 1, 2005 and October 9, 2007, inclusive. Ricon Corporation has determined that a safety related non-compliance with Section 6.1 of the FMVSS 403 exists in these wheelchair lifts.

! IMPORTANT !

Your Ricon Wheelchair Lift is being recalled

Contact West Texas Rehab Center or The Ricon Corporation immediately

WHAT IS BEING RECALLED:

This recall process applies to the "Threshold Warning System" only on Ricon's "1200, 2000 and 5000" series platform lifts labeled for "DOT Public Use" and "DOT Private Use". It does not apply to other Ricon products.

WHY IS IT BEING RECALLED:

The non-compliance with S6.1 of the FMVSS 403 is the result of the Threshold Warning System not detecting the presence of a wheelchair or mobility aid user in a certain spot within the defined threshold area. In the event this condition occurs during passenger operations the wheelchair or mobility aid user may move toward the vehicle lift door when the lift platform is below floor level. This situation could cause personal injury.

WHAT YOU AS THE OWNER SHOULD DO:

Immediately contact the Ricon Corporation to be directed to the nearest Ricon dealer or repair agent. You can do so by calling Ricon Customer Service at (800)322-2884, emailing at www.Marketing@riconcorp.com or you can locate the nearest servicing dealer using the Ricon Dealer Locator on the Ricon website – www.riconcorp.com

WHAT WE WILL DO:

West Texas Rehab Center, in cooperation with Ricon, will direct you to the nearest servicing Ricon dealer that will repair the non-compliance at no cost to you. If the lift is repaired or retrofitted by an authorized Ricon dealer and it is not completed within 3 business days from when started, please notify Ricon Customer Support at the toll free number listed above.

If after attempting to have your vehicle repaired you believe you have not been able to have your vehicle remedied without charge and within a reasonable amount of time, you may submit a complaint to the Administrator, National Highway Traffic Safety Administration, 1200 New Jersey Ave., S.E., Washington, D.C., 20590; or call the toll-free Vehicle Safety Hotline at 1-(888)327-4236(TTY: 1-800-424-9153); or go to <http://www.safercar.gov>

Thank you for your prompt attention to this matter. If you have any questions concerning these procedures please contact Ricon Customer Service at (800)322-2884 or by email at www.Marketing@riconcorp.com. You may also contact West Texas Rehab Center at 325-793-3546 or www.dsmith@wtrc.com with any questions or concerns.

We apologize for any inconvenience this safety recall may cause, but your safety is our first concern.

Sincerely,

West Texas Rehab Center