



Abilene  
4601 Hartford  
Abilene, Texas  
79605-4699  
325-793-3400

San Angelo  
3001 South Jackson  
San Angelo, Texas  
76904-5129  
325-223-6300

Ozona  
908 1st Street  
P.O. Box 728  
Ozona, Texas  
76943  
325-392-9872

## **SAFETY RECALL NOTICE**

"Date"

Carrie Neathery  
1527 CR 165  
Rochester, TX 79544

RE: Safety Standard Non-Compliance Recall Notification Ricon #07E-097

This notice is sent to you in accordance with the requirements of the National Traffic and Motor Vehicle Safety Act.

Ricon Wheelchair Lift Serial #195802/Model#S1200

Dear Sir:

West Texas Rehab Center has decided that certain Ricon Wheelchair Lifts fail to conform to Federal Motor Vehicle Safety Standard No. 110, "Platform lift systems for motor vehicles". Our records show that you may have a vehicle altered by West Texas Rehab Center that has a wheelchair lift built by Ricon Corporation between April 1, 2005 and September 6, 2006, inclusive. Ricon Corporation has determined that a safety related non-compliance with Section 6.10.2.3 of the FMVSS 403 exists in these wheelchair lifts.

### **! IMPORTANT !**

Your Ricon Wheelchair Lift is being recalled

Contact West Texas Rehab Center or The Ricon Corporation immediately

#### **WHAT IS BEING RECALLED:**

This recall process applies to the "Anti Stow Interlock System" only on Ricon's "1200, 2000 and 5000" series platform lifts labeled for "DOT Public Use" and "DOT Private Use". It does not apply to other Ricon products.

**WHY IS IT BEING RECALLED:**

The non-compliance with S6.10.2.3 of the FMVSS 403 is the result of the Anti Stow Interlock System not detecting the presence of a 50lb test weight on the platform operating volume. In the event this condition occurs during passenger operations it may be possible for the lift platform to begin stowing while a wheelchair or mobility aid user is still occupying the area of the platform close to the pivot point on the platform. This situation could cause personal injury.

**WHAT YOU AS THE OWNER SHOULD DO:**

Immediately contact the Ricon Corporation to be directed to the nearest Ricon dealer or repair agent. You can do so by calling Ricon Customer Service at (800)322-2884, emailing at [www.Marketing@riconcorp.com](mailto:www.Marketing@riconcorp.com) or you can locate the nearest servicing dealer using the Ricon Dealer Locator on the Ricon website – [www.riconcorp.com](http://www.riconcorp.com)

**WHAT WE WILL DO:**

West Texas Rehab Center, in cooperation with Ricon, will direct you to the nearest servicing Ricon dealer that will repair the non-compliance at no cost to you. If the lift is repaired or retrofitted by an authorized Ricon dealer and it is not completed within 3 business days from when started, please notify Ricon Customer Support at the toll free number listed above.

If after attempting to have your vehicle repaired you believe you have not been able to have your vehicle remedied without charge and within a reasonable amount of time, you may submit a complaint to the Administrator, National Highway Traffic Safety Administration, 1200 New Jersey Ave., S.E., Washington, D.C., 20590; or call the toll-free Vehicle Safety Hotline at 1-(888)327-4236(TTY: 1-800-424-9153); or go to <http://www.safercar.gov>

Thank you for your prompt attention to this matter. If you have any questions concerning these procedures please contact Ricon Customer Service at (800)322-2884 or by email at [www.Marketing@riconcorp.com](mailto:www.Marketing@riconcorp.com). You may also contact West Texas Rehab Center at 325-793-3546 or [www.dsmith@wtrc.com](mailto:www.dsmith@wtrc.com) with any questions or concerns.

We apologize for any inconvenience this safety recall may cause, but you safety is our first concern.

Sincerely,

West Texas Rehab Center