

GM CUSTOMER CARE AND AFTERSALES

DCS2390

URGENT - DISTRIBUTE IMMEDIATELY

Date: April 6, 2010

Subject: 10091A – Safety Recall
Voltage Regulator Internal Low Resistance Short
Revised Parts Information and Service Procedure Sections

Models: 2010 Chevrolet Express, GMC Savana 2500/3500/4500 Series
Vehicles Equipped with 145 Amp Generator (RPO KG3/KD9)

To: All Chevrolet and GMC Dealers

Attention: General Manager, Service Manager, Parts Manager,
New Car Vehicle Manager, and Warranty Administrator

The Parts Information and Service Procedure sections in bulletin 10091A have been revised.
Please review the revised information immediately.

Please discard all copies of bulletin 10091, issued March 2010.

END OF MESSAGE

GM CUSTOMER CARE AND AFTERSALES

Nothing in this message is intended to constitute an electronic signature unless a specific statement to the contrary is included in this message.

Confidentiality Note: This message is intended only for the person or entity to which it is addressed. It may contain confidential and/or privileged material. Any review, transmission, dissemination or other use, or taking of any action in reliance upon this message by persons or entities other than the intended recipient is prohibited and may be unlawful. If you received this message in error, please contact the sender and delete it from your computer.