

Glaval Bus Recall Instructions

914 COUNTY ROAD 1 N.
ELKHART, INDIANA 46514
800-445-2825 OR 574-262-2212

E-mail glavalcustomerservice@forestriverinc.com

Contact: Glaval Bus Customer Service

Units Involved: Glaval Bus Entourage Built between 7-10-09 and shipped before 11-01-10

Problem: Fire suppression nozzle location..

Solution: Relocate nozzle to engine compartment.

Time Allowance 1 hours

Instructions

Locate lower dash Access Panel:

1. Remove access panel under steering column.
2. Locate fire suppression nozzle on right side of steering column, above fuel pedal.
3. Remove p-clamp and push through to engine compartment side.



4. locate sensors making sure they are mounted in the engine compartment.

Picture 2 and 3 are the sensors found mounted to both sides of the valve covers in the engine compartment.



5. Locate fire suppression hose tee under the hood.

6. Shorten the inlet hose and reposition the passenger side hose and nozzle.

7. Reclamp all of the hoses.

Pictures 4 and 5 are pictures of the hoses mounted in the new locations under the hood.



Picture 6 is a full under hood view of the hoses rerouted and p-clamped in place.



Picture 7 is of passenger side nozzle location.



Picture 8 is of drivers side nozzle location.



8. Seal the hole in the firewall where hose was removed.
 9. Replace all covers and panels remove for access.
 10. contact Glaval Bus Customer Service for any issues.
- 1-800-445-2825 or **E-mail** glavalcustomerservice@forestriverinc.com