

# Part 573 Safety Recall Report

# 17V-264

**Manufacturer Name :** Thor Motor Coach**Submission Date :** APR 20, 2017**NHTSA Recall No. :** 17V-264**Manufacturer Recall No. :** RC000135**Manufacturer Information :**

Manufacturer Name : Thor Motor Coach

Address : PO Box 1486

701 County Road 15 Elkhart IN 46516

Company phone : 877-500-1020

**Population :**

Number of potentially involved : 36

Estimated percentage with defect : 100 %

**Vehicle Information :**

Vehicle 1 : 2017-2017 Quantum KM24

Vehicle Type : BUSES, MEDIUM &amp; HEAVY VEHICLES

Body Style : OTHER

Power Train : DIESEL

**Descriptive Information :** It has been discovered that on certain model year 2017 Quantum K24 motorhomes that the 12 gauge step wire was installed on the 50 amp breaker instead of the 20 amp breaker.

Production Dates : JAN 11, 2017 - MAR 03, 2017

VIN Range 1 : Begin :

NR

End : NR

 Not sequential**Description of Defect :**

**Description of the Defect :** The 12 gauge step wire on certain Quantum KM24 motorhomes was installed on the 50 amp breaker instead of the 20 amp breaker

FMVSS 1 : NR

FMVSS 2 : NR

**Description of the Safety Risk :** Should the step wire face an overload condition, the breaker will not trip at the appropriate amperage which may lead to property damage and/or a fire.

**Description of the Cause :** The 12 gauge wire was installed incorrectly at time of production.

**Identification of Any Warning** NA  
that can Occur :

**Supplier Identification :****Component Manufacturer**

Name : NR

Address : NR

NR

Country : NR

**Chronology :**

4/7/2017 During a routine inspection an auditor noticed that the 12 gauge step wire on a Quantum motorhome was attached to the incorrect breaker. After inspection of further units it was determined that only the KM24 motorhomes were involved.

4/12/2017 Scope was determined and it was decided that a recall was appropriate.

**Description of Remedy :**

Description of Remedy Program : TMC will provide instructions for attaching the 12 gauge step wire to the correct breaker. Reimbursement will be provided through the normal warranty claim process.

How Remedy Component Differs from Recalled Component : NA

Identify How/When Recall Condition was Corrected in Production : The 12 gauge step wire was properly installed on the 20 amp breaker as of 4/7/2017

**Recall Schedule :**

Description of Recall Schedule : NR

Planned Dealer Notification Date : JUN 07, 2017 - JUN 07, 2017

Planned Owner Notification Date : JUN 07, 2017 - JUN 07, 2017

\* NR - Not Reported