

**Recall Annual Report****20V-131**

**Manufacturer Name :** Halcore Group, Inc.  
**NHTSA Recall No. / MFR Recall No. :** 20V-131 /  
**Recall Subject :** Undersized A/C Input Power Cord May Cause Short  
**Owner Notification Beginning Date :** APR 27, 2020  
**Owner Notification End Date:** APR 30, 2020

**Annual Reports**

Report #	Submission Date	Report Year	Recall Population	Total Remedied	Total Unreachable	Total Removed
1	JUN 29, 2023	2023	8	8	0	0

**Quarterly Reports**

Report #	Submission Date	Report Quarter	Recall Population	Total Remedied	Total Unreachable	Total Removed
9	AUG 31, 2022	2022-2	8	7	0	0
8	AUG 31, 2022	2022-1	8	7	0	0
7	AUG 31, 2022	2021-4	8	7	0	0
6	AUG 31, 2022	2021-3	8	7	0	0
5	JUL 30, 2021	2021-2	8	7	0	0
4	JUN 22, 2021	2021-1	8	5	0	0
3	FEB 23, 2021	2020-4	8	3	0	0
2	SEP 23, 2020	2020-3	8	2	0	0
1	AUG 06, 2020	2020-2	8	2	0	0

This Document Last Updated : JUN 29, 2023

**Definitions :**

**Report Year :** The report year the manufacturer is reporting recall completion figures.

**Report Quarter :** The quarter the manufacturer is reporting recall completion figures (e.g. 2012-3 means the 3<sup>rd</sup> quarter of 2012).

**Recall Population :** The total number of products recalled by the manufacturer.

**Total Remedied :** The total number of products either remedied, inspected without needing remedy, or returned to inventory.

**Total Unreachable :** Products deemed unreachable as owner notifications were unable to be delivered.

**Total Removed :** Products that have been scrapped, stolen, or exported.