

Part 573 Safety Recall Report

21V-397

Manufacturer Name : KZRV, L.P.**Submission Date :** MAY 26, 2021**NHTSA Recall No. :** 21V-397**Manufacturer Recall No. :** KZ-2021-02**Manufacturer Information :**

Manufacturer Name : KZRV, L.P.

Address : 0985 N 900W

Shipshewana IN 46565

Company phone : 800-768-4016x154/153

Population :

Number of potentially involved : 117

Estimated percentage with defect : 95 %

Vehicle Information :

Vehicle 1 : 2021-2021 KZ RV Stratus

Vehicle Type : TRAILERS

Body Style :

Power Train : NR

Descriptive Information : Circuits run with a 14/2 wire are incorrectly protected by a 20 amp circuit breaker.

Production Dates : FEB 11, 2021 - MAY 20, 2021

VIN Range 1 : Begin :

NR

End : NR

☐ Not sequential

Vehicle 2 : 2021-2021 KZ RV SportTrek

Vehicle Type : TRAILERS

Body Style :

Power Train : NR

Descriptive Information : Circuits run with a 14/2 wire are incorrectly protected by a 20 amp circuit breaker.

Production Dates : FEB 11, 2021 - MAY 20, 2021

VIN Range 1 : Begin :

NR

End : NR

☐ Not sequential**Description of Defect :**

Description of the Defect : The water heater circuits are run with 14/2 wire and connected to a 20 amp circuit breaker instead of a 15 amp circuit breaker.

FMVSS 1 : NR

FMVSS 2 : NR

Description of the Safety Risk : If an issue develops, the circuit breaker will not trip and provide adequate protection to the wiring.

Description of the Cause : Production error.

Identification of Any Warning None
that can Occur :

Involved Components :

Component Name 1 : NR

Component Description : NR

Component Part Number : NR

Supplier Identification :

Component Manufacturer

Name : NR

Address : NR

NR

Country : NR

Chronology :

5/19/21 - PDI department inspects a unit built in Plant #8. They note the improper protection of the 14/2 wire on the water heater circuit. Yard inventory from this plant is placed on hold.

5/20/21 - The inventory in the yard is inspected and found with the same defect. These units are corrected. Investigation is conducted and found a wire supply change occurred in January 2021.

5/21/21 - A safety committee meeting is held and determines a recall should be issued.

Description of Remedy :

Description of Remedy Program : Replace the 20 amp circuit breaker with a 15 amp circuit breaker.

How Remedy Component Differs NR
from Recalled Component :

Identify How/When Recall Condition All wire circuits are paired with proper circuit breakers.
was Corrected in Production :

Recall Schedule :

Description of Recall Schedule : KZ will notify the dealers and owners of these recreational vehicles by letter. A final copy of the owner letter and dealer repair instructions will be provided to NHTSA.

Planned Dealer Notification Date : JUL 23, 2021 - JUL 23, 2021

Planned Owner Notification Date : JUL 23, 2021 - JUL 23, 2021

* NR - Not Reported