Part 573 Safety Recall Report

Manufacturer Name :	Forest River, Inc.
Submission Date :	OCT 28, 2021
NHTSA Recall No. :	21V-829
Manufacturer Recall No. :	79-1429

Manufacturer Information :

Manufacturer Name : Forest River, Inc. Estimated percentage with defect : 100 %Address : 55470 CR 1 P.O. Box 3030 Elkhart IN 46515-3030 Company phone : 1-800-348-7440

Vehicle Information :

Vehicle 1 : Vehicle Type : Body Style : Power Train :	OTHER	nc. XLR Toy Hauler Recreati	onal Vehicle
	Since the model change to began on July 15, 2021 to	October 14, 2021, when the ing a routine Corporate Qua	
Production Dates :	JUL 24, 2021 - JUL 28, 202	1	
VIN Range 1:	Begin : NR	End: NR	□ Not sequential

Population :

Description of Defect :

Description of the Defect :	The 12V wiring to the battery from the invertor is 2 Gauge whereas it should be 0/0 (both positive and negative), and is missing the 250AMP over-current protection within 18" of the battery, on the positive side. Additionally, the 110V side has a 20AMP double breaker, 12 gauge wiring from the distribution panel to the invertor, then 12 gauge wire to the first receptacle, then 14 gauge to three additional receptacles.
FMVSS 1 :	NR
FMVSS 2 :	NR
Description of the Safety Risk :	The incorrect gauge wire could potently melt, causing a short, which could potentially lead to a fire, property damage and/or personal injury.
Description of the Cause :	The manufacturing plant improperly wired 12V and 110V
Identification of Any Warning that can Occur :	None



3



Number of potentially involved :

21V-829

Part 573 Safety Recall Report

Involved Components :	
Component Name 1:	2 Gauge Wire
Component Description :	2 Gauge Wire
Component Part Number :	N/A
Component Name 2 :	20AMP Breaker
Component Description :	20AMP Breaker
Component Part Number :	N/A
Component Name 3:	14 Gauge Wire
Component Description :	14 Gauge Wire
Component Part Number :	N/A
Supplier Identification :	
Component Manufacturer	
Name : NR	
Address : NR	
NR Country : NP	
Country: NR	

Chronology:

On October 14, 2021, during a routine Corporate Quality Control inspection the improperly wired inverter was identified.

On October 15, 2021, the manufacturing plant contacted Forest Rivers' Office of Corporate Compliance and an investigation was started.

On October 18, 2021, the vehicle scope was identified.

On October 22, 2021, Forest River's Corporate recall committee voted to recall.

The information contained in this report was submitted pursuant to 49 CFR §573

On October 28, 2021, The recall was	amended to include the remedy.
Description of Remedy :	
Description of Remedy Program :	A remedy has not been determined at this time. The 573 report and the NoD will be updated with the remedy once it is determined.
	A-1 Forest River will provide all parts and labor free of charge to Consumers and Dealers. An authorized Forest River dealer will need to perform the remedy. The remedy will be include replacing the incorrect gauge wire and installing a sub panel with the correct breaker to protect the circuit to the inverter.
	What is the Forest River Customer Service Phone Number? (574) 642-0432
	If you have already paid for a repair that is within the scope of this defect under recall, you still need to have this recall inspected and/or performed to ensure the correct parts and procedures were utilized. Additionally, you may be eligible for a refund of previously paid repairs. Refunds will only be provided for within the scope of this defect under recall. Please send the service invoice to the following address:
	XLR Forest River, Inc. Attn: WARRANTY MANAGER 2421 Century Dr. Goshen, IN 46528
How Remedy Component Differs from Recalled Component :	A1 – Recalled Components 2 Gauge Wire Part number – N/A 20AMP Breaker Part number – N/A 14 Gauge Wire Part number N/A A1 Remedy Component Part Kit – Wiring, breaker and sub panel

The information contained in this report was submitted pursuant to 49 CFR \$573

Part 573	Safety	Recall	Report
-----------------	--------	--------	--------

	The 12V wire gauges were changed to 0/0 gauge and a 250amp mini breaker was installed along with the 110V wiring was changed to all 12 gauge wire on all vehicles in Forest River possession the week of October 15, 2021.
Recall Schedule :	
Description of Recall Schedule :	Forest River has the utmost urgency in our recalls. Forest River will send suspected VIN numbers to our third party vendor that is licensed to pull data on the current owner of the vehicles (as needed) once a formal NHTSA I.D. is provided. Forest River intends on pushing the mailing out as soon as NHTSA provides any correction(s) and an Acknowledgement Latter
Description of Recall Schedule : Planned Dealer Notification Date :	suspected VIN numbers to our third party vendor that is licensed to pull data on the current owner of the vehicles (as needed) once a formal NHTSA I.D. is provided. Forest River intends on pushing the mailing out as soon as NHTSA provides any correction(s) and an Acknowledgement Letter.

* NR - Not Reported

The information contained in this report was submitted pursuant to 49 CFR §573