

**Recall Quarterly Report****23V-607****Manufacturer Name :** Nova Bus (US) Inc.**NHTSA Recall No. / MFR Recall No. :** 23V-607 /CR5445**Recall Subject :** 250-Amp Fuse Holder May Overheat and Cause Fire**Owner Notification Beginning Date :** NOV 07, 2023**Owner Notification End Date:** NOV 08, 2023

Report #	Submission Date	Report Quarter	Recall Population	Total Remedied	Total Unreachable	Total Removed
2	APR 25, 2024	2024-1	1,189	3	0	0
1	JAN 30, 2024	2023-4	1,189	3	0	0

This Document Last Updated : APR 25, 2024

**Definitions :**Report Quarter : The quarter the manufacturer is reporting recall completion figures (e.g. 2012-3 means the 3<sup>rd</sup> quarter of 2012).

Recall Population : The total number of products recalled by the manufacturer.

Total Remedied : The total number of products either remedied, inspected without needing remedy, or returned to inventory.

Total Unreachable : Products deemed unreachable as owner notifications were unable to be delivered.

Total Removed : Products that have been scrapped, stolen, or exported.