

Part 573 Safety Recall Report

25V-285

Manufacturer Name : Jayco, Inc.

Submission Date : MAY 01, 2025

NHTSA Recall No. : 25V-285

Manufacturer Recall No. : 9903629



Manufacturer Information :

Manufacturer Name : Jayco, Inc.

Address : 903 South Main Street

PO Box 460 Middlebury IN 46540

Company phone : 800-283-8267

Population :

Number of potentially involved : 65

Estimated percentage with defect : 100 %

Vehicle Information :

Vehicle 1 : 2025-2025 Entegra Coach Launch

Vehicle Type : LIGHT VEHICLES

Body Style : OTHER

Power Train : DIESEL

Descriptive Information : Jayco Inc. has determined the population from our production records.

Production Dates : JAN 30, 2025 - MAR 31, 2025

VIN Range 1 : Begin : 1JSPEBBH4S1S18053 End : 1JSPEBBH0S1S18096 ☒ Not sequential

Vehicle 2 : 2025-2025 Jayco Terrain

Vehicle Type : LIGHT VEHICLES

Body Style : OTHER

Power Train : DIESEL

Descriptive Information : Jayco Inc. has determined the population from our production records.

Production Dates : FEB 04, 2025 - MAR 25, 2025

VIN Range 1 : Begin : 1UJPBBH1S1S14051 End : 1UJPBBHXS1S14064 ☒ Not sequential

Description of Defect :

Description of the Defect : Certain units were built with a standard outlet in the kitchen with no GFCI protection when there should have been a GFCI protected outlet in the kitchen.

FMVSS 1 : NR

FMVSS 2 : NR

Description of the Safety Risk : A lack of proper circuit protection increases the risk of electric shock and injury.

Description of the Cause : Engineering print error

Identification of Any Warning None
that can Occur :

Involved Components :

Component Name 1 : 20 Amp GFCI Breaker
Component Description : BREAKER,CKT GFCI 20A 120V SIEMENS Q SER
Component Part Number : 0226763

Supplier Identification :

Component Manufacturer

Name : NR
Address : NR
NR
Country : NR

Chronology :

3/27/2025 Jayco engineering notified Jayco Compliance by email that production failed to provide GFCI protection at an outlet near the kitchen.

3/31/2025 The Warranty Incident Review Committee (WIRC) discussed the incident and elevated it to CPAC.
4/2/2025 The Corrective Preventive Action Committee (CPAC) discussed the incident and elevated it to SSC.
4/24/2025 The Safety Steering Committee (SSC) met and voted to proceed with filing a safety recall with NHTSA.

Jayco Inc. is aware of only 1 claim regarding failure to provide GFCI protection at an outlet near the kitchen on these models.

Description of Remedy :

Description of Remedy Program :	Jayco Inc. dealers will replace the standard 20 Amp non-GFCI breaker with a new 20 amp GFCI Breaker at the load center for proper circuit protection at the kitchen outlet. Repairs made prior to the recall will be reimbursed in accordance with our Recall Reimbursement Plan on file with NHTSA. This repair will be performed at no charge. Jayco Inc. will file completion reports.
How Remedy Component Differs from Recalled Component :	The recalled component will have a 20 amp GFCI Breaker at the load center for the kitchen outlet.
Identify How/When Recall Condition was Corrected in Production :	3-27-25 Current production units have been remedied with the new 20 amp GFCI Breaker at the load center for proper circuit protection at the kitchen outlet.

Recall Schedule :

Description of Recall Schedule :	Jayco Inc. has determined the population from our production records.
Planned Dealer Notification Date :	JUN 06, 2025 - JUN 06, 2025
Planned Owner Notification Date :	JUN 06, 2025 - JUN 06, 2025

* NR - Not Reported