



May 5, 2025

## Jack Wiring Repair Procedure for Recall 25V317

### BOM:

- (2), 0013450 - 30Amp Blade Fuse
- (2), 0013476 - Insulated Female Quick Disconnect
- \*\*\* Wire Strippers, Wire Crimpers, 1/2" Socket

### Instructions:

1. Locate both Jack Power Wires on the load side of the orange disconnect switch( they both will have yellow eyelets on them, need a 1/2" socket to loosen the nut.)
2. Once located, remove both wire from disconnect switch, and then cut the yellow eyelets off of the wire
3. After the eyelets are cut, strip the wire and crimp on the insulated female connectors
4. After both connectors are crimped on, attach both wire to empty slots on the fuse panel
5. Lastly, install a 30A fuse in the slots of where the wires are located.