



Tech Tips

TT 57-13-01

Date: February 8, 2013

2011-2013 Touareg – Keyless Entry Remotes Inoperative

If all keyless entry remotes are inoperative but power door locks work from buttons inside vehicle, static current measuring mode may be active in the Diagnostic interface for databus (Gateway).

To deactivate Static current measuring mode, use Vehicle Self-diagnosis to select address word 19 – Diagnostic interface for databus (Gateway), and then select Adaptation. Choose Static current measuring mode from the displayed list, forward arrow, and ensure value is set to “not active”.

It may be necessary to cycle the ignition key for changes to take effect.