



Das Auto.

Service Information

VAS Tester

Number: VVT-13-11

Subject: VAS 5054A Transmitter Head – Bluetooth® & EDIC
Configuration – ODIS Service Only

Date: July 12, 2013

1.0 – Introduction

Use the following procedure to install and configure a VAS 5054A transmitter head on a VAS diagnostic laptop or tablet with **ODIS Service ONLY** ...i.e.: **VAS-PC not installed or previously uninstalled.**

We suggest printing this document for use during configuration.

2.0 – Preparation

Prerequisites

- ☐ VAS diagnostic laptop or tablet connected to power adapter and booted to Windows desktop.
- ☐ **VAS-PC not installed or previously uninstalled.**
- ☐ **The latest version of ODIS Service installed.** (ODIS Service must not be running during configuration).
- ☐ VAS diagnostic tester tablets: On-screen keyboard activated for number entry and USB mouse connected for easier navigation.

3.0 – Windows Bluetooth Configuration

1. Record the VAS 5054A **Serial Number (S#)** from a label on back of the transmitter housing:

VAS 5054A Serial Number (S# :) _____

2. Ensure the wireless operation switch is turned **ON** as applicable:



VAS 6150 & VAS 6150A

(Front panel behind handle)



VAS 6150B

(Middle right side behind WIRELESS door)



VAS 6160/X

(Upper left side behind SC/EX door)

3. Connect the VAS 5054A to the vehicle Data Link Connector (DLC) and switch the ignition ON. The blue LED on the transmitter head **must flash**.
4. From the Windows desktop, go to **Start > Settings > Control Panel**.
5. Select **Bluetooth Devices** from the Control Panel menu.


Continued ...2/




Das Auto.

Service Information

6. Select the **Options** tab: Verify that “**Allow Bluetooth devices to connect to this computer**” is **NOT** checked, and “**Alert me when a new Bluetooth device wants to**” **IS** checked (as illustrated below):



7. Select the **Devices** tab, and then click **Add**:



8. Check “**My device is set up and ready to be found**”. Click **Next** to start the device search:







Das Auto.

Service Information

9. Select/highlight the 5054A. Confirm the serial number matches that recorded in **Step 1**, click **Next**:




10. Select the passkey option: “Use the passkey found in the documentation”: Enter the **VAS 5054A** serial number recorded on **Page 1** as the passkey in the space provided, and then click **Next**:



11. Wait while Windows configures the Bluetooth connection.

12. Record the **Outgoing COM port** assigned to your device in the space below, and then click **Finish**:

Note: The COM port number illustrated below is **an example only!** Each configuration is unique, so it is important to record the COM port number assigned during **your** configuration.



Outgoing COM port: _____




Das Auto.


Service Information

The VAS 5054A now appears in the Bluetooth Devices window.

13. Select the **Hardware** tab:



14. Select (highlight) device name **Matsushita Bluetooth Controller** or **ALPS Integrated Bluetooth Device** as applicable to your device, and then click **Properties**:




Continued ...5/



Das Auto.

Service Information


15. If the **Power Management** tab is present, select it:



Note:

If the **Power Management** tab is **not** present, **close the Bluetooth Controller and Control Panel** windows. In this case the power management feature is not present and no further action is necessary.

16. Ensure that “**Allow the computer to turn off this device to save power**” is **deselected**, and then select **OK**:



17. Close the Control Panel window.




Das Auto.


Service Information

4.0 – EDIC Hardware Configuration


1. From the Windows desktop, double click the **ODIS Service EDIC configuration** program icon:




2. Click **Add EDIC ...** :



3. Select (highlight) **VAS5054** from the dropdown menu, and then click **OK**:



4. Click **OK**:



Continued ...7/




Das Auto.

Service Information


5. Select (highlight) the **outgoing COM port** as recorded on **Page 3 – Step 12**, and then click **OK**:

Note: The COM port selection illustrated below is **an example only**! Each configuration is unique, so it is important to select the COM port number assigned during **your** configuration.



The configured VAS 5054A and assigned COM port appears in the **Installed EDIC Interfaces** display.

5. Click **OK**:



6. From the Windows desktop, click the DiagStarter icon and start **ODIS Service**.

7. Initiate a diagnostic session and confirm vehicle to diagnostic device communication.

The VAS diagnostic device can now be placed into service with its configured VAS 5054A.