



**NUMBER:** 08-005-13

**GROUP:** Electrical

**DATE:** February 01, 2013

This bulletin is supplied as technical information only and is not an authorization for repair. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means, electronic, mechanical, photocopying, or otherwise, without written permission of Chrysler Group LLC.

**HELP USING THE wiTECH DIAGNOSTIC APPLICATION FOR FLASHING AN ECU IS AVAILABLE BY SELECTING "HELP" THEN "HELP CONTENTS" AT THE TOP OF THE wiTECH DIAGNOSTIC APPLICATION WINDOW.**

**THE wiTECH SOFTWARE LEVEL MUST BE AT RELEASE 13.03 OR HIGHER TO PERFORM THIS PROCEDURE.**

**SUBJECT:**

Flash: Power Liftgate May Not Power Open Or Close

**OVERVIEW:**

This bulletin involves reprogramming the Power Liftgate Module with new software.

**MODELS:**

|             |      |                |
|-------------|------|----------------|
| 2011 - 2012 | (WK) | Grand Cherokee |
| 2011 - 2012 | (WD) | Durango        |

**NOTE: This bulletin applies to vehicles equipped with Power Lift gate (sales code JRC) between March 1, 2010 (MDH 0301XX) and March 1, 2012 (MDH 0301XX).**

**SYMPTOM/CONDITION:**

The customer may experience the Power Lift Gate not opening and closing under power. Upon further investigation the Technician may find that B1882 Power Liftgate Position Sensor 1 Circuit set.

Updating the software will correct the conditions listed above.

**DIAGNOSIS:**

If the customer describes the symptom/condition or if the technician finds the DTC, perform the Repair Procedure.

**REPAIR PROCEDURE:**

**NOTE: Install a battery charger to ensure battery voltage does not drop below 13.2 volts. Do not allow the charging voltage to climb above 13.5 volts during the flash process.**

**NOTE: If this flash process is interrupted/aborted, the flash should be restarted.**

1. Use the wiTECH Diagnostic Application to reflash the Power Liftgate Module. Help using the wiTECH Diagnostic Application for flashing the Power Liftgate Module is made available through the wiTECH Diagnostic Application. For instructions select the "HELP" tab on upper portion of the wiTECH window, then "HELP CONTENTS." This will open the Welcome to wiTECH Help screen where help topics can be selected.
2. After the flash has been performed turn ignition switch off.

**NOTE: This will allow the active codes to become stored.**

3. Turn ignition switch on.
4. Clear any DTC's that may have been set in all modules due to reprogramming. The wiTECH application will automatically present all DTCs after the flash and allow the tech to clear them.

**POLICY:**

Reimbursable within the provisions of the warranty.

**TIME ALLOWANCE:**

| Labor Operation No: | Description  | Amount   |
|---------------------|--|----------|
| 18-19-31-94         | Module, Power Liftgate Control Module-<br>Reprogram<br>(1 -Semi - Skilled) | 0.2 Hrs. |

**FAILURE CODE:**

|    |              |
|----|--------------|
| FM | Flash Module |
|----|--------------|