

VAS Tester

Number: AVT-14-08

Subject:	VAS Diagnostic Devices – Windows [®] 7 Installation	Date: Feb. 26, 2014
	Instructions	

Table of Contents

Sectio	on	Page
1.0	Introduction - MUST READ!	<u>2</u>
1.1	Background	2
1.2	Eligible Devices	2
1.3	Installation Process Overview	2
2.0	Additional Documentation	<u>3</u>
3.0	Preparation Checklist	<u>4</u>
4.0	Installation	<u>5</u>
4.1	Standard Installation	5
4.2	Optional Installation	<u>7</u>
5.0	Recovery	<u>8</u>
6.0	Post-Recovery Setup	<u>10</u>
6.1	Windows [®] 7 Startup & Initial Setup	10
6.2	Windows [®] Update Settings & Internet Explorer Version Requirement	<u>17</u>
6.3	Network Setup	<u>18</u>
6.4	Reinstall & Configure Offboard Diagnostic Information System Service (ODIS Service) Diagnostic Software	<u>19</u>
6.5	VAS 5054A Transmitter Head Setup	<u>19</u>
6.6	Supplementary Setup & Function	<u>20</u>
67		04

Notes:

- The following procedures must be performed by qualified personnel only!
- Please read these instructions in their entirety before performing these procedures. If you do not have previous experience loading software or do not understand these instructions, arrange to have a qualified person perform these procedures.
- Heed all prerequisite requirements and notes, and follow all instruction steps in the Section order given, including instructions cross-referenced in documents posted on ServiceNet.
- Perform the procedures in an area that is quiet, clean and without distraction or interruption.
- **Discard all printed copies of this document after use**. Revised versions may be issued at any time. Always check ServiceNet for the latest version.

1.0 – Introduction

1.1 - Background

Microsoft[®] support of Windows[®] XP ends April 8, 2014. As a result, all eligible VAS diagnostic devices connected to VWAG Group systems worldwide **must be updated to Windows 7.**

This document contains step-by-step instructions required to install the **Windows 7 Professional operating system** from **AoA-supplied DVDs** on the eligible VAS diagnostic devices identified below.

1.2 – Eligible Devices

The Windows 7 installation process described here applies ONLY to the following VAS diagnostic devices:

Туре:	Model Numbers
Laptops	VAS 6150A, VAS 6150B & VAS 6150C
Tablets	VAS 6160 & VAS 6160A

1.3 – Installation Process Overview

Windows 7 Installation DVDs

Windows 7 installations are performed using device-specific DVDs.

Each DVD is individually identified by **device model number**, and can be used on multiple devices **of the same model**. An error message appears if a DVD is used on the wrong device.

Each dealer automatically receives (free of charge) **one of each** device-specific DVD based on the eligible VAS diagnostic device sales data current to the publication date of this document.



Installation & Recovery

Windows 7 files from the **device-specific DVD** are installed on a hard drive partition. The Windows recovery procedure is then initiated to overwrite the existing Windows XP operating system files with Windows 7 files.

All data on hard drive C:\ is erased and replaced. The Windows 7 recovery data installed on the hard drive partition is retained if recovery is required in future.

Continued3/

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.

Diagnostic Software and Security Certificate Reinstallation

The Windows 7 recovery process deletes the previously-installed ODIS Service license and certificate files, and changes the device's hardware key. As a result, **a new license file** must be requested from eShop prior to ODIS Service reinstallation. The new hardware key also requires that **a new ODIS Service Security certificate** be requested and imported.

The total time to complete all procedures depends on many variables. Examples include differences in device performance, installer proficiency, license and certificate approval times. Performing supplementary setups immediately or deferring until later also affects total completion times. Examples include reinstalling antivirus and printer software, configuring a VAS 6356 Test Box, downloading and installing ODIS Service and Windows updates. As such, a general time-to-completion estimate is not plausible.

IMPORTANT!

- If the Windows Panasonic CDs originally included with the device when new were retained, please LOCATE and DISCARD THESE DISCS NOW! Inadvertent use of the Panasonic CDs for recovery will completely erase the device-specific data and partitioned image, and install a standard, non-partitioned Windows XP or Windows 7 operating system.
- If the Windows 7 installation performed here malfunctions or becomes corrupt, it must be recovered from the image on the partition.
- It is not possible to revert back to Windows XP once Windows 7 is installed.
- Do not install VAS-PC diagnostic software on a Windows 7 device!
- Perform all procedures specified here on ONE DEVICE AT A TIME through to completion, BEFORE commencing with other devices.

2.0 – Additional Documentation

These instructions contain references to **Service Information (SI)** documents with additional instructions that must be carried out before placing the device back into service.

Locate and print the following documents to have on hand before proceeding. All documents are posted on **ServiceNet** (use the ServiceNet "**Search**" function to obtain the latest versions):

SI Document Category	Document Titles
	ODIS Service Installation Phase 1 - Preparation & License Request Instructions (eShop)
ODIS	ODIS Service Installation Phase 2 - Software Installation & Configuration Instructions
Service	ODIS Service Installation Phase 3 - Security Certificate Request & Installation Instructions
	ODIS Service Infomedia Setup Instructions
	VAS Diagnostic Device Computer Name Builder
VAS Tester	VAS 5054A Transmitter Head Bluetooth & EDIC Configuration – ODIS Service Only
	VAS 5054A Transmitter Head USB Configuration – ODIS Service Only

Additional Documentation steps completed. Proceed to Section 3.0 – Page 4.

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.

3.0 – Preparation Checklist

Complete the **Preparation Checklist** below for **each device** where Windows 7 will be installed. Additional checkboxes are provided throughout this document to note the fulfillment of prerequisites, redirects to device-specific information and completion of sections.

1	· ·			
\checkmark		Preparation Checl	klist	
	Print the additional documentation from ServiceNet as specified in Section 2.0.			
	Choose ONE eligible device in	workshop service as spec	ified in Section 1.2.	
	Note the device type and mode	l number.		
	VAS 6160 & VAS 6160A table mouse and keyboard directly t	t s: Mount tablet to base st o tablet.	ation (port replicator). Connect a USB	
	Connect the A/C power adapte	r directly to the laptop or ta	ablet.	
	Boot the device and confirm W	indows XP appears on sta	artup*.	
	Start ODIS Service. Finalize all	saved diagnostic sessions	s and transmit logs where applicable.	
	Disconnect the Ethernet (netw	ork) cable where applicabl	е.	
	Switch the Wireless Operation	n Switch to the OFF posit	ion as illustrated -arrows-:	
	VAS 6150A	VAS 6150B & VAS 6150C	VAS 6160 & VAS 6160A	
	Front panel behind handle Middle right side behind WIRELESS Upper left side behind SC/EX door door			
	Obtain the device-specific Wind	dows 7 installation DVD:		
	Model Number:	DVD Title:	Ordering Number**:	
	VAS 6150A	VAS 6150A/20	ASE 905 206 00 000	
	VAS 6150B	VAS 6150B/20	ASE 905 206 00 001	
	VAS 6150C	VAS 62150C/20	ASE 905 206 00 002	
	VAS 6160 & VAS 6160A	VAS 6160/20	ASE 905 400 00 000	
*DO I **Orc	*DO NOT use the Windows 7 installation DVDs on new VAS 6150C and VAS 6160A already loaded with Windows 7! **Order misplaced or additional DVDs from www.audi.techliterature.com			

All Preparation steps completed. Proceed to Section 4.0 – Page 5.

© 2014 Audi of America, Inc.



4.0 – Installation

Two installation methods are possible.

The **Standard Installation** method installs Windows 7 files directly from the device-specific DVD. This method is recommended for most cases.

The **Optional Installation** method installs Windows 7 files copied from the device-specific DVD to **alternate storage media**, e.g.: external hard drive, USB flash drive, SD card etc.

Note:

The optional method can be used if the device DVD-ROM drive functions were intermittent in the past, and/or performed only by those with experience with copying and installing files from a DVD to alternate storage media. Refer to **Section 4.2 – Page 7.**

4.1 – Standard Installation

Prerequisites:

- Confirm: All applicable Preparation Checklist items fulfilled.
- ODIS Service and all other programs **not** running.
- 1. Insert the device-specific installation DVD in the DVD-ROM drive and wait while the disc is read.
- 2. Go to: **My Computer** and **Open** the **DVD-ROM** directory. *Note:* The title and drive information illustrated below are for reference only:



3. Click Setup:



The Setup.exe and Symantec Ghost screens appear automatically, one after another:



Continued... 6/

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.



Notes:

- User intervention is not required during the setup and ghost processes.
- If the processes are aborted by the user, or automatically by the system, repeat Steps 1 3 above. **DO NOT** start the recovery process if the setup and ghost processes are not completed.

When the setup and ghost processes are completed, the following screen is displayed:



- 4. **Press** any key and **remove** the installation DVD from the CD/DVD drive.
- 5. Close all windows and shut down the diagnostic device: Start > Turn Off Computer... > Turn Off
- 6. **Remove** the diagnostic device from the base station (port replicator) where applicable.
- 7. Retain the DVD for use on additional devices with the same model number.

Installation steps completed. Proceed to Section 5.0 – Page 8.

^{© 2014} Audi of America, Inc.

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.



4.2 – Optional Installation

Prerequisites:

- All applicable **Preparation Checklist** items fulfilled.
- ODIS Service and all other programs **not** running.
- Access to desktop or laptop computer capable of reading and copying files from a DVD to alternate storage media available
- □ Formatted alternate storage media on hand with at least **10GB** of available free space, e.g.: external hard drive, USB flash drive, SD card etc.
- 1. **Connect** the alternate storage media to a desktop or laptop computer.
- 2. Create an empty directory folder.
- 3. Name the empty folder to identify its contents, using the device model number, e.g.: 6160_Win7_Rec.
- 4. Insert the device-specific installation DVD in the CD/DVD drive of the desktop or laptop computer.
- 5. **Copy** the entire contents of the installation DVD to the prepared directory folder on the alternate storage media.
- 6. **Remove** the installation DVD from the CD/DVD drive.
- 7. Safely Remove / Eject the alternate storage media as applicable.
- 8. **Connect** the alternate storage media to the diagnostic device.
- 9. From the Windows desktop go to Start > My Computer.
- 10. Locate and **open** the prepared directory folder
- 11. Proceed with installation steps 3 through 6 in Section 4.1 from Page 5.

Optional Installation steps initiated.

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.



5.0 – Recovery

Prerequisites:

- All devices **removed** from their base station (port replicator) where applicable.
- Confirm: Ethernet cable **DISCONNECTED** & wireless operation switch in the **OFF POSITION!**

ATTENTION!

The A/C power adapter must be connected directly to the device during recovery. DO NOT recover on battery power alone!

- 1. **Turn on** the diagnostic device.
- 2. When the **Panasonic** logo is displayed, quickly press the **F2** key on the keyboard to enter the setup.



A BIOS password prompt appears.

3. Note the device-specific password from the table below:

Model	BIOS Password
VAS 6150A	vas6150
VAS 6150B	vas6150b
VAS 6150C	vas6150c
VAS 6160 & VAS 6160A	vas6160

- 4. Enter the password exactly as noted above (lower case, no spaces):
- 5. Press the keyboard (or onscreen keyboard) Enter key:



Continued...9/

© 2014 Audi of America, Inc.

Page 8 of 24

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.



7. Using the up and down arrow keys, select either:



as applicable. Press the Enter key to continue:



After the Enter key is pressed, the system recovery starts. After approximately 2 minutes, the message "System will be recovered" is displayed.

8. Press the 2 key, then press the Enter key to continue:



- Allow 30 90 minutes for device recovery (device-dependent). •
- The progress window may appear to stall at 99% 100%. Please be patient!
- When complete, the system will automatically reboot and display a series of automatic setup, registry and service screens followed by the initial Windows setup screen.

Recovery steps completed. Proceed to Section 6.0 - Page 10.

© 2014 Audi of America, Inc.

Page 9 of 24

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.



6.0 – Post-Recovery Setup

6.1 – Windows[®] 7 Startup & Initial Setup

Prerequisite:

□ Confirm: Ethernet cable DISCONNECTED & wireless operation switch in the OFF POSITION!

Note:

The initial language selection made in Step 1 below cannot be changed after the device is placed in service. **Avoid having to repeat the recovery process by selecting the language carefully!**

1. From the initial Windows setup screen, **carefully scroll down** and select **My language is English:** Click **Next:**



2. Confirm the regional settings, time/currency and keyboard layout as illustrated, and then click Next:



Continued ...11/

© 2014 Audi of America, Inc.

Page 10 of 24

3. Read the license terms and conditions, and accept by checking the appropriate boxes. Click Next:



4. Set the Time Zone, Daylight Saving Time, Date and Time as applicable to your location. Click Next:



- Various settings are saved and the device automatically reboots to the Windows desktop.
- For convenience, the device can now be returned to its base station if desired (not mandatory).
- In all cases the A/C power adapter must remain connected for the following procedures. The USB mouse and keyboard should also remain connected where applicable.

Continued... 12/

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.



6.1.1 – Delete Non-Applicable Information

The Windows 7 desktop includes documents that are not applicable to the -US/CDN- market. **Please delete these documents** as follows:

1. From the Windows desktop: Locate two document shortcut icons entitled:

HowTo Guide_ODIS Service Set-Up_EN and HowTo Guide_ODIS Service Set-Up_DE:



- 2. Right-click a shortcut icon, and then select Delete from the dropdown.
- 3. When prompted to confirm file delete, click **Yes**. Repeat for the remaining icon.
- 4. From the Windows desktop: Open the Manuals folder:



5. Right-click the OffboardDiagService folder, and then select Delete from the dropdown:

Name	Date modified	Туре	Size
🗹 퉬 OffboardDiagService	30.01.2013 16:27	File folder	
🍓 Panasonic	27.09.2011 12:18	File folder	
🔲 퉬 Workshop Equipment	24.06.2013 19:43	File folder	

6.1.2 – Confirm Keyboard Language

1. Go to: Windows (Start) 5 Control Panel > Region and Language:



Region and Language

2. Select the Keyboards and Languages tab. Click Change Keyboards...:



Continued ...13/

© 2014 Audi of America, Inc.



- 3. Confirm that the Default input language is set to English (United States) US as illustrated below. If not, select it from the dropdown.
- 4. If the German (Germany) input language service appears, select it and click Remove.
- 5. If any changes were necessary, save them by clicking Apply, and then OK:

Services and Input Languages	×
General Language Bar Advanced Key Settings	
Default input language Select one of the installed input languages to use as fields.	s the default for all input
English (United States) - US	-
Installed services Select the services that you want for each input lan Use the Add and Remove buttons to modify this list. English (United States)	guage shown in the list.
E German (Germany) Keyboard	Add
	Properties .
	Move Up
	Move Down
OK	Cancer Apply

6. Close the languages window and return to the Control Panel menu.

6.1.3 – Device Power Management

To ensure uninterrupted data transfer when performing lengthy Software Version Management (SVM) procedures, configure the device to remain on as follows:

1. Go to: Control Panel > Power Options:



All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.

3. Select Never from the dropdowns as illustrated:

🔮 Turn off the display:	Never -	Never -
Put the computer to sleep:	Never	Never

4. Click Save changes (at bottom frame):

Save changes	Cancel
--------------	--------

- 5. Close the power options window and return to the Control Panel menu.
- 6. Check and proceed to the device-specific sections as applicable:
 - VAS 6150<u>B</u>, VAS 6150<u>C</u>, VAS 6160 & VAS 6160A: Proceed to Section 6.1.5 Page 16.
 - VAS 6150<u>A</u>: Proceed to Section 6.1.4 below:

6.1.4 – VAS 6150A Diagnostic Laptops: Increase Paging File Size

For optimum performance, increase the paging file size on VAS 6150A laptops as follows:

1. Go to: Control Panel > System:



2. From the Control Panel Home menu, click Advanced system settings:

Control Panel Home
Device Manager
Remote settings
System protection
Advanced system settings

3. Select the Advanced tab. In the Performance category, click Settings:



Continued ...15/

© 2014 Audi of America, Inc.

Page 14 of 24

4. Select the Advanced tab. In the Virtual memory category, click Change:



- 5. Ensure Automatically manage paging file size for all drives is deselected and Drive [Volume Label] C: is highlighted:
- 6. Select **Custom size:**, and then **enter 6000** in both the **Initial** and **Maximum** size entry fields as illustrated below: When complete, click **Set:**

V	irtual Memory
	Automatically manage paging file size for all drives Paging file size for each drive
L.	Drive [Volume Label] Paging File Size (MB)
L.	C: None
	D: [Data] None
L	Selected drive: C: Space available: 260001 MB
L	Custom size:
L	Initial size (MB): 6000
L	Maximum size (MB): 6000
L	System managed size
L	No paging file Set
L	Total paging file size for all drives
L	Minimum allowed: 16 MB
L	Recommended: 5974 MB
L	Currently allocated: 0 MB
	OK Cancel

Continued ...16/

© 2014 Audi of America, Inc.



7. Ensure that the Paging File Size (MB) indicated for C: is displayed as 6000 - 6000: Click OK:

Paging file size for ea	ich drive
Drive [Volume Label]	Paging File Size (MB)
C:	6000 - 6000
D: [Data]	None
	-
Selected drive: Space available:	C: 26000.1 MB
	20001110
Custom size:	6000
Initial size (MB):	6000
Maximum size (MB):	6000
System managed	size
No paging file	Set
O no poging me	ber
Total paging file size f	for all drives
Minimum allowed:	16 MB
Recommended:	5974 MB
Currently allocated:	0 MB
currently allocated:	0 MB

Note:

The recommended page file size of 6000 MB allows for 2GB of additional RAM that may be added.

6.1.5 – Restart Windows

A restart is required to complete automatic Windows configurations on certain devices. Proceed as follows, and note the **Windows 7 Shut down** and **Restart** routines for future reference:

1. Close all windows and **Restart** the device. Go to: **Windows (Start) (3) > --- > Restart**:

Devices and Prin	Switch user
	Log off
Help and Suppo	Lock
Run	Restart
	Sleep
Shut down	Hibernate

Windows 7 Startup & Initial Setup steps complete – Proceed to Section 6.2 – Page 17.

© 2014 Audi of America, Inc.

Page 16 of 24

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.

6.2 – Windows[®] Update Settings & Internet Explorer Version Requirement

The Windows 7 version installed here includes Internet Explorer (IE) version 9.

IMPORTANT!

ODIS Service and its web-based Infomedia functions are optimized for Windows 7 and IE9. The automatic download and installation of IE10 and IE11 from a Windows update must be prevented!

The installation of IE10 or IE11 results in impaired ODIS Service web-based services functions.

The default setting for Windows updates is to automatically download files when a network connection is present, and then prompt the user to install them. As a first step to prevent the download and installation of Windows updates that include IE10 and IE11, change the default setting to (manually) check for updates and prompt the user to choose the updates as specified below. Separate instructions on managing Windows updates and disabling IE updates are covered in **Section 6.7**.

Perform the following configuration **BEFORE setting up the network connection:**

1. Go to: Windows (Start) Scontrol Panel > Windows Update:



2. From the Control Panel Home menu, select Change settings:



3. Select the "Check... & ...choose" update method from the Important updates selection dropdown:



4. Click **OK** (at bottom frame):



5. Close the Control Panel window.

Windows Update Settings steps completed – Proceed to Section 6.3 – Page 18.

Page 17 of 24

^{© 2014} Audi of America, Inc.

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.



Note:

Before proceeding with **Sections 6.3** through **6.5**, have the additional documentation specified in Section 2.0 – Page 3 on hand.

6.3 – Network Setup

6.3.1 – Set Computer Name

If more than one VAS diagnostic device is connected to the dealership network, each device must be assigned a different computer name.

Assign the computer name before proceeding. For detailed instructions refer to VAS Tester – Service Information document title: VAS Diagnostic Device Computer Name Builder

6.3.2 – Enable Network Connections

For dealership networks using **DHCP** for Internet access, no network connection configuration is necessary (the device default setting is DHCP). If the dealership network uses DHCP for Internet access, skip to **Section 6.3.3** below.

For networks using **Static IP** configurations for Internet access, the IP configurations must be renewed by manual entry of the dealership-specific IPs. Ask your dealership systems administrator or IT professional for details and assistance.

If the device is to be used over a wireless LAN connection, switch the **wireless switch** to the **ON position** and perform the required wireless configuration at this time. Ask your dealership systems administrator or IT professional for details and assistance.

ATTENTION!

ODIS Service software functions require open network connections. Open access must be enabled on an individual basis for each diagnostic device. For details, refer to Service Information – ODIS Service document title: Required Open Internet Addresses (URLs)

6.3.3 – Reinstall Netviewer

- 1. Launch Internet Explorer and logon to ServiceNet.
- 2. Navigate to the Workshop Equipment > VAS Tester > Software section.
- 3. Right click / select the link: Netviewer one2one Telediagnosis Software.
- 4. Save file to Windows desktop.

Network Setup steps completed – Proceed to Section <u>6.4 – Page 19.</u>

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.

6.4 – Reinstall & Configure Offboard Diagnostic Information System Service (ODIS Service) Diagnostic Software

1. Use the diagnostic device to **submit a new license request** prior to software installation and configuration.

For detailed instructions, refer to ODIS Service – Service Information document title: ODIS Service Installation Phase 1 – Device Preparation & License Request Instructions

ODIS Service Installation Phase 1 steps completed.

2. When the new license file is received via email and saved to a USB flash drive, reinstall and configure ODIS Service.

For detailed instructions, refer to ODIS Service – Service Information document title: ODIS Service Installation Phase 2 - Software Installation & Configuration Instructions

Refer to the **Phase 2** document sections describing **New Installations**.

ODIS Service Installation Phase 2 steps completed.

3. Request and import a new ODIS Service security certificate.

For detailed instructions, refer to ODIS Service – Service Information document title: ODIS Service Installation Phase 3 – Security Certificate Request & Installation Instructions

ODIS Service Installation Phase 3 steps completed.

4. Setup ODIS Service Infomedia.

For detailed instructions, refer to ODIS Service – Service Information document title: ODIS Service Infomedia Setup Instructions

All ODIS Service Reinstallation Phase + steps completed. Proceed to Section 6.5 – below.

6.5 – VAS 5054A Transmitter Head Setup

1. Perform the Windows Bluetooth and EDIC configuration for **wireless** operation.

For detailed instructions, refer to VAS Tester - Service Information document title: VAS 5054A Transmitter Head - Bluetooth & EDIC Configuration – ODIS Service Only

2. Perform the UBS configuration for **cabled** operation.

For detailed instructions, refer to VAS-Tester - Service Information document title: VAS 5054A Transmitter Head - USB Configuration – ODIS Service Only

VAS 5054A Transmitter Head setup steps completed.

Windows 7 and ODIS Service Installation completed. Supplementary instructions: Refer to Section <u>6.6 - Page 20</u> and Section <u>6.7 - Page 21</u>.

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.

6.6 – Supplementary Setup & Function

Depending on the updated diagnostic device's previous preparation level and/or dealership requirements, the following supplementary setup procedures **may or may not** be required. Review and confirm as applicable.

6.6.1 – VAS 6356 Test Instruments Box - Configuration

If a VAS 6356 Test Instruments Box was previously configured for use with the updated device, it must be connected and the initial configuration repeated.

For detailed instructions, refer to Workshop Equipment - Service Information document title: VAS 6356 Test Instrument Box – Software Configuration – ODIS Service Only

Completed

Not applicable

6.6.2 – Printer Driver Reinstallation

If a USB (cabled) or wireless (WLAN) printer was previously configured for use with the updated device, the necessary driver installation and/or configuration must be repeated.

Obtain the printer driver CD where applicable and refer to the installation documentation supplied with the printer. Ask your dealership systems administrator or IT professional for assistance if necessary.

Completed Not applicable

6.6.3 – Reinstall Antivirus Software

Reinstall the antivirus software as may be required by the dealership IT policy. Ask your dealership systems administrator or IT professional for assistance if necessary.

Completed

Not applicable

6.6.4 – Windows 7 Familiarization

If Technician users are not familiar with Windows 7 features, navigation and functions, we recommend they read the various information resources included with the software.

Go to: Windows Start > Getting Started > Discover Windows 7 ...as well as the additional topics listed in the Getting Started dropdown:



© 2014 Audi of America, Inc.

Page 20 of 24

6.7 – Windows[®] 7 Updates

6.7.1 – General Information

All VAS diagnostic devices must be kept up-to-date with the latest Windows security and vulnerability updates. However, dealership service or IT personnel tasked with maintaining both ODIS Service and Windows updates **must be aware of the following, and act accordingly:**

 The initial package of important Windows updates available for this Windows 7 installation may take considerable time to install and download (typically between 60 – 120 minutes, device, content and bandwidth dependent). As a result, we recommend that the initial selection, download and installation of Windows updates be managed so that the update process takes place outside of workshop service hours.

Instructions on how select and initiate Windows updates follow in the **Managed Windows Update** section below.

 Under no circumstances are Internet Explorer (IE) versions 10 or 11 to be installed as part of the Managed Windows Update process. Refer to <u>Section 6.2 – Page 17</u> for details.

Instructions on how to deselect IE10 and IE11 from Windows update listings follow in the **Managed Windows Update** section below.

ATTENTION!

Please inform all service personnel that under no circumstances are IE10 or IE11 updates to be downloaded and installed on devices updated with Windows 7!

6.7.2 - Managed Windows Update Procedure

Prerequisites:

- Diagnostic device removed from service, after hours etc.
- Diagnostic device with active network connection.
- 1. Go to: Windows (Start) 💿 🛛 > Control Panel > Windows Update:



Windows Update

2. Click Check for updates:

Windows Update



Continued ...22/

© 2014 Audi of America, Inc.

Page 21 of 24

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.

3. The first time after a Windows 7 installation, an update prompt for **Windows Update** may or may not appear. If so, click **Install now:**



4. Wait while an update for Windows Update is installed:



5. After the update closes and re-opens, wait while the system checks for updates:

Windows Update

Windows Update



6. When the results are displayed, click the XX important updates are available link:



Note:

The number of updates illustrated above **is for reference only!** The number of available updates will always vary depending on type of device and date when available updates are checked.

© 2014 Audi of America, Inc.

Page 22 of 24

7. Deselect the Internet Explorer 10 and Internet Explorer 11 updates from the update listing:

Select the updates you want to install

		Name	Size	
Important (88)	W	ndows 7 (87)	^	
	1	Cumulative Security Update for ActiveX Killbits for Windows 7 for x64-based Systems (KB2900986)	41 KB	
Optional (44)	V	Cumulative Security Update for Internet Explorer 9 for Windows 7 for x64-based Systems (KB2898785)	28.3 MB	
		Internet Explorer 10 for Windows 7 for x64-based Systems	75.4 MB	Ξ
		Internet Explorer 11 for Windows 7 for x64-based Systems	84.1 MB	
	V	Security Update for Microsoft .NET Framework 3.5.1 on Windows 7 and Windows Server 2008 R2 for x64-based Systems (KB2832414)	7.4 MB	
	1	Security Update for Microsoft .NET Framework 3.5.1 on Windows 7 and Windows Server 2008 R2 for x64-based Systems (KB2861191)	144 KB	
	V	Security Update for Microsoft .NET Framework 3.5.1 on Windows 7 and Windows Server 2008 R2 SP1 for x64-based Systems (KB2604115)	23.1 MB	
	1	Security Update for Microsoft .NET Framework 3.5.1 on Windows 7 and Windows Server 2008 R2 SP1 for x64-based Systems (KB2729452)	13.0 MB	
	1	Security Update for Microsoft .NET Framework 3.5.1 on Windows 7 and Windows Server 2008 R2 SP1 for x64-based Systems (KB2736422)	331 KB	

8. To prevent the IE updates from reappearing, **right click** the IE10 update and select **Hide update** from the dropdown. **Repeat** with the IE11 update:

	Internet Explorer 10 for \	Mindows 7 for 161 bacad Surts	e
	Internet Explorer 11 for	Copy details	
1	Security Update for Mic	Hide update	1

9. Click **OK** (at bottom frame):

Total selected: 85 important updates	ОК	Cancel
rotal selected, os important apaates	UK	Curreer

10. Click Install updates:

Windows Update

© 2014 Audi of America, Inc.



- 11. Accept any Microsoft License Terms if prompted, and then click Finish.
- 12. Wait while the updates are downloaded and installed (no user intervention is necessary):

Windows Update	Windows Update
Downloading updates Downloading 85 updates (387.0 MB total, 2% complete)	 Installing updates Installing update 26 of 85 Security Update for Microsoft .NET Framework 4 on XP, Server 2003, Vista, Wind Stop installation

Page 23 of 24

13. Click Restart now:

Windows Update

The updates were successfully installed		
Restart now to finish installing updates.	Restart no	
Succeeded: 85 updates		
Windows can't update important files ar is using them. Save any open files, and t	nd services while the system hen restart the computer.	

- Additional Windows update configurations are performed during the shut-down and restart routine.
- On completion, the device boots to the Windows desktop, and an information prompt on the installed updates appears.

All rights reserved. Information contained in this document is based on the latest information available at the time of printing and is subject to the copyright and other intellectual property rights of Audi of America, Inc., its affiliated companies and its licensors. All rights are reserved to make changes at any time without notice. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, nor may these materials be modified or reposted to other sites, without the prior expressed written permission of the publisher.