
Reference	SSM72615
Models	LR4 / L319
Title	Low battery warning message displayed ECO Stop/ Start unavailable
Category	Electrical
Last modified	03-Feb-2016 00:00:00
Symptom	206000 Warning Indicators

Content

Issue: A customer may report that a low battery warning message is displayed on the Instrument Cluster and Eco Stop start unavailable.

Root cause: The Battery Monitoring System (BMS) clamp is not correctly positioned on the main battery terminal post.

Action to be taken: Carefully loosen and disconnect BMS clamp from battery pole. Fully loosen clamp and ensure jaws of clamp are fully open. Replace clamp over battery pole, ensuring the top of clamp is level with or lower than top of battery pole. Secure the bolt to a f 5Nm as specified in Topix. Using Symptom Driven Diagnostics (SDD) reset the BMS and ensure the battery is fully charged.