

PRODUCT INVESTIGATION ELECTRICAL

UPDATE

CAPABLE
OF GREAT
THINGS
PALM SPRINGS 2020

Intermittent Battery Ground Connection	19-20MY Discovery
<p>Customer Voice:</p> <ul style="list-style-type: none">• Intermittent no start <p>Technical Description:</p> <ul style="list-style-type: none">• A 6mm earth (ground) stud maybe loose in the body and require replacement. <p>Status:</p> <ul style="list-style-type: none">• TOPIX instructions to replace the earth stud are located under 501-25A: Body Repairs - General Information• Studs can now be purchased as quantity of one from the JLR tooling and equipment website - https://jirequipment.service-solutions.com.<ul style="list-style-type: none">• Stud part # 78905-SINGLE• Tool part # JLR-MRPK4081 (installs 6mm and 8mm earth studs)• The earth stud tool will become a mandatory tool (awaiting timing from Bosch) <p>All 6mm earth stud tools will be shipped air freight to Bosch USA, with all 230 expected to be in USA stock by 4/21</p>	