

# SCR ADS Self-Check

---



[Anthony Kasper](#) 20 posts since Aug 26, 2020

**SCR ADS Self-Check** Feb 17, 2021 3:32 PM

When performing scr ads self check yellow triangles pop up sometimes one or two and sometime on every box in the window (attach picture) and disappear when trying to run routine. has code 4374/0. pump speed is at 3000+. no crystallization out pump vent ports. def not frozen.

the triangles that pop up are concerning, makes me thing its loosing communication or has some wiring issue. any ideas would be helpful.

3AKJGLD56FSGL5819

- [\(3AKJGLD56FSGL5819\) 2-17-2021 0855.04.DrumrollLog](#) 393.3 KB
- [ADS.PNG](#) 51.3 KB

Tags: def, scr, ads, def pump, ads self-check



[Scott Trippel](#) 4,095 posts since Dec 13, 2014

**Re: SCR ADS Self-Check** Feb 17, 2021 9:46 PM

That is an issue with the DL8 tool software, we have had that problem with several versions now. No need to troubleshoot the truck.



[James McFadden](#) 198 posts since Dec 9, 2014

**Re: SCR ADS Self-Check** Feb 18, 2021 4:09 PM

Are you hard wired or running blue tooth ? I notice more of the caution symbol's when im connected BT. its just intermittent data display like scott says nothing to worry about. .



[Francois Tourigny](#) 85 posts since Mar 8, 2019

**Re: SCR ADS Self-Check** Feb 21, 2021 7:38 PM

I also have an issue with that service panel.

I've starting the test, all indications appears on the right side of the screen, at this time, pump rpm should raise and pressure too. But it never happen, waiting 2-3 min. I've trying to shut the truck off for 10 min, use another shop laptop. It never start. I finally use and 3rd laptop, and the test started as usually. I've send a ticket about it, I've received a comeback as it could be a glitch into the system. Is DL8 having some recent bug on this panel?  
TY