

2022 Ascent

JOB 1) COMPLAINT: Water pump cycles every 30 seconds to a minute

CAUSE: Found low point drain valve leaking when valve is in closed position. Valve will need to be removed and replaced

CORRECTION: REMOVE AND REPLACE VALVE

TIME NEEDED: 0.75 HR **0.30 approved.**