Reviewers Note: Words/phrases in blue will be links to specific diagnostic procedures when this document is published in Freshdesk.

CNG Fuel System Maintenance Schedule

DSM.0132 Ver. 2.0 November 22, 2022

Performing regular maintenance will help ensure the Hexagon® Agility® compressed natural gas (CNG) fuel system delivers safe and reliable performance and minimize down time.

To determine the correct maintenance intervals for the vehicle, first determine vehicle service type and/or operating conditions.

Severe Duty

- Operation on extremely poor roads or off-roads/highways
- Frequent short-distance or stop and go travel, such as refuse or transit bus
- Construction site operation
- Poor fuel quality

Normal Duty

- Long haul
- Over the road
- Infrequent stops

Item / action	Interval	
	Normal Duty	**Severe Duty**
High-pressure (HP) fuel filter / Manifilter element – replace*	Every 30000 miles / 48000 km OR Every 1000 hours / 9 months – whichever occurs first	Every 15000 miles / 24000 km OR Every 1000 hours / 9 months – whichever occurs first
Supply solenoid valve (SSV) coil – replace	Every 24 months	
Cylinder valves, electric solenoid coil – replace	Every 24 months	

**If excess oil is found in the HP fuel filter during service, review fuel dispenser service history.*