

Release date:

2/19/2024

## **Condition**

Applicable Vehicles					
Model(s)	Year	Eng. Code	Trans. Code	VIN Range From	VIN Range To
Golf, Golf GTI, Golf R, Atlas, Atlas Cross Sport, Tiguan, Jetta, Arteon, Taos	2020-2023	All	All	All	All

Revision Table			
Instance Number	Published Date	Version Number	Reason For Update
2055190/5	2/19/2024	57-19-02	Update to battery replacement labor operation number.
2055190/4	2/13/2023	57-19-02	Update to model and model year applicability.
2055190/3	3/2/2021	57-19-02	Update to model and model year applicability.
2055190/2	12/03/2019	57-19-02	Remove model year 2018, add time and mileage applicability limits, add Golf and Golf GTI, clarify VAS 6356 requirement, update 12 Volt battery maintainer tool number.
2055190/1	6/4/2019	57-19-02	Original publication.



57-19-02 - Remote Key Battery Replacement

Release date:

**Transaction No:** 

2/19/2024

2055190/5



### NOTICE

This technical bulletin is applicable up to 12 months in service or 12,000 miles (whichever comes first).

Customer reports one or more of the following conditions is present or has occurred:

- The remote control key buttons do not work.
- The vehicle does not start unless the key is held against the steering column.
- The vehicle cannot be unlocked/opened from the outside with the remote control buttons.
- The following message appears in the instrument cluster: "Replace key battery".
- The following message appears in the instrument cluster: "Key battery low".

One or more of the following DTCs may be stored in the -*J519*- Central Electrics Control Module (BCM) (diagnostic address 09).

- B147918 Remote key 1 Voltage too low (static or sporadic).
- B147A18 Remote key 2 Voltage too low (static or sporadic).
- B147B18 Remote key 3 Voltage too low (static or sporadic).



In vehicles equipped with KESSY, a message pertaining to the key battery condition may be displayed in the instrument cluster without setting one of these DTCs.

# **Technical Background**

There is no specification for testing the open circuit voltage of key batteries. Open circuit voltage testing using a voltmeter will result in misdiagnosis of the actual key battery condition.

## **Production Solution**

Not applicable.

### **Service**

If diagnosis leads to the key battery as the suspected cause of the remote key concern, it is necessary to check the key battery using the applicable Guided Fault Finding (GFF) test plan.


Only replace the key battery according to the GFF test plan result. The completed GFF Test plan must be uploaded to Volkswagen via GFF Paperless or retained by the dealer (electronically or otherwise), as it may be subject to request. The measurements in the test plan must be performed using a VAS 6356 test instrument box connected to the ODIS tester (results obtained from manual entry of default values into the test plan are not valid).




Release date:

2/19/2024

#### Locating the test plan:



- Key battery diagnosis is performed using the GFF test plan "0009 Remote control battery check".
- If the test plan was attached automatically based on DTCs, click "Perform test" to begin.





57-19-02 - Remote Key Battery Replacement

Release date:


**Transaction No:** 

2/19/2024


2055190/5

If the test plan was not attached automatically, it will be necessary to locate and add it manually.

- Click "Select self-test" (1).
- Click the magnifying glass icon (2).




- Then enter "Remote control battery" as the search term (3).
- Select the result "0009 Remote control battery check" (4).
- Click "Go to" (5).





### 57-19-02 - Remote Key Battery Replacement

**Release date:** 2/19/2024



- Select the test plan "0009 Remote control battery check" (6).
- Click "Attach to the test plan" (7).
- Once the test plan is attached, select it, and click "Perform test".



It is also possible to find the test plan by drilling-down through the self-test selections as follows:

Diagnosis-capable systems > 0009 - Vehicle Electrical Control Module System > 0009 - Functions, Electronic central electric > 0009 - Remote control battery check.



57-19-02 - Remote Key Battery Replacement

Release date:

**Transaction No:** 

2/19/2024

2055190/5

#### Overview of the test instrument setup for voltage measurement in the test plan:

The test plan will require setting up the test instruments to provide 320 Ohms across the key battery during the voltage measurement.



During the GFF test plan, the VAS 6345 resistor decade will be used together with the VAG 1594/19A extension leads.

- The voltage measurement is performed within the test plan, using the VAS 6356 test instrument box.
- The resistance will be validated within the test plan before proceeding to measure voltage.
- The free ends of the leads are held against the positive and negative sides of the key battery during the voltage measurement.

#### Overview of identifying the key remote data:


The following data will be requested within the GFF test plan (see examples below):

- The brand name of the battery.
- The part number of the remote control.
- The manufacturing date of the remote control in WW/YY format.



Release date:

2/19/2024



Identification of data for Hella remote key.



Identification of data for Continental remote key.



Release date:

2/19/2024

# Warranty

If a key battery is replaced, a completed GFF test plan must available to support the claim.

Model(s) Year(s)		Eng. Code(s)	Trans. Code(s)	s) VIN Range From		VIN Range To		
Golf, Go Atlas, A Cross S Tiguan, Arteon,	Atlas Sport, Jetta,	2020-2023		All	AII	All		AII
	T			SAGA	Coding			
Claim Type:  Use applicable Claim Type 1)								
Service Number:		Damage Code	нѕт		Damage Location (Depends on Service No.)			
5785		0040						
Parts Manufacturer		Atlas, Atlas Cross Sport, Arteon, Golf R, – battery replaced according to test plan		WWO <sup>2)</sup>				
		Tiguan, Jetta, Golf, Golf GTI, Taos – battery replaced according to test plan		3ME <sup>2)</sup>				
		ALL – Battery <u>not</u> replaced (diagnosis only, as test plan does not support replacement of key battery).		K21 <sup>2)</sup>				
<b>Labor Operation</b> <sup>3)</sup> : Radio remote sender repaired (battery replaced)			57854100 = see Elsa for latest time units + GFF Time expenditure.					
<b>Labor Operation</b> 3): Radio remote sender repaired (battery replaced) TAOS Only			57851900 = see Time expenditur		latest tim	ne units + GFF		



Release date:

2/19/2024

Labor Operation 3): Battery NOT (diagnosis)	replaced	Select GFF Time expenditure. (Max. 75 TU)		
Causal Part: (type CR2032 batter)	/)	N 10528301		
Causal Part: (type CR2025 battery)		N 10437301		
Diagnostic Time 4)				
GFF Time expenditure	01500000 = Actual GFF print out (75 TU max.)		YES	
Road Test	01210002 = 00 TU 01210004 = 00 TU		NO	
Technical Diagnosis	01320000 = 00 TU max.		NO	

Claim Comment: Input "As per Technical Bulletin 2055190" in comment section of Warranty Claim.

# **Required Parts and Tools**

No special parts required.

Tool Description	Tool No:
Midtronics Battery Tester/Maintainer	GRX3000VAS
	or
	MTRMSP0702
VAS Diagnostic Tool	VAS 6150/X & VAS 6160/X and ODIS Service with: current online updates
Test Instrument Box	VAS 6356
Resistor Decade Box	VAS 6345 (or equivalent)
Extension Leads	VAG 1594/19A (or equivalent)

<sup>1)</sup> Vehicle may be outside any Warranty in which case this Technical Bulletin is informational only

<sup>&</sup>lt;sup>2)</sup> Code per warranty vendor code policy.

<sup>3)</sup> Labor Time Units (TUs) are subject to change with ELSA updates.

<sup>&</sup>lt;sup>4)</sup> Documentation required per Warranty Policies and Procedures Manual.



57-19-02 - Remote Key Battery Replacement

Release date:

**Transaction No:** 

2/19/2024

2055190/5

## **Additional Information**

All part and service references provided in this Technical Bulletin are subject to change and/or removal. Always check with your Parts Dept. and Repair Manuals for the latest information.