

D25M3 and General Programming Best Practices

Topic Background:

- D25M3 was released shortly before the holiday
- This led to 50-60 cases per day coming into DTTS for programming issues

Topic Resolution Info:

- Diagnostic Link 8.23 is required for programming D25M3
- Step 7 of campaign was added to improve programming efficiency
 - Cases now down to 20-30 per day
- Go to the 'Program 'Device' tab, remove all previously downloaded data from older units and then on the "Software" tab, click "Refresh all software."
- *This is good practice for all programming even if not involved with D25M3 when possible*
 - If this step is not completed, it can lead to:
 - Not pulling down latest software available
 - Unable to program entirely
 - Incorrect parameters loaded
 - Manual Mainframe changes required
 - DTTS Case Creation likely needed

